

Draft Safety Guide on Modifications to Nuclear Power Plants (DS 497 B)

COMMENTS BY REVIEWER				RESOLUTION			
Reviewer: Country/Organisation : India		Page 1 .of 2 Date:19.03.2021					
Comment No.	Page/ Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification / Rejection
1.	Page 14/ Clause 4.29/	The procedures to be considered for revision should include operating procedures for normal operation, emergency operating procedures, severe accident management guidelines, surveillance and maintenance procedures, and calibration and testing procedures and plant instructions.	Changes should also be made in plant instructions as the Clause 4.27 of the same guide states that “When modifications are to be made to operational limits and conditions, the associated operating instructions and procedures should be modified accordingly”				
2.	Page-21 Para no. 7.21	...It should also include a check that the plant documentation including surveillance program has been revised to take into account the modification, ..	Although present text meets the intent, however, additional emphasis on Surveillance program may be beneficial.				

			Surveillance programme needs to be revised after implementation of the modification to ensure the completion of the modification.				
--	--	--	---	--	--	--	--