

20 October 2021

IAEA SAFETY STANDARDS
for protecting people and the environment

**Step 11: Approval by
Committee(s) for submission of
draft to Commission**

Safety of Uranium and Plutonium Mixed Oxide Fuel Fabrication Facilities (Revision of SSG-7)

DS 517–C

Revision of IAEA Safety Standards Series No. SSG-7

DRAFT SPECIFIC SAFETY GUIDE

CONTENTS

1. INTRODUCTION	1
Background.....	1
Objective.....	1
Scope.....	1
Structure.....	2
2. HAZARDS IN MOX FUEL FABRICATION FACILITIES	3
3. MANAGEMENT SYSTEM AND VERIFICATION OF SAFETY FOR MOX FUEL FABRICATION FACILITIES	4
Management responsibility.....	4
Resource management	5
Process implementation	6
Measurement, assessment, evaluation and improvement	7
Verification of safety	7
4. SITE EVALUATION FOR MOX FUEL FABRICATION FACILITIES	8
5. DESIGN OF MOX FUEL FABRICATION FACILITIES	9
Main safety functions.....	9
Postulated initiating events	16
Instrumentation and control	24
Human factor considerations	26
Safety analysis	27
Emergency preparedness and response.....	30
Management of radioactive waste	31
Management of gaseous and liquid effluents.....	32
Other design considerations.....	32
Ageing management considerations	34
6. CONSTRUCTION OF MOX FUEL FABRICATION FACILITIES	35
7. COMMISSIONING OF MOX FUEL FABRICATION FACILITIES	35
8. OPERATION OF MOX FUEL FABRICATION FACILITIES	37
Organization of operation of MOX fuel fabrication facilities	37
Staffing of a MOX fuel fabrication facility	37
Qualification and training of personnel	38
Operational documentation.....	39
Maintenance, calibration and periodic testing and inspection	41
Ageing management	42
Control of modifications.....	42
Control of nuclear criticality hazards.....	43
Radiation protection.....	44
Industrial and chemical safety	47
Management of radioactive waste and effluents.....	48
Emergency preparedness and response.....	48
Feedback of operating experience	49

9. PREPARATION FOR DECOMMISSIONING OF MOX FUEL FABRICATION FACILITIES	50
REFERENCES.....	1
ANNEX I TYPICAL PROCESS ROUTES IN A MOX FUEL FABRICATION FACILITY	4
ANNEX II EXAMPLES OF STRUCTURES, SYSTEMS AND COMPONENTS IMPORTANT TO SAFETY AND POSSIBLE CHALLENGES TO SAFETY FUNCTIONS FOR MOX FUEL FABRICATION FACILITIES	5
ANNEX III EXAMPLES OF PARAMETERS FOR DEFINING OPERATIONAL LIMITS AND CONDITIONS FOR MOX FUEL FABRICATION FACILITIES	10
CONTRIBUTORS TO DRAFTING AND REVIEW.....	13

1. INTRODUCTION

BACKGROUND

1.1. Requirements for all the important areas of safety in all stages of the lifetime of a nuclear fuel cycle facility are established in IAEA Safety Standards Series No. SSR-4, Safety of Nuclear Fuel Cycle Facilities [1].

1.2. This Safety Guide provides specific recommendations on the safety of uranium and plutonium mixed oxide (MOX) fuel fabrication facilities.

1.3. Plutonium is a valuable energy resource that arises from the civil and military industries in a number of States. When plutonium oxide is mixed with uranium oxide, the resulting mixed oxide can be fabricated into fuel suitable for loading into thermal reactors and fast reactors, thereby utilizing this energy resource.

1.4. The MOX fuel fabrication processes rely to a large extent on passive and active engineered safety measures in addition to administrative controls to ensure safety. The potential hazards of a MOX fuel facility are release of actinides (plutonium, americium and uranium in order of significance), increased radiotoxicity due to trans-uranium actinides, and nuclear criticality.

1.5. The toxicity of plutonium is high and therefore it is important that best practices be employed at all stages of the fabrication of MOX fuel, and that plutonium be handled, processed, treated and stored safely. It is important that best practices are also considered as part of applying optimization to the generation and management of all radioactive wastes and effluents generated in MOX fuel fabrication facilities.

1.6. This Safety Guide supersedes IAEA Safety Standard Series No. SSG-7, Safety of Uranium and Plutonium Mixed Oxide (MOX) Fuel Fabrication Facilities¹.

OBJECTIVE

1.7. The objective of this Safety Guide is to provide recommendations on siting, design, construction, commissioning, operation including management for safety, and preparation for decommissioning of MOX fuel fabrication facilities to meet the requirements established in SSR-4 [1].

1.8. The recommendations in this Safety Guide are aimed primarily at operating organizations of MOX fuel fabrication facilities, regulatory bodies, designers and other relevant organizations.

SCOPE

1.9. The safety requirements applicable to fuel cycle facilities (i.e. facilities for uranium refining, conversion, enrichment, reconversion², storage of fissile material, fabrication of fuel including MOX fuel, storage and reprocessing of spent fuel, associated conditioning and storage of waste, and facilities for fuel cycle related research and development) are established in SSR-4. [1]. This Safety Guide provides recommendations on meeting these requirements for MOX fuel fabrication facilities.

1.10. This Safety Guide deals with the handling, processing, material transfer, and storage of: (1) plutonium oxide powder; (2) depleted, natural or reprocessed uranium oxide powder as related to MOX

¹ INTERNATIONAL ATOMIC ENERGY AGENCY, Safety of Uranium and Plutonium Mixed Oxide Fuel Fabrication Facilities, IAEA Safety Standards Series No. SSG-7, IAEA, Vienna (2010).

² Often called also 'deconversion'

fuel fabrication facilities; (3) MOX fuel pellets, rods and assemblies fabricated from plutonium oxide and uranium oxide powders for use in thermal reactors and fast reactors. This Safety Guide deals also with the generation and management of wastes and effluents arising from the handling and processing of these materials.

1.11. This Safety Guide is limited to the safety of MOX fuel fabrication facilities; it does not deal with any impact that the fabricated fuel assemblies might have on safety for the reactors in which they are to be used.

1.12. The fuel fabrication processes covered by this Safety Guide are dry processes and processes related to mixing and processing of uranium dioxide and plutonium dioxide powders. Wet MOX fabrication process and the production of oxide powders are not addressed in this Safety Guide. IAEA Safety Standards Series Nos SSG-6 (Rev. 1), Safety of Uranium Fuel Fabrication Facilities [2], and SSG-42, Safety of Nuclear Fuel Reprocessing Facilities [3] provide additional recommendations on the safety of producing uranium and plutonium oxide powders.

1.13. This Safety Guide covers the production of MOX fuel from mixtures of uranium and plutonium oxides, obtained by either blending separate uranium oxide powders and plutonium oxide powders or as a prepared blend. Many aspects, such as the facility design, the safety analysis and the operation of the facility, depend on the nuclide compositions of these oxides. This Safety Guide covers all combinations of oxide composition possible.

1.14. The recommendations on ensuring criticality safety in a MOX fuel fabrication facility in this publication supplement the recommendations provided in IAEA Safety Standards Series No. SSG-27, Criticality Safety in the Handling of Fissile Material [4].

1.15. The implementation of safety requirements on the legal and governmental framework and regulatory supervision (e.g. requirements for the authorization process, regulatory inspection and regulatory enforcement) as established in IAEA Safety Standards Series No. GSR Part 1 (Rev.1), Governmental, Legal and Regulatory Framework for Safety [5] is not addressed in this Safety Guide.

1.16. This Safety Guide does not include recommendations on nuclear security for a MOX fuel fabrication facility. Recommendations on nuclear security are provided in IAEA Nuclear Security Series No. 13, Nuclear Security Recommendations on Physical Protection of Nuclear Material and Nuclear Facilities (INFCIRC/225/Revision 5) [6] and guidance is provided in IAEA Nuclear Security Series No. 27-G, Physical Protection of Nuclear Material and Nuclear Facilities (Implementation of INFCIRC/225/Revision 5) [7]. However, this Safety Guide includes recommendations on managing interfaces between safety, nuclear security and the State system for nuclear material accounting and control.

STRUCTURE

1.17. Section 2 provides recommendations on the management system for a MOX fuel fabrication facility. Section 3 provides recommendations on the development of a management system for a MOX fuel fabrication facility and the activities associated with it. Section 4 describes the safety aspects to be considered in the evaluation and selection of a site to avoid or minimize any environmental impact of operations. Section 5 addresses safety in the design stage: it provides recommendations on the safety analysis for operational states and accident conditions and covers the safety aspects of radioactive waste management in the MOX fuel fabrication facility and other design considerations. Section 6 addresses the safety aspects in the construction stage. Section 7 addresses safety considerations in commissioning. Section 8 deals with safety in the stage of operation of the facility: it provides recommendations on the management of operation, maintenance and periodic testing, control of modifications, criticality control,

radiation protection, industrial safety, the management of waste and effluents, and emergency preparedness and response. Section 9 provides recommendations on meeting the safety requirements for the preparation for decommissioning of a MOX fuel fabrication facility. Annex I shows the typical process routes for a MOX fuel fabrication facility. Annex II provides examples of structures, systems and components important to safety in MOX fuel fabrication facilities, grouped in accordance with process areas. Annex III provides examples of parameters for defining the operational limits and conditions for a MOX fuel fabrication facility.

2. HAZARDS IN MOX FUEL FABRICATION FACILITIES

2.1. In MOX fuel fabrication facilities, large amounts of fissile material and radioactive material are present in a dispersible form. This is particularly the case in the early stages of the fuel fabrication process, when the material is in powder form. In addition, the radioactive material encountered exists in diverse physical forms. Thus, in MOX fuel fabrication facilities the main hazards are potential nuclear criticality, loss of confinement and radiation exposure (both internal and external).

2.2. In MOX fuel fabrication facilities, plutonium oxide (PuO_2) and uranium oxide (UO_2) or mixed oxide are processed. The factors affecting the safety of a MOX fuel fabrication facility include the following:

- Plutonium having high radiological toxicity, the consequences to the personnel, the public and the environment following an accident might be expected to be high;
- The powder processes used for MOX fuel fabrication have a potential for the dispersion of radioactive material;
- The isotopic characteristics of plutonium have an effect on nuclear criticality safety, radiation exposure and heat generation.

2.3. External exposure assessment should include exposure due to neutron emission from ^{238}Pu and ^{240}Pu isotopes and gamma radiation from ^{241}Am , which is formed through the radioactive decay of ^{241}Pu during storage. Gamma radiation from ^{228}Th decay products (including ^{208}Tl) should also be considered.

2.4. The decay heat of ^{238}Pu should be included in the calculation of heat generation.

2.5. A MOX fuel fabrication facility using only dry processes does not store or process significant quantities of hazardous chemicals. Thus, chemical hazards that could lead to radiological consequences are low. However, this would not be the case for MOX fuel fabrication facilities using wet processes. To meet the requirements established in SSR-4 [1], the operating organization is required to perform a safety analysis in which potential accidents are analysed to ensure that they are adequately prevented, detected and, if they do occur, that their consequences are mitigated. This requires application of the concept of defence in depth (see Requirement 10 of SSR-4 [1]). For the MOX fuel fabrication facility to remain in a safe state also when the fuel fabrication process is stopped (i.e. there is no movement or transfer of material), the following systems should continue to operate:

- Heat removal systems in storage areas to remove decay heat from reactor grade plutonium;
- Systems supporting confinement functions to supplement the physical confinement barriers and to provide mitigation and monitoring of radioactive discharges;
- Inert gas feed systems of sintering furnaces or gloveboxes;
- Criticality accident detection and alarm systems.

3. MANAGEMENT SYSTEM AND VERIFICATION OF SAFETY FOR MOX FUEL FABRICATION FACILITIES

3.1. A documented management system that integrates safety, health, environmental, security, quality, and human and organizational factors of the operating organization is required to be established and implemented with adequate resources, in accordance with Requirement 4 of SSR-4 [1]. The integrated management system should be established and put into effect by the operating organization, early in the design stage of a MOX fuel fabrication facility, to ensure that safety measures are specified, documented, implemented, monitored, audited and periodically reviewed throughout the lifetime of the facility or the duration of the activity.

3.2. Requirements for the management system are established in GSR Part 2 [8]. Associated recommendations are provided in IAEA Safety Standards Series Nos GS-G-3.1, Application of the Management System for Facilities and Activities [9], GS-G-3.5, The Management System for Nuclear Installations [10], GSG-16, Leadership, Management Sys and Culture for Safety in Radioactive Waste Management [11], and TS-G-1.4, The Management System for the Safe Transport of Radioactive Material [12].

3.3. Coordination of the nuclear safety and security interface in the establishment of the integrated management system should be ensured. The management system should consider the specific concerns of each discipline regarding the management of information. Potential conflicts between the need for transparency of information relating to safety matters and the need for protection of information for security reasons should be addressed.

3.4. In determining how the management system for the safety of MOX fuel fabrication facilities is to be developed and applied, a graded approach is required to be used: see Requirement 7 and para. 4.15 of GSR Part 2 [8]. This approach should be based on the relative importance to safety of each item or process.

3.5. The management system is required to support the development and maintenance of a strong safety culture, including in all aspects of criticality safety: see Requirement 12 of GSR Part 2 [8].

3.6. In accordance with paras 4.15–4.23 of SSR-4 [1], the management system is required to address the following functional areas:

- (a) Management responsibility, which includes the necessary support and commitment of the management to achieve the objectives of the operating organization.
- (b) Resource management, which includes the measures necessary to ensure that the resources essential to the implementation of safety policy and the enhancement of safety and the achievement of the objectives of the operating organization are identified and made available.
- (c) Process implementation, which includes the actions and tasks necessary to achieve the goals of the operating organization.
- (d) Measurement, assessment, evaluation and improvement, which provide an indication of the effectiveness of management processes and work performance compared with objectives or benchmarks. It is through measurement, assessment and evaluation that opportunities for improvement are identified.

MANAGEMENT RESPONSIBILITY

3.7. The prime responsibility for safety, including criticality safety, rests with the operating organization. In accordance with para. 4.11 of GSR Part 2 [8], the management system for a MOX fuel fabrication facility is required to clearly specify the following:

- (a) A description of the organizational structure;
- (b) Functional responsibilities;
- (c) Levels of authority.

3.8. The documentation of the management system should describe the interactions among the individuals managing, performing and assessing the adequacy of the processes and activities important to safety. The documentation should also cover other management measures, including planning, scheduling and resource allocation (see para. 9.9 of SSR-4 [1]).

3.9. Paragraph 4.15 of SSR-4 [1] states:

“The management system shall include provisions for ensuring effective communication and clear assignment of responsibilities, in which accountabilities are unambiguously assigned to individual roles within the organization and to suppliers, to ensure that processes and activities important to safety are controlled and performed in a manner that ensures that safety objectives are achieved.”

The management system should include arrangements for empowering relevant personnel to stop unsafe operations at the MOX fuel fabrication facility.

3.10. The operating organization is required to ensure that safety assessments and analyses are conducted, documented and updated: see Requirement 24 and para. 4.65 of IAEA Safety Standards Series No. GSR Part 4 (Rev. 1), Safety Assessment for Facilities and Activities [13] and Requirement 5 of SSR-4 [1].

3.11. In accordance with para. 4.2(d) of SSR-4 [1], the operating organization is required to audit all safety related matters on a regular basis. This should include the examination of arrangements for emergency preparedness and response, such as emergency communications, evacuation routes and signage. Checks should be performed by the nuclear criticality safety staff who performed the safety assessments to confirm that the data used and the implementation of criticality safety measures are correct. Audits should be performed by personnel who are independent of those that performed the safety assessments or conducted the activities important for safety. The data from audits should be documented and submitted for management review and for action, if necessary.

RESOURCE MANAGEMENT

3.12. The operating organization is required to provide adequate resources (both human and financial) for the safe operation of the MOX fuel fabrication facility (see Requirement 9 of GSR Part 2 [8]), including resources for mitigating the consequences of accidents.

3.13. The management of the operating organization should undertake the following:

- (a) Determine the necessary competence of personnel, and provide training, as necessary;
- (b) Prepare and issue specifications and procedures on safety related activities and operations;
- (c) Support and performing safety assessments including modifications;
- (d) Have frequent personal contact with personnel, including observing work in progress;
- (e) Make provisions for adequate staffing³, succession planning and retention of corporate knowledge.

³ Including for situations where a large number of personnel might be unavailable, such as during an epidemic or a pandemic affecting an area where personnel live.

3.14. Requirement 58 of SSR-4 [1] states that:

“The operating organization shall ensure that all activities that may affect safety are performed by suitably qualified and competent persons”.

3.15. In accordance with requirement 58 and paras 9.39–9.47 of SSR-4 [1], the operating organization is required to ensure that these personnel receive training and refresher training at suitable intervals, appropriate to their level of responsibility. In particular, personnel involved in activities with fissile material (both uranium and plutonium), radioactive material including waste and with chemicals should understand the nature of the hazard posed by these materials and how the risks are controlled by the established safety measures, operational limits and conditions, and operating procedures..

3.16. Requirement 11 of GSR Part 2 [8] states that:

“The organization shall put in place arrangements with vendors, contractors and suppliers for specifying, monitoring and managing the supply to it of items, products and services that may influence safety”

In accordance with paras 4.33–4.36 of GSR Part 2 [8], the management system for a MOX fuel fabrication facility is required to include arrangements for procurement.

In accordance with para. 4.16(b) of SSR-4 [1], the operating organization is required to ensure that suppliers of items and resources important to safety have an effective management system in place. To meet these requirements, the operating organization should conduct audits of the management systems of the suppliers.

PROCESS IMPLEMENTATION

3.17. Requirement 63 of SSR-4 [1] states:

“Operating procedures shall be developed that apply comprehensively for normal operation, anticipated operational occurrences and accident conditions, in accordance with the policy of the operating organization and the requirements of the regulatory body.”

Paragraph 9.66 of SSR-4 states that:

“Operating procedures shall be developed for all safety related operations that may be conducted over the entire lifetime of the facility.”

The operating procedures should specify all parameters which are intended to be controlled and the criteria that should be fulfilled.

3.18. The management system for a MOX fuel fabrication facility should include management for criticality safety. Further recommendations on the management system for criticality safety are provided in SSG-27 [4].

3.19. Any proposed modification to existing facilities or activities, or proposals for introduction of new activities, are required to be assessed for their implications on existing safety measures and appropriately approved before implementation: see paras 9.57(b)-(c) of SSR-4 [1]. Modifications of safety significance are required to be subjected to safety assessment and regulatory review and, where necessary, they are required to be authorized by the regulatory body before they are implemented: see paras 9.57(h) and 9.59 of SSR-4 [1]. The facility or activity documentation is required to be updated to reflect modifications (see paras 9.57 (f)–(g) of SSR-4 [1]). The operating personnel, including supervisors, should receive adequate training on the modifications.

3.20. Requirement 75 of SSR-4 [1] states:

“The interfaces between safety, security and the State system of accounting for, and control of, nuclear material shall be managed appropriately throughout the lifetime of the nuclear fuel cycle facility. Safety measures and security measures shall be established and implemented in a coordinated manner so that they do not compromise one another.”

The activities for ensuring safety throughout the lifetime of the facility or duration of the activity involve different groups and interface with other areas such as those relating to nuclear security and to the system for nuclear material accounting and control. The activities with such interfaces should be identified in the management system, coordinated, planned and conducted to ensure effective communication and clear assignment of responsibilities. Communications regarding safety and security should ensure that confidentiality of information is maintained. This includes the system of nuclear material accounting and control, for which information security should be coordinated in a manner ensuring that subcriticality is not compromised.

MEASUREMENT, ASSESSMENT, EVALUATION AND IMPROVEMENT

3.21. The audits performed by the operating organization (see para. 3.11), as well as proper control of modifications to facilities and activities (see para. 3.19) are particularly important for ensuring subcriticality. The results of audits are required to be evaluated by the operating organization and corrective actions to be taken where necessary: see para. 4.2(d) of SSR-4 [1].

3.22. Deviation from operational limits and conditions, deviations from operating procedures and unforeseen changes in process conditions that could affect nuclear criticality safety are required to be reported and promptly investigated by the operating organization, and the operating organization is required to inform the regulatory body: see paras 9.34, 9.35 and 9.84 of SSR-4 [1]. The depth and extent of the investigation should be proportionate to the safety significance of the event, in accordance with a graded approach. The investigation should cover the following:

- (a) An analysis of the causes of the deviation to identify lessons and to determine and implement corrective actions to prevent a recurrence;
- (b) An analysis of the operation of the facility or conduct of the activity including an analysis of human factors;
- (c) A review of the safety assessment and analyses that were previously performed, including the safety measures that were originally established.

3.23. Requirement 73 of SSR-4 [1] states that **“[t]he operating organization shall establish a programme to learn from events at the facility and events at other nuclear fuel cycle facilities and in the nuclear industry worldwide.”** Recommendations on operating experience programmes are provided in IAEA Safety Standards Series No. SSG-50, Operating Experience Feedback for Nuclear Installations [14].

VERIFICATION OF SAFETY

3.24. In accordance with Requirement 5 of SSR-4 [1], the safety of a MOX fuel fabrication facility is required to be assessed in the safety analysis and verified by periodic safety reviews. The operating organization should ensure that these periodic safety reviews of the facility form an integral part of the organization’s management system.

3.25. Requirement 6 of SSR-4 [1] states, that: **“[a]n independent safety committee (or an advisory group) shall be established to advise the management of the operating organization on all safety aspects of the nuclear fuel cycle facility.”**

3.26. The safety committee of a MOX fuel fabrication facility should have members or access to experts in areas of human factors, criticality safety as well as radiation protection. Such experts should be available to the facility at all times during operation.

4. SITE EVALUATION FOR MOX FUEL FABRICATION FACILITIES

4.1. The site evaluation process for a MOX fuel fabrication facility will depend on a large number of variables. At the earliest stage of planning a facility, a list of these variables should be prepared and considered in accordance with their safety significance. The risks posed by possible significant external hazards (e.g. earthquakes, accidental aircraft crashes, fires, nearby explosions, floods, extreme weather conditions) will probably dominate in the site evaluation process and should be taken into account in the design of the facility. Requirements for site evaluation for MOX fuel fabrication facilities are provided in IAEA Safety Standards Series No. SSR-1, Site Evaluation for Nuclear Installations [15] and further recommendations are provided in IAEA Safety Standards Series No. SSG-35, Site Survey and Site Selection for Nuclear Installations [16].

4.2. The scope of the site evaluation for a MOX fuel fabrication facility is established in Requirement 3 of SSR-1 [15] and Requirement 11 and paras 5.1–5.14 of SSR-4 [1] and should reflect the specific hazards listed in Section 2 of this Safety Guide.

4.3. For a MOX fuel fabrication facility, where a dry process is used to manufacture fuel, appropriate design and operation can ensure that gaseous releases are negligible under normal operating conditions. The major hazard in accident conditions is the potential release of plutonium (as plutonium oxide or MOX) as particles to the atmosphere or to the air of the working zone.

4.4. A MOX fuel fabrication facility should be considered to be a facility with a high hazard potential. This should be taken into consideration when applying a graded approach to the implementation of the requirements of SSR-4 [1] to the facility. The following characteristics of the site should be considered to ensure the safety of the facility:

- *Legal requirements.* Using a site for which regulatory consent to process plutonium has already been granted.
- *Transport links.* Minimizing the distance by which fissile material needs to be transported (for example, by siting a MOX fuel fabrication facility on the same site as plutonium production).

Combined hazards and hazard interactions between the facilities on the same site should be understood and taken into consideration.

4.5. The population density and population distribution in the vicinity of a MOX fuel fabrication facility are required to be considered in the site evaluation process to minimize any possible health consequences for people in the event of a release of radioactive material and hazardous chemicals: see Requirements 4 and 12 of SSR-1 [15]. Also, in accordance with Requirement 25 and paras 6.1–6.2 of SSR-1 [15], the dispersion in air and water of radioactive material released from the MOX fuel fabrication facility are required to be assessed taking into account the orography, land cover and meteorological features of the region. The environmental impact from the facility under all facility states is required to be evaluated (see para. 5.3 of SSR-4 [1]) and should meet the applicable criteria.

4.6. Security advice is required to be taken into account in the selection of a site for a MOX fuel fabrication facility: see para. 11.4 of SSR-4 [1]. Considering the presence of plutonium in the facility, special attention should be given to the management of the interface between nuclear safety and nuclear security during site evaluation (Requirement 75 of SSR-4 [1]). The selection of a site should take into

account both safety and security aspects and should be facilitated by experts from both safety and security.

4.7. Even if an existing nuclear site is used for a MOX fuel fabrication facility, the site evaluation should be performed using a similar process as that for the siting of a new facility at a new site (see paras 3.24–3.27 of SSG-35 [16]).

4.8. The operating organization should maintain a full record of the decisions taken on the selection of a site for a MOX fuel fabrication facility and the reasons behind those decisions.

4.9. The site characteristics should be reviewed periodically for their adequacy and persistent applicability during the lifetime of a MOX fuel fabrication facility. Any changes to these characteristics which might require safety reassessment should be identified and evaluated (see para. 5.14 of SSR-4 [1]). This includes the case of an increase of a production capacity beyond the original envelope.

5. DESIGN OF MOX FUEL FABRICATION FACILITIES

MAIN SAFETY FUNCTIONS

5.1. Requirement 7 of SSR-4 [1] states:

“The design shall be such that the following main safety functions are met for all facility states of the nuclear fuel cycle facility:

- (a) Confinement and cooling of radioactive material and associated harmful materials;**
- (b) Protection against radiation exposure;**
- (c) Maintaining subcriticality of fissile material.”**

All these safety functions are applicable to MOX fuel fabrication facilities.

5.2. The requirements on the confinement and cooling of radioactive material are established in Requirements 35 and 39 and paras 6.123–6.128 and 6.157–6.159 of SSR-4 [1].

5.3. The requirements on protection against internal radiation exposure are established in Requirement 34 and paras 6.120–6.122 of SSR-4 [1]. The requirements on protection against external radiation exposure are established in Requirement 36 and paras 6.129–6.134 of SSR-4 [1]. Concerning the radiation associated with plutonium (neutron emissions and gamma radiation), an appropriate combination of requirements on source limitation, distance, time and shielding is necessary for the protection of personnel in respect of whole body exposure, exposure of the hands and exposure of the lens of the eye. For neutron emissions, a general design principle is to place the shielding as close as possible to the source. In some cases, remote operation should be considered if necessary. Individual monitoring of neutron doses for the personnel should be conducted in addition to individual monitoring of gamma radiation.

5.4. The requirements on maintaining subcriticality are established in Requirement 38 and paras 6.138–6.156 of SSR-4 [1]. Recommendations on the design of a MOX fuel fabrication facility to ensure subcriticality are provided in Section 3 of SSG-27 [4].

Design basis and safety analysis

5.5. A design basis accident is a postulated accident leading to accident conditions for which a facility is designed in accordance with established design criteria and conservative methodology, and for which

releases of radioactive material are kept within acceptable limits [1].

5.6. The safety requirements relating to design basis for items important to safety and for the design basis analysis for a nuclear fuel cycle facility are established in Requirements 14 and 20 of SSR-4 [1], respectively.

5.7. The specification of a design basis (or equivalent) will depend on the design of the facility, its siting and regulatory requirements. However, particular consideration should be given to the following hazards in the specification of the design basis safety analysis for MOX fuel fabrication facilities:

- (a) Release of plutonium inside and/or outside of the facility;
- (b) Internal and external hazards, including internal and external explosions (in particular hydrogen explosions), internal and external fires, dropped loads and handling errors, extreme meteorological phenomena (in particular earthquakes, flooding and tornadoes), accidental aircraft crashes.

5.8. These hazards are of major safety significance as they might result in radiological consequences for the facility personnel. In addition, these hazards could also result in some adverse off-site consequences for the public or the environment.

5.9. The hazards listed in para. 5.7 might occur as a consequence of a postulated initiating event. Selected postulated initiating events for MOX fuel fabrication facilities are provided in the Appendix of SSR-4 [1].

Structures, systems and components important to safety

5.10. Paragraph 6.21 of SSR-4 [1] states that:

“The design of the nuclear fuel cycle facility: [...]”

- (e) Shall provide for structures, systems and components and procedures to control the course of and, as far as practicable, to limit the consequences of failures and deviations from normal operation that exceed the capability of safety systems.”

Annex II of this Safety Guide presents examples of structures, systems and components and representative events that might challenge the associated safety functions in MOX fuel fabrication facilities.

Confinement of radioactive material

5.11. To meet Requirement 35 of SSR-4 [1] in a MOX fuel fabrication facility, three static barriers (or more, as dictated by the safety analysis) should be provided, in accordance with a graded approach. The first static barrier normally consists of gloveboxes, fuel claddings, material containers or other equipment containing radioactive material. The second static barrier normally consists of the rooms around the gloveboxes. The third static barrier is the building itself. The design of the static containment system should consider openings between the different confinement zones (e.g. doors, penetrations). Such openings should be designed to ensure that confinement is maintained in all operational states, especially during maintenance (e.g. by the provision of permanent or temporary additional barriers) and, as far as practicable, in accident conditions.

5.12. Each physical barrier of the containment system should be complemented by one or more associated systems, which should establish a cascade of pressure between the environment outside the building and the air that might contain contaminated material inside the building, and across all static barriers within the building. The associated systems should be designed to prevent the movement or diffusion of radioactive or toxic gases, vapours and airborne particulates through any openings in the

barriers to areas of lower contamination or concentration of these materials. The design of the associated systems should address the following, as far as applicable:

- (a) Operational states and accident conditions;
- (b) Maintenance, which may cause localized changes to conditions (e.g. opening access doors, removing access panels);
- (c) Where more than one ventilation system is used, protection in case of a failure of a lower pressure (higher contamination) system, causing pressure differentials and airflows to be reversed;
- (d) The need to ensure that all static barriers, including any filters or other effluent control equipment, can withstand the maximum differential pressures and airflows generated by the system, including increasing the filter resistance during operation and considering conservative assumptions regarding the meteorological conditions.

5.13. Specific attention should be paid in the design to operations that lead to the transfer of contaminated materials outside the static containment system. Normal operations should not involve any transfer of radioactive powders outside the first barrier (with gloveboxes and tunnels linking them). Design features should be provided for removal of materials and items (such as waste or scrap) from the gloveboxes when needed.

5.14. Devices for monitoring air contamination should be included in the design of confinement areas close to working locations, especially at gloveboxes. The location of such devices should be finalized during cold commissioning, when precise airflows are established.

5.15. In confinement areas, appropriate equipment should be provided for monitoring surfaces for contamination. Contamination can be detected by smear sampling of surfaces or by using portable devices.

5.16. The design of a MOX fuel fabrication facility should be such as to facilitate operation, maintenance and decontamination activities. Building compartmentalization should be considered in the design to prevent contamination of large areas of the MOX fuel fabrication facility.

5.17. The ventilation system normally includes filters in series to protect the public and the environment. The air drawn into the ventilation system from the environment as well as the air discharged from the facility should be filtered. The filters filter the air during normal operation and ensure the continuity of the static barriers in the event of loss of ventilation.

5.18. The ventilation system should be designed and operated to minimize the opportunity for buildup of particulates. Appropriate procedures should be established, and instruments should be provided to control the potential buildup of plutonium powder or MOX powder particulates in the ventilation ducts and in the high efficiency particulate air (HEPA) filters.

5.19. Primary filters should be located as close to the source of contamination as practicable (e.g. near or in the gloveboxes) to minimize the potential buildup of plutonium powder or MOX particulates in the ventilation ducts. Multiple primary filters in series should preferably be used to prevent any transfer of contamination during maintenance of one of the filters.

5.20. Filtration should be provided at ventilation inlet points to prevent the loss of particulates due to reverse or static flow conditions in case of failure the ventilation system.

5.21. In addition, operating fans and standby fans should be provided and should be powered such that, in the case of loss of normal power, the uninterrupted functioning of glovebox ventilation systems is ensured. Local monitoring systems and alarm systems should be installed to alert operators to system malfunctions that might result in differential pressures that are considered too high or too low.

5.22. Last stage filters (see also para. 5.35) should be used to protect the public and the environment and should normally be located close to the location at which discharges to the environment occur.

5.23. To prevent the propagation of a fire through the ventilation ducts and to maintain the integrity of firewalls, ventilation systems should be equipped with fire and smoke dampers (see also para. 5.61).

5.24. At the design stage, provision should also be made for the installation of equipment for monitoring airborne radioactive material. Monitoring points should be chosen that would correspond most accurately to the exposure of personnel and would minimize the time for detection of any leakage from the first barrier.

5.25. The design of a MOX fuel fabrication facility should allow all planned activities associated with operation or maintenance to be performed without breaching the primary containment.

Protection of workers

5.26. Requirements on the design of MOX fuel fabrications facilities to ensure radiation protection are established in Requirement 8 of SSR-4 [1].

5.27. The first static barrier normally protects the workers. The specifications for the design of the first static barrier should be established to ensure and to control the integrity of this barrier. The design should include specifications for: welding; selection of materials; leaktightness (for gloveboxes, for the ratio of the leak rate to the flow rate); the ability to withstand seismic loads; the design of the equipment (internal equipment for gloveboxes); penetration seals for electrical and mechanical penetrations; and the ease of performing maintenance work.

5.28. Gloveboxes often consist of welded stainless steel enclosures with windows, arranged either singly or in interconnected groups. Access to equipment inside the glovebox is provided through access holes in the glovebox window that are fitted with gloves (made out of various materials depending on the work being performed in the glovebox) which maintain the confinement barrier.

5.29. Gloveboxes, fume hoods and filtered ventilation systems should be used to minimize the radiation exposure of personnel and their exposure to hazardous material that could become airborne and be inhaled. In addition, personal protective equipment should be used to avoid contamination of workers with radioactive material and other hazardous material, if protection cannot be achieved by design solutions only.

5.30. For normal operation, the need for the use of respiratory protection should be minimized through careful design of the static and dynamic containment systems and of devices for the immediate detection of low thresholds of airborne radioactive material. Respiratory protection during normal operation should be used only as a complementary means of protection in addition to existing barriers (see also paras 9.100–9.101 of SSR-4 [1]).

5.31. Audible alarm systems should be installed to alert operators of fan failures and of high or low differential pressures across filters. At the design stage, provision is also required to be made for the installation of equipment for monitoring airborne uranium concentration and/or gas concentration: see para. 6.120 of SSR-4 [1]. Monitoring points should be chosen that would correspond most accurately to the exposure of personnel and would minimize the time for detection of any leakage (see para. 6.121 of SSR-4 [1]).

5.32. To facilitate decontamination and decommissioning of the facility, the walls, floors and ceilings in areas of the uranium fuel fabrication facility where contamination is likely should be made non-porous and easy to clean. This may be done by applying special coatings, such as epoxy, to surfaces. In addition,

all surfaces that could become contaminated should be made readily accessible to allow for periodic decontamination as necessary.

Protection of the public and the environment

5.33. Paragraph 3.9 of IAEA Safety Standards Series No. GSR Part 3, Radiation Protection and Safety of Radiation Sources: International Basic Safety Standards GSR Part 3 [17] states that:

“Any person or organization applying for authorization: [...]

e) Shall, as required by the regulatory body, have an appropriate prospective assessment made for radiological environmental impacts, commensurate with the radiation risks associated with the facility or activity.

Further recommendations for performing environmental impact assessment of MOX fuel fabrication facilities are provided in IAEA Safety Standards Series No. GSG-10, Prospective Radiological Environmental Impact Assessment for Facilities and Activities [18].

5.34. The uncontrolled dispersion of radioactive substances to the environment as a result of an accident can occur if multiple confinement barriers are impaired. Barriers that may provide environmental protection comprise the room and the building itself. The provision of multiple redundant filters in parallel should be considered for the final stage of filtration before the discharge of exhaust gases through a stack. Filtration, including final stage filtration, also provides means of minimizing the release of radioactive particulates to the environment under normal operating conditions, usually reducing gaseous discharges to acceptably low levels.

5.35. The design of a MOX fuel fabrication facility should also provide measures for assuring that the performance of filtration is the same as that claimed in the facility safety analysis, particularly for the last stage filters. Provisions to assure the performance of filtration may include testing the particulate removal efficiency (such as aerosol challenge testing), differential pressure measurements and monitoring of alpha particles in ductwork. The design should make provisions to monitor the environment around the facility, and to identify breaches of the confinement barriers.

Protection against external exposure

5.36. Relevant requirements on design provisions for protection against external radiation exposure are established in Requirement 36 and paras 6.129–6.134 of SSR-4 [1].

5.37. External exposure of workers should be controlled by means of an appropriate combination of requirements on source reduction, distance, time and shielding. Owing to the specific activity of plutonium, the shielding provided by the vessels and/or gloveboxes of a MOX fuel fabrication facility might not be sufficient to control exposure adequately, and thus additional controls on time, distance and shielding should be considered, where necessary.

5.38. If necessary, consideration should be given to the remote operation of process equipment and the installation of equipment for powder collection to prevent any spreading of radioactive powder in gloveboxes.

5.39. Provision for shielding in material storage areas, at process gloveboxes (e.g. where powder processing or pellet processes are performed) and in the fuel assembly area should be considered.

Prevention of nuclear criticality

5.40. Prevention of nuclear criticality is an important topic with various aspects to be considered during the design and operation of a MOX fuel fabrication facility (see Requirement 38 of SSR-4 [1]). Paragraphs 5.41–5.49 provide recommendations on some of the main elements of criticality safety that are specific for uranium fuel fabrication facilities. Detailed recommendations on criticality safety are provided in SSG-27 [4].

5.41. The criticality safety analysis should demonstrate that the design of equipment and the related safety measures are such that the facility is in a subcritical state at all times, i.e. the values of the controlled parameters are always maintained in the subcritical range. This should be achieved by determining the effective multiplication factor (k_{eff}), which mainly depends on the mass, the geometry, the distribution and the nuclear properties of the fissionable material and all other materials with which it is associated. The calculated value of k_{eff} (including all uncertainties and biases) should then be compared with the value specified by the design limit (which should be set in accordance with paras 2.4–2.7 of SSG-27 [4]) and actions should be taken to maintain the value of k_{eff} under this limit.

5.42. Paragraph 6.142 of SSR-4 [1] states that “[f]or the prevention of criticality by means of design, the double contingency principle shall be the preferred approach”. For ensuring criticality safety in a MOX fuel fabrication facility one or more of the following parameters of the system should be kept within subcritical limits:

- (a) PuO₂ (receipt):
 - (i) Mass and geometry (limitation of the dimensions or shape) should be selected in accordance with the safety specification of PuO₂ isotopic composition and moderation;
 - (ii) Presence of appropriate neutron absorbers should be ensured.
- (b) UO₂ (receipt): Mass and geometry should be selected in accordance with the safety specification of UO₂ isotopic composition and moderation.
- (c) MOX powder (receipt or preparation): MOX powder is formed in the fuel fabrication process and the associated criticality hazard should be assessed in accordance with the isotopic specification and the PuO₂ content at each stage of the process:
 - (i) Mass, geometry and moderation should be considered.
 - (ii) Presence of appropriate neutron absorbers should be ensured.
- (d) MOX pellets: Mass, geometry and moderation should be selected in accordance with the isotopic specifications, the PuO₂ content and the size of the pellets.
- (e) Fuel rods: Geometry and moderation should be selected in accordance with the isotopic specifications, the PuO₂ content and the design of the rods (size and cladding).
- (f) Fuel assemblies: Geometry and moderation should be selected in accordance with the isotopic specifications, the PuO₂ content distribution in the different rods and the design of the assembly.

5.43. Some examples of the parameters subject to control for the prevention of criticality are as follows:

- (a) PuO₂ (receipt):
 - The isotopic composition of plutonium (ratios of the amount of a particular isotope of plutonium to the total amount of plutonium: ²³⁹Pu/Pu, ²⁴⁰Pu/Pu, ²⁴¹Pu/Pu, ²⁴²Pu/Pu). ²³⁸Pu should not be taken into account as its isotopic content and neutron properties are not as well qualified as for the other Pu isotopes.
 - The amount of moisture (degree of moderation) for control of criticality in the next stages of the MOX fuel fabrication process.
 - The upper bounded PuO₂ density.
- (b) UO₂ (receipt):

- The isotopic composition of uranium (the ratio of the amount of ^{235}U to the total amount of uranium: $^{235}\text{U}/\text{U}$). When this ratio is less than 1%, and given that there is no significant presence of deuterium, beryllium or graphite present in the facility, no criticality hazard is to be considered for uranium powders.
 - The amount of moisture (degree of moderation) for control of criticality in the next stages of the MOX fuel fabrication process.
 - The upper bounded UO_2 density.
- (c) MOX powder (receipt or preparation):
- The ratio of PuO_2 to the total amount of oxides ($\text{PuO}_2/(\text{UO}_2 + \text{PuO}_2)$);
 - The amount of moisture (degree of moderation) and the amount of additives (degree of moderation) for assessment of the criticality hazard at each stage of the process;
 - The upper boundary of the UO_2 - PuO_2 (MOX) density;
 - The presence of non-homogeneous distributions of moderators, if considered necessary.
- (d) MOX pellets (in addition to previous controls):
- Diameter range of the pellets.
- (e) Fuel rods (in addition to previous controls):
- Cladding thickness range of the rods.
- (f) Fuel assemblies (in addition to previous controls):
- Distribution of the fuel rods within the assembly.

5.44. In order to perform criticality analysis of a MOX fuel fabrication facility, the following input data should be specified:

- (a) The Pu and U isotopic composition;
- (b) The PuO_2 content of the final MOX powder mix ($\text{PuO}_2/(\text{UO}_2+\text{PuO}_2)$) value;
- (c) The maximum density of the final MOX powder mix;
- (d) The final moderator material content in the mix (powder moisture, hydrogen and carbon content (composition) of the additives).

5.45. Several methods that vary widely in basis and form can be used to perform the criticality safety analysis, such as the use of experimental data, reference books or consensus standards, hand calculations and calculations by means of deterministic or probabilistic computer codes. For more extensive recommendations on performing a criticality safety assessment, including recommendations on validation of computer codes see Section 4 of SSG-27 [4].

5.46. The criticality analysis should include the following:

- (a) The use of a conservative approach taking into account:
 - (i) Uncertainties in physical parameters, the physical possibility of optimal moderation conditions and the potential of non-homogeneous distributions of moderators;
 - (ii) Optimal geometry configuration of a system with fissile material;
 - (iii) Plausible operational occurrences and their combinations if they cannot be shown to be independent;
 - (iv) Operational states that might result from external hazards.
- (b) The use of appropriate verified and validated computer codes that are validated together with the appropriate data libraries of nuclear reaction cross-sections, for the normal and credible abnormal conditions being analysed, while taking into account any bias and its uncertainties (see paras 4.20–4.25 of SSG-27 [4]).

5.47. Consideration should be given to criticality safety during pelletizing the final MOX powder mix as the powder undergoes compression and changes geometry. The approach to the criticality safety including safety analysis after this stage in the production is similar to the approach undertaken in a uranium fuel fabrication facility with additional considerations applicable to plutonium in MOX as presented in SSG-27 [4].

5.48. The following are recommendations for conducting a criticality analysis for a MOX fuel fabrication facility to meet the safety requirements established in para. 6.144 of SSR-4 [1]:

- *Enrichment.* In criticality calculations the use of an ‘effective enrichment’⁴ should be avoided unless the validity of the data used can be demonstrated with a high level of confidence.
- *Mass.* The mass margin should be sufficient to compensate for possible over-batching of PuO₂ or MOX, or under-batching of UO₂.
- *Geometry.* The potential for changes in dimensions during operational states and accident conditions is required to be considered (e.g. bulging of slab hoppers) in accordance with para. 6.144(d) of SSR-4 [1].
- *Concentration, density and form of materials (in an analytical laboratory and in liquid effluent units).* The analysis should cover a range of: (i) plutonium and uranium concentrations for solutions; and (ii) powder and pellet densities and moderators for different forms of MOX (e.g. powder, green and sintered pellets, rods), to determine the most reactive conditions that could occur.
- *Moderation.* Water, oil and other hydrogenous substances such as additives are common moderators that are present in MOX fuel fabrication facilities or that might be present in accident conditions (e.g. water from firefighting). Special consideration should be given to cases of non-homogeneous moderation.
- *Reflection.* The most conservative margin should be retained of those resulting from different assumptions such as: (i) a hypothetical thickness of water around the processing unit; and (ii) consideration of the actual neutron reflection effect due, for example, to the presence of human beings, organic materials, shielding materials, or the concrete or steel of the container in or around the processing unit. Consideration should be given to situations where material might be present that could lead to a greater increase of the neutron multiplication factor than in a full water reflection system.
- *Neutron interaction.* Consideration should be given to neutron interaction between all facility parts. This includes the minimum distance of mobile units containing UO₂ or PuO₂ and the engineered means for ensuring the minimal distance between equipment containing UO₂ or PuO₂.
- *Neutron absorbers.* The neutron absorbers that may be used in MOX fuel fabrication facilities include cadmium and boron and the safety analysis should incorporate their effect as neutron absorbers; however, ignoring their effects would yield conservative results. The use of mobile neutron absorbers should be avoided. Absorber parameters include thickness, density and nuclide composition of both the absorber material and the hydrogenated material used to increase its absorption efficiency (if applicable).

5.49. For processes in which fissile material is handled in a discontinuous manner (batch processing), the process and the related equipment should be designed to ensure that fissile material is transferred only when the limits defined for the next process are satisfied.

POSTULATED INITIATING EVENTS

5.50. In accordance with para. 6.60 of SSR-4 [1], postulated initiating events for detailed further analysis from the list of internal and external hazards are required to be identified for MOX fuel

⁴ Effective enrichment takes into account the neutron absorption characteristics of elements and isotopes present such as gadolinium, ²³⁶U, ²³⁸Pu or ²⁴⁰Pu.

fabrication facilities.

Internal hazards

Fire and explosion

5.51. Fire in MOX fuel fabrication facilities might lead to the dispersion of radioactive material by breaching the confinement barriers or might cause a criticality accident by affecting the system or the parameters used for the control of criticality (e.g. the moderation control system or the dimensions of the processing equipment). Special consideration should be given to the fire extinguishing media deployed, and their potential moderation effect.

5.52. The fire hazards that are specifically encountered in a MOX fuel fabrication facility are associated with the presence of flammable and combustible materials such as electrical cabling and shielding, in particular when associated with gloveboxes and hydrogen in the sintering furnaces.

Fire hazard analysis

5.53. As an important aspect of fire hazard analysis for a MOX fuel fabrication facility, areas of the facility that need special consideration should be identified (see Requirement 22 of SSR-4 [1]). Fire hazard analyses of the facility should give particular consideration to the following:

- (a) Areas where fissile material is processed and stored;
- (b) Gloveboxes, especially those in which nuclear material is processed as powder or powder is produced;
- (c) Workshops and laboratories in which flammable liquids and/or combustible liquids, solvents and resins and reactive chemicals are used, or zirconium metal is mechanically treated (e.g. producing cuttings or shavings);
- (d) Areas with high fire loads, such as waste storage areas;
- (e) Waste treatment areas;
- (f) Rooms housing safety related equipment, for example items such as air filtering systems, and electrical switch rooms, whose ageing issues might lead to radiological consequences or consequences in terms of criticality that are considered to be unacceptable;
- (g) Process control rooms and emergency control rooms;
- (h) Evacuation routes.

5.54. An analysis of fire and explosion is required to be conducted for MOX fuel fabrication facilities to meet Requirement 22 and the requirements established in paras 6.77–6.79 of SSR-4 [1]. Fire hazard analysis should involve identification of the causes of fires, assessment of the potential consequences of a fire and, where appropriate, estimation of the frequency or probability of occurrence of fires. Fire hazard analysis should be used to assess the inventory of fuels and initiation sources, and to determine the appropriateness and adequacy of measures for fire protection. Computer modelling of fires may sometimes be used in support of the fire hazard analysis.

5.55. The estimation of the likelihood of fires can be used as a basis for making decisions or for identifying weaknesses that might otherwise go undetected. Even if the estimated likelihood of fire may seem low, a fire might have significant consequences for safety, and thus certain protective measures should be undertaken, such as delineating small fire areas, to prevent fires or prevent the fire from spreading.

5.56. The analysis of fire hazards should also involve a review of the provisions made at the design stage for preventing, detecting and mitigating fires.

Fire prevention, detection and mitigation

5.57. Prevention is the most important aspect of fire protection. Facilities should be designed to limit fire risks through the incorporation of measures to ensure that fires do not break out. Measures for mitigation should be put in place to minimize the consequences of a fire in the event that a fire breaks out despite preventive measures.

5.58. To accomplish the twofold aim of fire prevention and mitigation of the consequences of a fire, a number of general and specific measures should be taken, including the following:

- (a) Minimization of the amount of combustible material present in gloveboxes; nevertheless it may be necessary to maintain an inert atmosphere and install alarm systems for monitoring oxygen levels to minimize the probability a large fire.
- (b) Separation of the areas where non-radioactive hazardous material is stored from the process areas.
- (c) Minimization of the fire load of individual rooms.
- (d) Selection of materials, including building materials, process components and glovebox components and materials for penetrations, in accordance with functional criteria and fire resistance ratings.
- (e) Compartmentalization of the building and ventilation ducts as far as possible to prevent the spreading of fires. The building should be divided into fire zones and the structural design should take into consideration the respective fire load. Measures should be put in place to prevent or severely curtail the capability of a fire and smoke to generate soot and spread beyond the fire zone in which the fire breaks out. The higher the fire risk, the greater the number of fire zones the building should have.
- (f) Suppression or limitation of the number of possible ignition sources such as open flames or electrical sparks.

5.59. Paragraph 6.79 of SSR-4 [1] establishes requirements for the analysis with regard to fire extinguishing systems. Fire extinguishing devices, automatically or manually operated, with the use of an adequate extinguishing agent should be installed in zones where a fire is possible and where the consequences of a fire could lead to the dispersion of plutonium contamination outside the first static barrier. The installation of automatic firefighting devices with water sprays should be avoided for areas where uranium, plutonium and/or mixed oxide might be present, with account taken of the potential for criticality. Extinguishing gas other than CO₂ may be used in the event of a fire breaking out in a glovebox. The possible use of carbon dioxide should be considered in the criticality safety assessment.

5.60. A detection and/or suppression system should be installed such that it is commensurate with the risks from internal fires and explosions. This system should be established in compliance with the national requirements.

5.61. The design of ventilation systems should be given particular consideration with regard to fire prevention. Dynamic containment systems comprise ventilation ducts and filter units which might constitute weak points in the fire protection system unless they are of suitable design. Fire dampers should be mounted in the ventilation system. Spark arrestors should be used to protect the filters if necessary. The required operational performance of the ventilation system should be specified so as to comply with fire protection requirements.

5.62. Lines that cross the boundaries between fire zones (e.g. electricity, gases and process lines) should be designed to ensure that fire does not spread.

Explosions

5.63. In MOX fuel fabrication facilities, the use of hydrogen in the sintering furnaces is a potential

cause of explosion. Hydrogen should be diluted with an inert gas (e.g. argon) before it enters the sintering furnace to reduce the likelihood of a hydrogen explosion. The supply of premixed gas should be automatically stopped when the concentration of hydrogen in the premixed gas exceeds a limit. The measurement of the concentration of hydrogen in the premixed gas should be subject to quality control. The composition of the premixed gas should be permanently monitored during operation.

5.64. In addition, effective gas locks should be provided between rooms with a hydrogen atmosphere and other areas of the facility. Systems for detecting hydrogen leakages should be installed in rooms with a hydrogen atmosphere.

5.65. The concentration of oxygen within gloveboxes filled with inert gas, presenting a risk of explosion should be monitored.

Flooding

5.66. Flooding in a MOX fuel fabrication facility might lead to the dispersion of radioactive material and to changes in the conditions for moderation.

5.67. Gloveboxes should not be connected to the water supply in normal operating conditions.

5.68. In facilities where vessels and/or pipes containing water are present, the criticality analysis should take into account the presence of the maximum amount of water that could be contained within the room under consideration, as well as the maximum amount of water in any connected rooms. Such rooms or premises should be clearly identified and the personnel should be informed.

5.69. Walls (and floors if necessary) of rooms where flooding could occur should be capable of withstanding the water load, and safety related equipment should not be affected by flooding.

Leaks and spills

5.70. The amount of liquids present in a MOX fuel fabrication facility is limited. Water is used for cooling sintering furnaces. Possible steam explosions resulting from water entry due to a potential leak in the cooling system should be considered.

5.71. Spillages might occur outside gloveboxes from cans, drums and waste packages during transit within the facility and/or in storage. Appropriate mechanical protection and appropriate confinement should be provided for movements of radioactive material.

5.72. Where spillages in quantities that could be significant from the standpoint of criticality safety are possible (as for example ingress of water from condensed humidity through ventilation systems), consideration should be given to installing design features to prevent water or moderator intrusion. In these areas, installation of humidity detectors and drainage systems should also be considered.

5.73. The surfaces of floors and walls should be chosen to facilitate their cleaning. This will also facilitate the minimization of waste from decommissioning.

Loss of services

5.74. To meet the requirements established in Requirements 49 and 50, and in para. 6.89 of SSR-4 [1], electric power supplies and other support systems in a MOX fuel fabrication facility should be of high integrity. In the event of loss of normal power and depending on the status of the facility, an emergency power supply should be provided to certain structures, systems and components important to safety, including the following:

- (a) Criticality accident detection and alarm systems;
- (b) Ventilation fans and glovebox monitoring systems for the confinement of radioactive material;
- (c) Detection and alarm systems for leaks of hazardous materials, including explosive gases;
- (d) Heat removal systems;
- (e) Emergency control systems;
- (f) Fire detection and suppression systems;
- (g) Monitoring systems for radiation protection;
- (h) Lighting within the process facility.

Use of mobile power sources for emergencies should be considered.

5.75. The loss of items such as gas for instrumentation and control, cooling water for process equipment and ventilation systems, heating water, breathing air and compressed air might also have consequences for safety. Examples of suitable measures to be addressed in the design of a MOX fuel fabrication facility to ensure safety include the following:

- (a) Loss of gas supply to gas actuated safety valves and dampers. In accordance with the safety analysis, valves should be used that are designed to fail to a safe position.
- (b) Loss of cooling water. Adequate backup capacity or a redundant supply should be provided for in the design.
- (c) Loss of breathing air. Adequate backup capacity or a redundant supply should be provided to allow work to continue to be performed in areas with airborne radioactive material.

5.76. MOX materials generate heat due to presence of ^{238}Pu , and storage rooms, storage gloveboxes and larger production units in MOX fuel fabrication facilities have potentially large heat loads. Overheating might challenge the safety functions.

5.77. Ventilation systems are designed to provide cooling and to maintain temperatures below specified values. In a MOX fuel fabrication facility, in the event of a failure of the ventilation system, the time interval before confinement is breached should be adequate for repairing the failure or for taking alternative actions. All structures, systems and components important to safety should be designed such that they can withstand heat loads generated during this interval.

Loss or excess of process media

5.78. Either the loss of process media such as process gas supplies (e.g. hydrogen, helium, nitrogen or argon) and additives, or any excess of these media might have consequences for safety. Some examples are the following:

- (a) Excess of additives in the powder preparation process should be considered in the criticality analysis.
- (b) Increase of levels of airborne contamination and/or concentration of hazardous material in the work areas of the facility because of overpressure in the gloveboxes (containing, for example, nitrogen, argon or helium).
- (c) Reduction of criticality safety due to loss of favourable geometry or loss of moderation control by excess of process gases;
- (d) Releases of large amounts of nitrogen, argon or helium might result in a reduction in the oxygen concentration in breathing air in the work areas of the facility.
- (e) For reasons of fire protection, inert gas may be used for the atmosphere in some gloveboxes. Failure of the gas supply, therefore, would remove one protective barrier. Consideration should be given to the integrity of gas supply by providing a suitable backup supply or by ensuring diversity of supply.

Handling errors

5.79. Handling systems (e.g. cranes) should be designed to reduce the frequency of occurrence of load drops. The consequences of possible load drops should be minimized e.g. by qualification of the containers for the drop, by the design of the floors and by the provision of safe travel paths.

5.80. Mechanical failures or human errors during the handling of radioactive material might result in a degradation of criticality control, confinement or shielding. Mechanical failures or human errors during the handling of loads of non-radioactive material might also result in a degradation of the safety functions of the MOX fuel fabrication facility.

Facility failures and equipment failures

5.81. Measures for the industrial safety of commercial grade equipment installed in gloveboxes (e.g. mechanical guards) should be adapted to the nuclear environment.

5.82. The design should minimize the potential for mechanical impacts to containers of hazardous and/or radioactive material caused by moving devices such as vehicles and cranes.

5.83. Mechanical failures during the processing of nuclear material could result in damage to equipment (e.g. by crushing, bending or breakage) which might result in a degradation of criticality control, confinement or shielding. The design should ensure that the movement of heavy loads by cranes above vessels and piping containing large amounts of hazardous and/or radioactive material is minimized. For complex or important systems (e.g. rod handling systems designed to avoid the hazard of breaking a rod), a systematic method of failure analysis should be implemented.

5.84. Failure due to fatigue or chemical corrosion or lack of mechanical strength should be considered in the design of containment systems for hazardous and/or radioactive material.

5.85. To prevent failure of equipment containing hazardous materials (e.g. furnaces), effective programmes for maintenance, periodic testing and inspection should be established at the design stage (see also paras 5.164–5.166).

Radiolysis

5.86. The irradiation of organic or hydrogenated substances by plutonium, or the resulting decomposition of molecules, might lead to the generation of gas, especially the release of hydrogen or the degradation of containment systems. The potential for radiolysis should be taken into account in the safety analysis for the following:

- (a) Liquid effluents and organic solvents used in the laboratory;
- (b) Contaminated oils and inflammable waste;
- (c) Process scraps enclosing hydrogenated additives;
- (d) Containers or plastic bags containing PuO₂ or MOX.

5.87. Pressurization caused by alpha decay generating helium in a sealed system and the potential for water evaporation due to radiolytic heat generation should be considered.

External hazards

5.88. A MOX fuel fabrication facility should be designed in accordance with the nature and severity of the external hazards, either natural or human induced, identified and evaluated in accordance with the provisions of SSR-1 [15]. Detailed recommendations on external hazards are provided in Safety Standards Series Nos SSG-9 (Rev. 1), Seismic Hazards in Site Evaluation for Nuclear Installations [19],

SSG-18, Meteorological and Hydrological Hazards in Site Evaluation for Nuclear Installations [20], SSG-21, Volcanic Hazards in Site Evaluation of Nuclear Installations [21], SSG-68, Design of Nuclear Installations Against External Events Excluding Earthquakes [22]. Recommendations for specific external hazards for a MOX fuel fabrication facility are provided in paras 5.89–5.104.

Earthquakes

5.89. To ensure that the design of a MOX fuel fabrication facility provides the required degree of robustness, a detailed seismic assessment (see SSR-1 [15] and SSG-9 (Rev. 1) [19]) should be made of the MOX fuel fabrication facility design, including the following seismically induced events:

- (a) Loss of cooling.
- (b) Loss of support services, including utilities.
- (c) Loss of confinement functions (static and dynamic).
- (d) Loss of safety functions for ensuring the return of the facility to a safe state and maintaining the facility in a safe state after an earthquake, including structural functions and functions for the prevention of other hazards (e.g. fire, explosion, load drop, flooding).
- (e) The effect on criticality safety controls such as geometry, moderation, absorption and reflection of the following:
 - (i) Deformation (geometry control);
 - (ii) Displacement (geometry control, fixed neutron absorbers, neutron interaction);
 - (iii) Loss of material (geometry control, soluble neutron absorbers);
 - (iv) Ingress of moderating material (moderation control).

5.90. A MOX fuel fabrication facility should be designed for the design basis earthquake to ensure that the earthquake will not impair the function of control rooms. Supplementary control rooms or emergency control panels should be accessible and operable by staff after an earthquake exceeding the design basis. Equipment necessary to maintain the MOX fuel fabrication facility in a safe and stable state and equipment necessary to monitor the facility and environment should be tested (as far as practicable) and qualified using appropriate conservative methodologies, including the use of an earthquake simulation platform.

5.91. Depending on the site characteristics and location of the MOX fuel fabrication facility, as evaluated in the site assessment (see Section 4), the effect of a tsunami induced by an earthquake and other extreme flooding events should be addressed in the facility design.

External fires and explosions and external toxic hazards

5.92. Hazards from external fires and explosions could arise from various sources in the vicinity of a MOX fuel fabrication facility, such as petrochemical installations, forests, pipelines and road, rail or sea routes used for the transport of flammable material such as gas or oil, and volcanic hazards.

5.93. To demonstrate that the risks associated with such external hazards are below acceptable levels, the operating organization should first identify all potential sources of hazards and then estimate the associated event sequences affecting the facility. The radiological or associated chemical consequences of any damage should be evaluated, and it should be verified that they are within acceptance criteria. Toxic hazards should be assessed to verify that specific gas concentrations meet the acceptance criteria. It should be ensured that external toxic hazards would not adversely affect the control of the facility. The operating organization should conduct a survey of potentially hazardous installations and transport operations for hazardous material in the vicinity of the facility. In the case of explosions, risks should be assessed for compliance with overpressure criteria.

5.94. To evaluate the possible effects of flammable liquids, toxic spills, volcanic ashes, falling objects (such as chimneys), air shock waves and missiles resulting from explosions, their possible distance from the facility and hence their potential for causing physical damage should be assessed.

Extreme meteorological phenomena

5.95. A MOX fuel fabrication facility should be protected against extreme meteorological conditions as identified in the site evaluation (see Section 4) by means of appropriate design provisions. These should generally include the following:

- (a) The ability of structures important to safety to withstand extreme weather loads, with particular assessment of parts of the facility structure designed to provide confinement;
- (b) The ability to maintain the availability of cooling systems under extreme temperatures and other extreme conditions;
- (c) The prevention of flooding of the facility including adequate means to evacuate water from the roof in cases of extreme rainfall;
- (d) The safe shutdown of the facility in accordance with the operational limits and conditions, followed by maintaining the facility in a safe and stable shutdown state, where necessary;
- (e) Events consequential to extreme weather conditions.

Tornadoes

5.96. Measures for the protection of the facility against tornadoes will depend on the meteorological conditions for the area in which the facility is located. The design of buildings and ventilation systems should comply with specific national regulations relating to hazards from tornadoes. If specific national regulations do not exist, the design should adhere to international good practices.

5.97. High winds are capable of lifting and propelling objects as large as automobiles or telephone poles. The possibility of impacts of tornado missiles such as these should be taken into consideration in the design stage for the facility, as regards both the initial impact and the effects of possible secondary fragments arising from collisions with and spallation from concrete walls or from other types of transfer of momentum.

Extreme temperatures

5.98. The potential duration of extreme low or high temperatures should be taken into account in the design of support system equipment to prevent unacceptable effects such as the freezing of cooling circuits or to prevent adverse effects on venting and cooling systems.

5.99. If safety limits for humidity or temperature are specified in a building or a compartment, the air conditioning system should be designed to perform efficiently, including under extreme hot or wet weather conditions. The effect of condensation inside the facility should also be taken into consideration. Structural components of buildings (as static containment) should also be designed for extreme temperature and humidity and their associated thermal stress effects such as shrinkage in concrete.

Snowfall and ice storms

5.100. The occurrence of snowfall and ice storms and their effects should be taken into account in the design of the facility and the safety analysis. Snow and ice are generally taken into account as an additional load on the roofs of buildings. In addition, snow and ice might impact ventilation systems and electrical equipment outside of the buildings. The neutron reflecting effect, or the interspersed moderation effect of the snow should be considered if relevant.

Flooding

5.101. For any flood events such as extreme rainfall (for an inland site) or storm surge (for a coastal site) attention should be focused on potential leak paths (breaks in the confinement barrier) into active cells and structures, systems and components important to safety when these are vulnerable to damage. Equipment containing fissile material should be designed to prevent any criticality accident in the event of flooding. Gloveboxes should be designed to be resistant (remain undamaged and static) to the dynamic effects of flooding and all glovebox penetrations should be above any potential flood levels. Electrical systems, instrumentation and control systems, emergency power systems (batteries and power generation systems) and control rooms should be protected by design.

5.102. For extreme rainfall, attention should be focused on the stability of buildings (e.g. hydrostatic and dynamic effects), the water level and, where relevant, the potential for mudslides. Consideration should be given to the highest flood level historically recorded and to siting the facility above this flood level, at sufficient elevation and with sufficient margin to account for uncertainties (e.g. in postulated effects of global warming), to avoid major damage from flooding.

Accidental aircraft crashes

5.103. In accordance with the risks identified in the site evaluation (see Section 4), a MOX fuel fabrication facility should be designed to withstand the design basis impact.

5.104. For evaluating the consequences of impacts or the adequacy of the design to resist aircraft impacts, only realistic crash scenarios should be considered, which may demand the knowledge of such factors as the possible angle of impact, velocity of the aircraft or the potential for fire and explosion due to the aviation fuel load. In general, fire cannot be ruled out following an aircraft crash. Therefore, specific requirements for fire protection and for emergency preparedness and response should be established.

INSTRUMENTATION AND CONTROL

5.105. Instrumentation should be provided to monitor the relevant parameters (such as radiation doses due to external exposure, air quality of operational areas and building pressure), and systems (such as ventilation systems) and general conditions of the facility (such as temperature, contamination) over their respective ranges for: (1) normal operation; (2) anticipated operational occurrences; and (3) accident conditions, to ensure that adequate information can be obtained on the status of the operations and the facility, and proper actions can be undertaken in accordance with operating procedures .

5.106. Instrumentation should be provided for measuring all the main parameters whose variation might affect the safety of processes (such as pressure, temperature and flowrate). In addition, instrumentation should be provided for monitoring general conditions at the facility (such as criticality safety related parameters, radiation levels, individual dosimetry for external and internal exposure of personnel, releases of effluents and ventilation conditions), and for obtaining any other information about the facility necessary for its reliable and safe operation (such as presence of personnel and environmental conditions).

5.107. Passive and active engineering controls are more reliable than administrative controls and should be preferred for control in operational states and in accident conditions. Automatic systems should be designed to maintain process parameters within the operational limits and conditions or to bring the process to a predetermined safe state, which for a MOX fuel fabrication facility is generally the shutdown state.

5.108. Appropriate information should be made available to the operator for monitoring the effects of automatic actions. The layout of instrumentation and the manner of presentation of information should

provide the operating personnel with an adequate picture of the status and performance of the facility. Devices should be installed that provide in an efficient manner visual and, as appropriate, audible indications of operational states that have deviated from normal conditions and that could affect safety. Provision should be made for the automatic measurement and recording of values of parameters that are important to safety and where applicable, manual periodic testing should be used to complement automated continuous testing of conditions.

Control rooms and panels

5.109. Control rooms and human-machine-interface panels should be provided to centralize the availability of information and monitoring of actions. The need for and location of control rooms and panels in different areas should be evaluated taking into account occupational exposure, safety of personnel and emergency response. Where applicable, it may be useful to have dedicated control rooms to allow for the remote monitoring of operations, thereby reducing exposures and risks to personnel. Particular consideration should be paid to identifying those events, both internal and external to the control rooms, that might pose a direct threat to the operators and to the operation of control rooms. Ergonomic factors should be taken into account in the design of control rooms and the design of control room displays and systems.

Safety related instrumentation and control systems

5.110. The safety related instrumentation and control systems of a MOX fuel fabrication facility should include systems for the following:

- (a) Criticality control, criticality detection and alarm:
 - (i) Depending on the method of criticality control, the control parameters usually include mass, density, moisture content, isotopic composition, fissile content, moderation and reflection of additives, and spacing between items;
 - (ii) Radiation detectors (gamma and/or neutron detectors) with audible and, where necessary, visual alarms for initiating immediate evacuation from the affected area, should cover all the areas where a significant quantity of fissile material is present – see para. 6.173 of SSR-4 [1].
- (b) Fire detection and suppression systems;
 - (i) All rooms with fire loads or significant amounts of fissile and/or toxic chemical material should be equipped with fire alarms;
 - (ii) Gas detectors should be used in areas where a leakage of gases (e.g. hydrogen) could produce an explosive atmosphere.
- (c) Process control:
 - (i) A key safety related control system is the means of confirming the correct concentration of hydrogen in the gas supply to the sintering furnaces.
 - (ii) Indicating temperatures, pressures, flow rates, concentrations of chemicals and/or radioactive material, tank levels.
- (d) Monitoring and control of ventilation.
 - (i) Monitoring and control of ventilation is needed to ensure that the airflows in all areas of the MOX fuel fabrication facility are flowing in the correct direction, i.e. towards areas that are more contaminated. In working areas, the temperature and humidity levels and the level of pollutants should be controlled to ensure the comfort of personnel and good levels of hygiene. In some cases, local ventilation should be used, e.g. in rooms housing backup batteries.

- (ii) Monitoring and control of ventilation should be applied in particular in areas where sintering furnaces and pellet grinding equipment are located.
- (e) Control of occupational radiation exposure:
 - (i) External exposure. Direct reading dosimeters with real-time displays and/or alarms should be used to monitor radiation doses for workers, in particular in areas in which inspection equipment such as X ray equipment and radioactive sources are located. Portable equipment and installed equipment should be used to monitor whole body exposures and exposures of the hands to gamma radiation and neutron emissions.
 - (ii) Internal exposure. Owing to the specific hazards of airborne plutonium, the following provisions should be considered:
 - Continuous air monitors to detect plutonium should be installed as close as possible to the working areas to ensure the early detection of any dispersion of plutonium;
 - Continuous air sampling devices should be installed in the breathing zone of personnel for the retrospective assessment of doses due to internal exposure;
 - Devices for detecting alpha surface contamination should be installed close to the working areas and also close at least to the exits of rooms in which working areas are located;
 - Devices for detecting and assessment of doses to the lens of the eye should be installed where appropriate (assessment of doses to the lens of the eye can also be performed by calculation methods).
- (f) Control of liquid and gaseous effluents:
 - (i) MOX fuel fabrication facilities (with dry fabrication process) have low volumes of liquid discharges that can usually be monitored for control purposes by sampling and analysis and by measuring the volumes of discharges. Real time measurements should be provided for continuous discharges. Special arrangements should be made for effluents from laboratories, which can differ from site to site.
 - (ii) Real time measurements should be made to confirm that filtration systems are working effectively.
 - (iii) The detection and alarm system of abnormal releases should be ensured.
- (g) System for the control of transfers of nuclear material.
- (h) Systems for the detection of surface contamination and airborne radioactive material and alarm systems.
- (i) Glovebox control:
 - (i) Gloveboxes should be equipped with instrumentation and control systems ensuring negative pressure.
 - (ii) For gloveboxes containing inert gas, the in-leakage gas concentration should be monitored for safety and, if necessary, to verify product quality. Temperature levels should also be monitored.

HUMAN FACTOR CONSIDERATIONS

5.111. The requirements relating to consideration of human factor engineering are established in Requirement 27 of SSR-4 [1].

5.112. Human factors in operation, inspection, periodic testing and maintenance should be considered at the design stage. Human factors to be considered for MOX fuel fabrication facilities should include the following:

- (a) The ease of intervention by the operator in all facility states;

- (b) Possible effects on safety of inappropriate or unauthorized human actions (with account taken of tolerance of human error);
- (c) The potential for occupational exposure.

5.113. The design of the facility to take account of human factors is a specialist area. Experts and experienced operators should be involved from the earliest stages of design. Areas that should be considered include the following:

- (a) Design of working conditions to ergonomic principles:
 - (i) The operator–process interface, for example, electronic control panels displaying all the necessary information and no superfluous information;
 - (ii) The working environment, for example, ensuring good access to, and adequate space around, equipment and suitable finishes to surfaces for ease of cleaning.
- (b) Choice of location and clear labelling of equipment so as to facilitate maintenance, testing, cleaning and replacement.
- (c) Provision of fail-safe equipment and automatic control systems for accident sequences for which reliable and rapid protection is required.
- (d) Good task design and ease for implementing operating procedures, particularly during maintenance work, when automated control systems may be disabled.
- (e) Minimization of the need to use additional means of personal radiation protection.
- (f) The criticality mass limit, the actual mass of fissile material and the monitoring thresholds in a glovebox should be visible to the operator. The availability of this information should be considered in case of computer failure.
- (g) Operating experience feedback relevant to human factors.

5.114. In the design and operation of gloveboxes, the following specific considerations should be taken into account:

- (a) In the design of equipment inside gloveboxes, account should be taken of the potential for conventional industrial hazards that might result in injuries to personnel, including internal radiation exposure through cuts in the gloves and/or wounds on the operator’s skin, and/or the possible failure of confinement.
- (b) Ease of physical access to gloveboxes and adequate space and good visibility in the areas in which gloveboxes are located.
- (c) The potential for damage to gloves. Sharp edges and corners on equipment and fittings and associated tools should be avoided to minimize the potential for glove damage.
- (d) Training of operators on procedures to be followed for normal and abnormal conditions.

SAFETY ANALYSIS

5.115. Requirement 14 of GSR Part 4 (Rev. 1) [13] states that: “**The performance of a facility or activity in all operational states and, as necessary, in the post-operational phase shall be assessed in the safety analysis**”. The safety analysis of MOX fuel fabrication facilities should include the analysis of the variety of hazards for the whole facility and all activities.

5.116. The list of postulated initiating events identified should take into account all the internal and external hazards and the resulting event scenarios. The safety analysis should be performed taking into consideration all the structures, systems and components important to safety that might be affected by the postulated initiating events identified.

5.117. For MOX fuel fabrication facilities, the safety analysis should be performed iteratively with the development of the design with the objectives of achieving the following:

- (a) That doses to personnel and the public during operational states are within acceptable and

operational limits for those states and consistent with the optimization of protection and safety (see Requirements 11 and 12 of GSR Part 3 [17]);

- (b) That the radiological and chemical consequences of design basis accidents (or equivalent) to the public are within the limits specified for accident conditions and consistent with the optimization of protection and safety (see GSR Part 3 [17]);
- (c) The development of appropriate operational limits and conditions.

Safety analysis for operational states

5.118. A facility specific, realistic, enveloping and robust (i.e. conservative) assessment of internal and external occupational exposure and public exposure during normal operation and anticipated operational occurrences should be performed on the basis of the following assumptions:

- (a) Calculations of the estimated doses due to occupational exposure should be made on the basis of the conditions at the most exposed workplaces, should use maximum annual working times and should account for maintenance activities.
- (b) Calculations of the envelope source term should be made on the basis of: (i) reference isotopic compositions of plutonium and traces of associated transuranic elements and fission products; and (ii) the highest specific activities of these radioactive materials. On the basis of data on dose rates collected during commissioning runs and as necessary, the operational limits and conditions may include maximum annual working times for particular workplaces.
- (c) Calculations of estimated doses to the public should be made on the basis of the maximum estimated releases of radioactive material to the air and to water and the maximum depositions to the ground and the direct exposure. Conservative models and parameters should be used to calculate the estimated doses to the public in the initial stages of design, with consideration given to further refinement as appropriate.
- (d) The licensed inventories of radioactive material present in each piece of equipment, and in each glovebox and storage area.
- (e) Calculations of the efficiency of shielding during normal operation should be made on the basis of conservative assumptions regarding the performance of shielding.
- (f) The maximum cumulative annual working time at each workplace for operation and anticipated maintenance work.

5.119. A best estimate methodology with the use of adequate margins may also be used in the safety analysis.

5.120. The design of equipment, the layout of equipment in, for example, gloveboxes, and the placement of shielding should be determined on the basis of adequate interaction and feedback between process and mechanical designs, safety assessment, and operational experience from similar facilities and/or facilities upstream in the process (spent fuel reprocessing or plutonium polishing facilities). Cleaning operations (e.g. elimination of heavy dust from gloveboxes) should be given special consideration in the design.

5.121. As soon as plutonium is introduced into the MOX fuel fabrication facility, the calculated doses should be compared with actual doses rates. If considered necessary, maximum permissible annual working times for specific workplaces may be included in the operational limits and conditions.

Safety analysis for accident conditions

Methods and assumptions for safety analysis for accident conditions

5.122. The acceptance criteria associated with the accident analysis should be defined in accordance with Requirement 16 of GSR Part 4 (Rev. 1) [13], and with respect to national regulations and relevant

criteria.

5.123. For a MOX fuel fabrication facility, the consequences of design basis accidents could result in consequences for individuals on the site and close to the location of the accident. The consequences depend on various factors such as the amount and rate of the release of radioactive material, the distance between the individuals exposed or affected and the source of the release, pathways for the transport of material to the individuals and the exposure times.

5.124. To estimate the on-site and off-site consequences of an accident, the entire range of physical processes that could lead to a release of radioactive material to the environment or to a loss of shielding should be modelled in the accident analysis and the worst credible consequences should be determined.

5.125. Accident consequences should be assessed in accordance with the requirements established in GSR Part 4 (Rev. 1) [13] and with relevant parts of its supporting Safety Guides.

Analysis of design extension conditions

5.126. The safety analysis should identify design extension conditions and their progression and consequences should be analysed in accordance with Requirement 21 of SSR-4 [1]. The objective is to identify and analyse additional accident scenarios to be addressed in the design of a MOX fuel fabrication facility to ensure that the design is such that, for design extension conditions, off-site protective actions that are limited in terms of times and areas of application shall be sufficient for the protection of the public, and sufficient time shall be available to take such actions. And moreover that the possibility of conditions arising that could lead to early releases of radioactive material or to large releases of radioactive material is practically eliminated (see para. 6.74 of SSR-4 [1]).

5.127. Design extension conditions include events more severe than design basis accidents that could originate from extreme events or combinations of events which could cause damage to structures, systems and components important to safety or which could challenge the fulfilment of the main safety functions. The postulated initiating events provided in the Appendix of SSR-4 [1] are required to be used including combinations of initiating events as well as events with additional failures. Accidents that have more severe consequences as well as progression of events that could potentially lead to radiological or chemical releases should also be analysed to support emergency preparedness and response and assist in the development of emergency plans to mitigate the consequences of an accident.

5.128. Additional safety features or increased capability of safety systems, identified during the analysis of design extension conditions, should be implemented in the facility where practicable.

5.129. For analysing design extension conditions, best estimate methods with realistic boundary conditions can be applied. Acceptance criteria for this analysis, in accordance with para. 6.74 of SSR-4 [1], should be defined by the operating organization and should be reviewed by the national regulatory body.

5.130. Examples of design extension conditions that are applicable to MOX fuel fabrication facilities can be found in Ref. [23].

5.131. Analysis of design extension conditions should also demonstrate that the MOX fuel fabrication facility can be brought into the state where the confinement function and subcriticality can be maintained in the long-term (see also SSG-27 [4]).

Assessment of possible radiological or associated chemical consequences

5.132. The main steps for the assessment of possible radiological or chemical consequences in the safety

analysis should include the following:

- (a) Analysis of the actual site conditions (e.g. meteorological, geological, hydrogeological site conditions) and conditions expected in the future including internal and external initiating events with the potential for adverse effects.
- (b) Specification of facility design information and facility configurations, with the corresponding operating procedures and administrative controls for operations.
- (c) Identification of individuals and population groups (for facility personnel and members of the public) who could possibly be affected by radiation risks and/or associated chemical risks arising from the operation of the facility.
- (d) Identification and analysis of conditions at the facility, including internal and external initiating events that could lead to a release of material or of energy with the potential for adverse effects, the time frame for emissions and the exposure time, in accordance with reasonable scenarios.
- (e) Quantification of the consequences for the individuals and population groups identified in the safety assessment.
- (f) Identification and specification of the structures, systems and components important to safety that may be credited to reduce the likelihood and/or to mitigate the consequences of accidents. These structures, systems and components that are credited in the safety assessment should be qualified to perform their functions in the accident conditions.
- (g) Characterization of the source term (e.g. material, mass, release rate, temperature).
- (h) Identification and analysis of pathways by which material that is released could be dispersed in the environment.
- (i) Considerations for interface between safety and nuclear security.

5.133. The analysis of the conditions at the site and the conditions expected in the future involves a review of the meteorological, geological and hydrological conditions at the site that might influence facility operations or might play a part in transporting material or transferring energy that might be released from the facility.

5.134. Environmental transfer of material should be calculated with qualified computer codes or by using data derived from qualified codes, with account taken of the meteorological and hydrological conditions at the site that would result in the highest exposure of the public.

5.135. The identification of personnel and members of the public (i.e. the representative person) who might potentially be affected by an accident involves a review of descriptions of the facility and of demographic information.

5.136. In the assessment of the consequences of design extension conditions, less conservative assumptions compared to design basis analysis may be used (for example prevailing wind directions on the site).

5.137. The magnitude and severity of conditions considered in design extension conditions as well as the acceptance criteria used for acceptability of consequences of design extension conditions should be approved by the national regulatory body.

5.138. Further recommendations on the assessment of potential radiological impact to the public can be found in GSG-10 [18]. Useful guidelines for assessing the acute and chronic toxic effects of chemicals used in MOX fuel fabrication facilities are provided Ref. [24].

EMERGENCY PREPAREDNESS AND RESPONSE

5.139. A comprehensive hazard assessment should be performed in accordance with Requirement 4 of IAEA Safety Standards Series No. GSR Part 7, Preparedness and Response for a Nuclear or Radiological

Emergency [25] before commissioning. The results of the hazard assessment should provide a basis for identifying the emergency preparedness category relevant to the facility and the on-site areas and, as relevant, off-site areas where protective actions and other response actions may be warranted in case of a nuclear or radiological emergency. Further recommendations are provided in IAEA Safety Standards Series No. GS-G-2.1, Arrangements for Preparedness for a Nuclear or Radiological Emergency [26].

5.140. The operating organization of a facility is required to establish emergency arrangements that take into account the potential hazards at the facility (Requirement 72 of SSR-4 [1]). The emergency plan and procedures and the necessary equipment and provisions should be determined on the basis of selected scenarios for design extension conditions and beyond design basis accidents (or the equivalent). The conditions under which an off-site emergency response might be required to be initiated should include criticality accidents, widespread fires, and earthquakes.

MANAGEMENT OF RADIOACTIVE WASTE

5.141. The general requirements for optimization of protection and safety for waste and effluent management and the formulation of a waste strategy are established in IAEA Safety Standards Series No. GSR Part 5, Predisposal Management of Radioactive Waste [27] and additional recommendations are provided in IAEA Safety Standards Series Nos GSG-3, The Safety Case and Safety Assessment for the Predisposal Management of Radioactive Waste [28], GSG-1, Classification of Radioactive Waste [29], SSG-41, Predisposal Management of Radioactive Waste from Nuclear Fuel Cycle Facilities [30] and GSG-16 [11]. Recommendations on aspects that are particularly relevant or specific to MOX fuel fabrication facilities are provided in paras 5.142-5.143.

5.142. In accordance with Requirement 24 of SSR-4 [1], the generation of radioactive waste is required to be kept to the minimum practicable in terms of both activity and volume, by means of appropriate design measures. Recovery of nuclear material and reuse of chemicals should be applied to the extent practicable in MOX fuel fabrication facilities to minimize the generation of waste in both solid and liquid forms. The main type of waste encountered in MOX fuel fabrication facilities is material contaminated with plutonium (from plutonium oxide or MOX). The following aspects should be considered in the design of MOX fuel fabrication facilities:

a) Generation of waste.

- The design of the facility should be such as to minimize the amount of materials imported into gloveboxes in order to minimize radioactive waste generation.
- Appropriate management options (including, as appropriate, disposal routes) should be identified for all waste streams that will be generated and the design of the facilities should be such as to facilitate waste management.
- It is possible that segregation of wastes with different properties (including different levels of radioactivity) may be possible at some stages of the process and should be considered to facilitate disposal by optimized routes. For example, removal of uncontaminated outer packaging for disposal separate to plutonium contaminated inner packaging.

b) Removal of waste.

- Waste should be first bagged in the glovebox and then removed from the glovebox using bagging ports in which a bag is attached to the glovebox and the waste is inserted and then removed after sealing to maintain confinement. The size of the port should be such as to accommodate the expected waste, which may include equipment that has been replaced.
- Filters from the gloveboxes and the ventilation system should be packed using appropriate radioactive waste containers.
- First stage aerosol filters should be recycled to return nuclear material to production.

c) Collection of waste.

- For the assessment and management of waste contaminated with plutonium, provision should be made for a central waste management area. In this central area, waste should be monitored for its plutonium content and may be treated and placed in containers for interim storage.
- Design features for the collection and transport of waste should be such as to reduce the potential for dropping bags of waste.
- An indicative measurement or qualified estimate of fissile material mass in a waste package should be made before moving the package to the central waste management area to ensure criticality safety.
- Design features should be provided for the collection and transport of waste in containers to provide an additional level of confinement.
- Consideration should be given to criticality control and radiation exposure of the personnel when a number of bags of waste are collected.

d) Interim storage of waste.

- Subsequent treatment outside the MOX fuel fabrication facility may include conditioning, compaction and washing of the waste before its long term storage.

5.143. Appropriate quality controls should be applied throughout the management of waste from all waste streams. Recommendations on the management system for radioactive waste management are established in GSG-16 [11].

MANAGEMENT OF GASEOUS AND LIQUID EFFLUENTS

5.144. MOX fuel fabrication facilities should be designed so that the need for discharges is avoided. If discharges cannot be avoided, the operating organization should ensure that discharge limits can be met in normal operation and accidental releases to the environment are prevented.

5.145. Liquid effluents to be discharged to the environment should be monitored, treated and managed as necessary to reduce the discharges of radioactive material and hazardous chemicals.

5.146. Where necessary, equipment should be installed to reveal potential failure of treatment systems, such as differential pressure gauges to identify failed filters. If required by the safety analysis or the relevant authorization, discharge monitoring should be provided via continuous sampling of the activity in the liquid or gas, coupled with continuous measurement of the discharge flow rate.

5.147. MOX fuel fabrication facilities which use dry processes generate dust. The gaseous effluent discharges from MOX fuel fabrication facilities should be reduced by filtration, which normally consists of a number of HEPA filters in series.

OTHER DESIGN CONSIDERATIONS

Customer specifications on fuel characteristics

5.148. Customer specifications on fuel characteristics that have implications for safety in the design and operation of MOX fuel fabrication facilities (e.g. criticality, shielding, thermal effects) should be taken into account at an early stage in the design of the facility and equipment, especially the specifications for the plutonium content and anticipated or conservatively bounding isotopic vector as input and the specifications for MOX fuel assemblies as output.

Gloveboxes

5.149. Gloveboxes should be designed to facilitate the use of dry methods of cleaning (e.g. with vacuum

cleaners).

Radiation protection and shielding

5.150. Plutonium oxide and MOX can generate significant dose rates depending on the isotopic composition of the material processed. MOX from higher burnup plutonium oxide can give rise to significant neutron dose rates while the presence of ^{241}Am (a decay product of ^{241}Pu) can give rise to gamma radiation. Uranium oxide from reprocessing may also contain residual fission products and ^{232}U with its fission products that give rise to beta and gamma radiation.

5.151. As there might be significant dose rates in areas of the MOX fuel fabrication facility occupied by personnel, consideration should be given at the design stage to the need for neutron and gamma shielding.

5.152. Effective shielding from 60 keV gamma radiation from ^{241}Am and from neutron emissions may be applied to the faces of gloveboxes, but this can restrict visibility and thus lead to increased occupancy periods of personnel by the glovebox. The type of shielding should therefore be selected on the basis of the estimated total doses due to occupational exposure during normal operation and maintenance.

Intermediate storage of MOX and plutonium oxide

5.153. Plutonium oxide may be stored in MOX fuel fabrication facilities pending its processing. MOX may be stored at intermediate stages in the process as powder, pellets, rods and assemblies. The necessary storage capacity should be determined by process buffer quantities.

Modularization

5.154. To facilitate the construction and commissioning of a MOX facility to meet Requirement 29 of SSR-4 [1], the modularization of structures, systems and components should be considered. Modularization enables manufacturers of structures, systems and components to pre-assemble parts of the production line out of the facility site in better space conditions and using specific tools and equipment and to perform initial tests of the structures, systems and components. This helps the installation on site and reduces manufacturing deficiencies of the structures, systems and components before their transport to the facility site.

5.155. The design should consider using a limited number of types of modules, and combining modules for different purposes, so as to reduce the complexity of the structures, systems and components in order to achieve a lower frequency of maintenance activities and reduced doses to workers (see Requirement 36 of SSR-4 [1]).

Maintenance policy

5.156. The maintenance policy should cover the following aspects:

- (a) Consideration of whether maintenance should be performed by remote operation or manually by using gloves. This may vary for different stages in the process.
- (b) Criticality safety conditions such as limitations on the introduction of liquids, solvents, plastics and other moderators.
- (c) Prevention of contamination when replacing equipment (e.g. motors and drives may be located outside gloveboxes).
- (d) Limitation and removal of dust. Gloveboxes might become dusty unless cleaned regularly. A dusty environment might reduce visibility and might increase the whole body exposure and the occupational hand exposure (when hands are placed in dusty gloves).

- (e) Loss of shielding material. Shielding on gloveboxes is often provided for normal process operations and may need to be removed for access for maintenance. Ideally, it should be possible to remove the source before removing the shielding.
- (f) The design should avoid where possible sharp edges and the need for sharp equipment in gloveboxes to minimize the potential for causing wounds that could become contaminated.

Design provisions for on-site transfer of radioactive material and hazardous materials

5.157. Requirements for the control over the transfer of radioactive material and other hazardous materials are established in Requirement 28 and paras 6.111–6.112 of SSR-4 [1].

5.158. The design of the facility and the production processes should take into account the number of onsite transfers of radioactive materials across different safety related zones (such as contamination and criticality controlled areas).

5.159. For incoming containers, containing radioactive material, sufficient technical provisions for checking the integrity should be considered during the design stage.

5.160. All containers used for transfer of radioactive material on site should be considered in the safety analysis.

5.161. For cases where misidentification of containers could pose a hazard, provisions for easy identification of the content should be used (for example, use of unique colours, shapes, valves).

5.162. Technical provisions for inspection and maintenance of containers which are classified as items important to safety should be available. All containers should be controlled by a computer based system (actual status, position and technical conditions of the containers).

5.163. The analyses of handling arrangements should cover the following:

- (a) Transport routes and intersections within the facility;
- (b) Technical limits of the transport vehicles;
- (c) Handling failures during transport.

AGEING MANAGEMENT CONSIDERATIONS

5.164. In accordance with Requirement 32 of SSR-4 [1], the design of facility is required take into account the ageing effects of systems, structures and components important to safety to ensure their reliability and availability during the lifetime of the facility.

5.165. The design should allow all systems, structures and components important to safety to be easily inspected in order to detect their ageing (static containment deterioration, corrosion) and to allow their maintenance or replacement if needed.

5.166. An ageing management programme should be implemented at the design stage to ensure that provisions are in place for anticipating equipment replacements.

Design provisions for decontamination and decommissioning

5.167. To facilitate decontamination and the decommissioning of the facility, surface areas of the MOX fuel fabrication facility where there might be contamination should be non-porous and easy to clean. This may be achieved by applying special coatings to surfaces and ensuring that no areas are difficult to access. In addition, all surfaces that could become contaminated should be made readily accessible to allow for periodic and incidental decontamination.

5.168. The design should allow dismantling of the equipment within gloveboxes rather than using destructive techniques during decommissioning.

6. CONSTRUCTION OF MOX FUEL FABRICATION FACILITIES

6.1. Requirements for the construction of MOX fuel fabrication facilities are established in Requirement 53 and paras 7.1–7.7 of SSR-4 [1]. General recommendations on the construction and construction management of nuclear installations are provided in IAEA Safety Standards Series No. SSG-38, Construction for Nuclear Installations [31].

6.2. MOX fuel fabrication facilities are complex facilities, and regulatory body authorization should be sought in several stages. Each stage may have a hold point at which approval by the regulatory body may be necessary before the subsequent stage may be commenced (para. 7.2 of SSR-4 [1]). In addition to the construction programme (see Requirement 53 of SSR-4 [1]) and the management process by which the operating organization maintains control over construction, frequent visits by the regulatory body to the construction site should be used to provide feedback of information to the construction contractor to prevent future operational problems.

6.3. MOX fuel fabrication facilities are complex mechanically and, as such, modularized components should be used in their construction. This enables equipment to be tested and proven at manufacturers' shops before its installation at the MOX fuel fabrication facility (see para. 5.154). This will also aid in the commissioning, maintenance and decommissioning of the facility.

6.4. Components and cables in a MOX fuel fabrication facility should be clearly labelled, owing to the complexity of the control systems.

6.5. Preferably, construction work should be completed before commissioning of the facility or its parts. In cases when the construction and commissioning or operational stages overlap, the appropriate precautions should be considered to minimize potential adverse impact of construction activities on safety. Consideration should be also given to the protection of equipment which has been already installed.

6.6. All structures and components after their installation should be properly cleaned and painted with suitable primer followed by appropriate surface treatment.

6.7. Effect of nearby activities handling corrosive substances should also be considered.

6.8. Contractors engaged in the construction work should be properly assessed for their integrity and competency in adhering strictly to design requirements and quality requirements to ensure the future safety of the facility.

7. COMMISSIONING OF MOX FUEL FABRICATION FACILITIES

7.1. The requirements for commissioning are established in Requirement 54 and paras 8.1–8.23 and 8.27 of SSR-4 [1].

7.2. The operating organization should make the best use of the commissioning stage to become completely familiar with the facility. It should also be an opportunity to promote and further enhance safety culture, including positive behaviours and attitudes, throughout the entire organization.

7.3. The commissioning should be divided into two main stages: cold commissioning (or ‘inactive’) and hot commissioning (or ‘active’): see paras 8.14–8.18 of SSR-4 [1]. For a MOX fuel fabrication facility the hot commissioning stage should be further divided into uranium commissioning and plutonium commissioning:

(1) Cold commissioning (or ‘inactive’).

In this stage, the facility’s systems are systematically tested, both individual items of equipment and the systems in their entirety. Initial testing of normal operation should be conducted. This might require regulatory authorization to use radiation sources. As much verification and testing as possible should be performed because of the relative ease of taking corrective actions in this stage. Any modifications to structures, systems and components important to safety should be reported to the regulatory body. Testing of the effectiveness of the static confinement and dynamic confinement should be undertaken and approved by the competent authority and baseline performance data should be recorded. In this stage, the operating organization should prepare the set of operational documents and should train the personnel in the safety requirements, operating procedures (including those for maintenance) and emergency procedures. At the end of this stage, the operating organization should provide evidence of conformity of the facility to design requirements and safety requirements and operational readiness for uranium commissioning to the regulatory body.

(2) Hot commissioning – uranium commissioning.

Natural or depleted uranium should be used in this stage, to avoid criticality risks, to minimize doses due to occupational exposure and to limit possible needs for decontamination. This stage also provides the opportunity to initiate the radiation protection control regimes that will be necessary when plutonium is introduced. Testing of neutron monitors and other radiation detectors should be conducted (with sources, if necessary) at the beginning of or before this stage.

Safety tests performed during this commissioning period should cover confinement checking, control of movement of material and final balancing of dynamic confinement. This should include: (i) checks for airborne radioactive material and checks of levels of exposure at the workplace; (ii) smear sampling of surfaces; (iii) checks for gaseous and liquid discharges; and (iv) checks for the unexpected accumulation of material. At the end of this stage, the operating organization should provide evidence to the regulatory authority that the facility is ready to conduct safe commissioning with plutonium, ensuring the required level of radiation protection and criticality safety.

(3) Hot commissioning - plutonium commissioning.

This stage enables the process to be progressively, and cautiously, brought into full operation by addition of plutonium to the process in stages. Additional checks of radiation exposure and heat loading should be made.

7.4. During inactive commissioning the operating organization should verify (by a ‘smoke test’ or other equivalent method) that the location of key radiological instruments is correctly designed, i.e. that the air flows within the facility are as estimated by the calculations during the design stage.

7.5. During commissioning and later during operation of the facility, the estimated doses to personnel that were calculated should be assessed against actual dose rates. If, in operation, the actual doses are higher than the calculated doses, corrective actions should be implemented, including making any necessary changes to the licensing documentation (i.e. the safety analysis report) or adding or changing safety features or work practices (see also Section 8).

7.6. To minimize the contamination of equipment during commissioning, process testing with uranium should be used where necessary to evaluate the performance of instruments for the detection of radiation or processes for the removal of uranium.

7.7. The licence to operate the MOX fuel fabrication facility is generally issued to the operating organization just before the third commissioning stage (plutonium commissioning). In this case, plutonium commissioning will be performed under the responsibility, safety procedures and organization of the operating organization. It may be considered part of the operational stage of the MOX fuel fabrication facility.

7.8. Sufficient operating personnel with required qualifications and training should be available at each stage of the commissioning.

7.9. All processes and equipment associated with the operation of a MOX fuel fabrication facility (as for example waste management processes) should be commissioned using appropriate procedures during the facility commissioning. The purpose is to demonstrate that these processes operate as demonstrated in the safety analysis.

7.10. Where possible, lessons identified from the commissioning and operation of similar MOX fuel fabrication facilities should be sought out and applied.

8. OPERATION OF MOX FUEL FABRICATION FACILITIES

ORGANIZATION OF OPERATION OF MOX FUEL FABRICATION FACILITIES

8.1. The distinctive features of a MOX fuel fabrication facility described in Section 2 should be taken into account in meeting the safety requirements for operation established in Section 9 of SSR-4 [1].

8.2. In a MOX fuel fabrication facility many individual processes are performed with full automation, which helps to reduce human interaction with radioactive material. Because of this, more emphasis is placed on administrative measures, monitoring and preventive maintenance to ensure safe operation.

8.3. The internal safety committee in a MOX fuel fabrication facility, in accordance with para. 4.29 of SSR-4 [1] should be created from the safety committee established for commissioning. Its function should be specified in the management system and it should be adequately staffed. The committee should include diverse expertise and should have appropriate independence from the direct line management of the operating organization (see also para. 3.26).

STAFFING OF A MOX FUEL FABRICATION FACILITY

8.4. Requirement 56 of SSR-4 [1] states that: “[t]he operating organization shall ensure that the nuclear fuel cycle facility is staffed with competent managers and sufficient qualified personnel for the safe operation of the facility.”

8.5. Para. 9.16 of SSR-4 [1] states that: “[a] detailed programme for the operation and utilization of the nuclear fuel cycle facility shall be prepared in advance and shall be subject to the approval of senior management.”

The programme for the operation and utilization of a MOX fuel fabrication facility should be reviewed and updated periodically to ensure that it is consistent with and supports long term objectives. The staffing should address the development of professional and managerial skills and experience, and

should take into account losses of personnel and their knowledge due to retirement and other reasons. The long term staffing plan should allow sufficient time for the transfer of responsibilities to new personnel, and thereby facilitate continuity in the conduct of duties.

8.6. The staffing of a MOX fuel fabrication facility should be based on the functions and responsibilities of the operating organization. A detailed analysis of tasks and activities to be performed should be made to determine the staffing and qualification needs at different levels in the organization. This analysis should also be used to determine the recruitment, training and retraining needs for the facility.

8.7. The operating organization should establish the necessary arrangements to ensure the safety of personnel and the safe operation of a MOX fuel fabrication facility during situations in which a large number of personnel might be unavailable, such as during an epidemic or a pandemic affecting areas in which personnel live. Such arrangements should include the following:

- (a) Retaining a minimum number of qualified personnel on the site to ensure safe operation of the facility;
- (b) Ensuring that a minimum number of qualified back-up personnel remain available off the site;
- (c) Establishing additional measures to prevent the spread of an infection on the site, in accordance with national and international guidance (e.g. enabling remote working for non-essential personnel).

QUALIFICATION AND TRAINING OF PERSONNEL

8.8. The safety requirements relating to the qualification and training of facility personnel are established in Requirements 56 and 58 of SSR-4 [1]. Further recommendations are provided in paras 4.6–4.25 of GS-G-3.1 [9].

8.9. Personnel should be provided periodically with basic training in criticality safety and radiation safety and emphasis should be made on protection from radiation exposure, criticality control and emergency preparedness and response.

8.10. The safety risks for operators, maintenance staff and other personnel, such as the decontamination team, should be carefully considered when establishing the training programme. In particular, all staff handling fissile material, should have a sound understanding of radiation protection, criticality safety and the relevant physical phenomena.

8.11. Training all levels of management should be considered. Personnel involved in the management and operation of the facility should understand the range of hazards present at the MOX fuel fabrication facility at a level of detail consistent with their level of responsibility.

8.12. Comprehensive training should cover both automatic operations and manual operations. Dedicated training facilities should be established as necessary, with the training emphasis on activities according to their potential safety consequences.

8.13. For manual activities, training should include the following:

- (a) Maintenance, cleaning activities and project activities that may involve intervention in the active parts of the facility and/or changes to the facility configuration;
- (b) Work within gloveboxes, glove changes and glovebox posting activities;
- (c) Decontamination, preparation of work areas, erection and dismantling of temporary enclosures and waste handling;
- (d) Procedures for passing barriers, personnel self-monitoring for contamination and the use of

- personal protective equipment;
- (e) Response actions to be undertaken in situations that are outside normal operation (including emergency response actions).

8.14. For automatic modes of operation, training should include the following:

- (a) Comprehensive training for the control room;
- (b) The response to alarms;
- (c) Alertness to the possibility of failures, malfunctions and errors in automatic and remote systems;
- (d) Alertness to unexpected changes (or lack of changes) in key parameters;
- (e) Response actions to be undertaken in situations that are outside normal operation (including emergency response actions).

8.15. Complementary training of safety and security personnel and their mutual participation in exercises of both types should be part of the training programme to effectively manage the interface between safety and security. In particular, personnel with responsibilities and expertise in safety analysis and safety assessment should be provided with a working knowledge of the security requirements of the facility and security experts should be provided with a working knowledge of the safety considerations of the facility, so that potential conflicts between safety and security can be resolved effectively.

OPERATIONAL DOCUMENTATION

8.16. Requirement 57 and paras 9.27–9.37 of SSR-4 [1] require that operational limits and conditions be developed for a MOX fuel fabrication facility. The safety significance of the operational limits and conditions as well as of the action levels and conditions should be well understood by the personnel operating the facility. The set of action levels should be defined and maintained by the operating organization.

8.17. Since the number of operational limits and conditions may be large for a MOX fuel fabrication facility, these could be grouped by topic or activity. Examples of structures, systems and components that may be used when defining operational limits and conditions for each process area are presented in Annex II.

8.18. Close attention should be paid to the prevention of events during non-routine operations and secondary operations such as decontamination, washing and preparation for maintenance or testing.

8.19. Operational documentation should be prepared that list all the operational limits and conditions under which the facility is operated. Annex III gives examples of parameters that can be used for defining the operational limits and conditions in the various processing areas of the facility.

8.20. In accordance with para. 9.31 of SSR-4 [1], limits on operating parameters are required to be established for safe operation of a MOX fuel fabrication facility. Examples of such limits are the following:

- (a) The allowed ranges of the isotopic composition of plutonium oxide and the content of ^{241}Am especially at, but not limited to, the plutonium or MOX receipt stage;
- (b) The maximum plutonium oxide content allowed for the different steps in the process;
- (c) The maximum specific heat loads;
- (d) The maximum allowed throughputs and inventories for the facility;
- (e) The maximum quantities of additives allowed at different steps in the process;
- (f) The maximum quantities of liquid moderator allowed at different steps in the process;
- (g) The maximum concentration of hydrogen allowed in the atmosphere of sintering furnaces;
- (h) The maximum concentrations of oxygen and moisture in gloveboxes;

- (i) The maximum quantities of nuclear material deviating from the process balance (allowed loss rates).

8.21. Examples of administrative controls for safe operation (see para. 9.36 of SSR-4 [1]) for a MOX fuel fabrication facility are:

- (a) Minimum staffing on shift;
- (b) Availability of specific expertise (e.g. criticality expert, radiation protection expert) at all times when the facility is in operation;
- (c) Minimum and maximum number of persons working in a glovebox.

8.22. Consideration should be given to ensuring that plutonium and uranium, especially in the form of powder or pellets, are present only in areas designed for the storage or handling of plutonium and uranium. To meet the requirements established in para. 6.121 and in Requirement 64 of SSR-4 [1], programmes should be put in place for routine monitoring of surface contamination and airborne contamination, and for ensuring an adequate level of housekeeping. Areas with higher dose rates (as for example around gloveboxes) should be clearly delineated and additional barriers where practicable should be provided when operations in these areas are not in progress.

8.23. In a MOX fuel fabrication facility, the safe state of the process attained after any anticipated operational occurrence is often the shutdown state. However, some systems, such as the criticality detection and alarm system, radiation detection and alarm system, and the ventilation system used for confinement, should continue to operate.

8.24. Operating procedures should be developed to control process operations directly. The procedures should include directions for attaining a safe state of the facility for all anticipated operational occurrences and accident conditions. Procedures of this type should include the actions needed to ensure criticality safety, fire protection, emergency preparedness and environmental protection.

8.25. The operating procedures for the ventilation system should be specified for fire conditions, and periodic testing of the ventilation system and fire drills should be performed.

8.26. Procedures should be developed for planned outages of production needed for activities such as inventory checking, maintenance, cleaning equipment from fissile materials, and other operational needs. These procedures should specify systems for ensuring fissile materials are returned to their safe locations. The duration of scheduled activities and relevant compensatory measures should be specified in the procedures.

8.27. To meet Requirement 64 of SSR-4 [1], the following practices should be followed to establish and maintain a high standard of housekeeping in a MOX fuel fabrication facility:

- (a) Prevent the accumulation of materials and tools in gloveboxes;
- (b) Prevent accumulation of nuclear material in gloveboxes;
- (c) Control the amount of radioactive material in gloveboxes in accordance with the principle of optimization of protection;
- (d) Prevent accumulation of flammable materials anywhere in the building (tissues, gloves, cloths, oils, general waste);
- (e) Prevent accumulation of waste inside and outside of gloveboxes;
- (f) Maintain notices and warning signs in good condition;
- (g) Maintain high standards of cleanliness;
- (h) To develop a baseline condition for each workplace by photographs (or equivalent means) ensuring that its condition can be maintained.

MAINTENANCE, CALIBRATION AND PERIODIC TESTING AND INSPECTION

8.28. The safety requirements relating to maintenance, calibration, periodic testing and inspection of MOX fuel fabrication facilities are established in Requirement 65 and paras 9.74–9.82 of SSR-4 [1].

8.29. All maintenance activities in a MOX fuel fabrication facility should be pre-authorized on the basis of a safety report or safety assessment in line with the established management system.

8.30. Before any maintenance activities are undertaken, consideration should be given to radiological checks of the work areas, the need for decontamination and the need for periodic surveys during the period of maintenance and before return to service.

8.31. Before maintenance is performed in areas where fissile material is located, criticality safety staff should be consulted (see also para. 5.46 of SSG-27 [4]).

8.32. Maintenance should follow good practices, with particular consideration given to the following:

- (a) Work control (e.g. handover and handing back of documents, means of communication and visits to job sites, changes to the planned scope of work, suspension of work, ensuring safe access);
- (b) Equipment isolation (e.g. disconnection of electrical cabling and heat and pressure piping, venting and purging of equipment);
- (c) Testing and monitoring (e.g. checks before commencing work, monitoring during maintenance, checks for recommissioning);
- (d) Safety precautions for work (e.g. specification of safety precautions, ensuring the availability of fully functional personal protective equipment and ensuring its use, emergency response procedures);
- (e) Reinstallation of equipment (e.g. reassembly, reconnection of pipes and cables, testing, cleaning the job site and monitoring after recommissioning).
- (f) Verifying that after maintenance is performed the work area and equipment have been placed back within normal safe condition.
- (g) Pressure drops across banks of air filters should be checked and recorded on a routine basis. Particular attention should be paid to gloves to ensure the detection of any degradation of glove material.

8.33. Periodic testing of fire detection and suppression systems for gloveboxes should be performed.

8.34. All temporary changes to the facility configuration during maintenance activities should be coordinated between safety specialist and security specialists to avoid potential conflicts (e.g. loss of electrical power supply on some safety systems, opening of barriers and doors). Compensatory measures should be implemented as necessary.

8.35. Compliance of the operational performance of the ventilation system with the fire protection requirements (see para. 5.61) should be verified on a regular basis.

8.36. The operating organization should have a system in place which ensures that the information and experience gained through maintenance activities is collected, recorded, analysed and utilized in the operating experience feedback programme.

8.37. A programme of periodic inspections of the facility should be established. Its purpose is to verify that the facility and its structures, systems and components are operating in accordance with the operational limits and conditions. Suitably qualified and experienced persons should perform these inspections.

8.38. Places in the process line, identified by the operating organization as those with potential for accumulation of uranium and/or plutonium compounds, should be periodically inspected.

AGEING MANAGEMENT

8.39. The operating organization should take into account the following in implementing an ageing management in accordance with Requirement 60 of SSR-4 [1]:

- (a) Ensuring support for the ageing management programme by the management of the operating organization;
- (b) Ensuring early implementation of an ageing management programme;
- (c) Following a proactive approach based on an adequate understanding of the ageing of structures, systems and components, rather than a reactive approach responding to failures of structures, systems and components;
- (d) Ensuring optimal operation of structures, systems and components to slow down the rate of ageing degradation;
- (e) Ensuring the proper implementation of maintenance and testing activities in accordance with operational limits and conditions, design requirements and manufacturers' recommendations, and following approved operating procedures;
- (f) Minimizing human performance factors that might lead to premature degradation, through enhancement of personnel motivation, sense of ownership and awareness, and understanding of the basic concepts of ageing management;
- (g) Ensuring availability and use of correct operating procedures, tools and materials, and of a sufficient number of qualified staff for a given task;
- (h) Collecting feedback from operating experience to learn from relevant ageing related events.

8.40. The ageing management programme should consider the physical as well as the non-physical aspects of ageing and its effectiveness should be regularly assessed and reviewed.

8.41. The periodic tests and inspections should be completed by regular checks performed by the operating personnel, such as the following:

- (a) Monitoring of deterioration;
- (b) Regular visual inspections of structures, systems and components (e.g. UO₂ and PuO₂ powder pipes);
- (c) Monitoring of operating conditions (e.g. taking heat images of electrical cabinets, check of temperatures of ventilator bearings).

CONTROL OF MODIFICATIONS

8.42. Requirement 61 of SSR-4 [1] states that “[t]he operating organization shall establish and implement a programme for the control of modifications to the facility.” The management system of a MOX fuel fabrication facility should include a standard process for all modifications (see para. 3.19). The work control system, quality assurance procedures and appropriate testing procedures of the facility should be used for the implementation of modifications.

8.43. The operating organization should prepare procedural guidelines and provide training to ensure that the responsible personnel have the necessary training and authority to ensure that modification projects are carefully considered: see paras 9.57(e) and 9.58 of SSR-4 [1]. The safety of modifications should be assessed for potential hazards during installation, commissioning and operation. Decision making relating to modifications should be conservative.

8.44. Proposed modifications should be scrutinized by and be subject to approval by qualified and experienced persons to verify that the arguments used to demonstrate safety are suitably robust. This is

considered particularly important if the modification could have an effect on criticality safety.

8.45. The depth of the safety arguments and the degree of scrutiny to which they are subjected should be commensurate with the safety significance of the modification (see also para. 9.59 of SSR-4 [1]).

8.46. The safety committee is required to review the proposed modifications (see para. 4.31(d) of SSR-4 [1]). Suitable records should be kept of their decisions and recommendations.

8.47. The modification should also specify which documentation will need to be updated as a result of the modification (e.g. training plans, specifications, safety assessment, notes, drawings, engineering flow diagrams, process instrumentation diagrams, operating procedures). Procedures for the control of documentation should be put in place to ensure that documents are changed within a reasonable time period following the modification. Personnel should be informed and trained accordingly before operation commences.

8.48. An adequate management process should be used as an overall means of monitoring the progress of modifications through the system and as a means of ensuring that all modification proposals receive an equivalent and sufficient level of scrutiny. The modification documentation should also specify the functional (commissioning) checks that are required before the modified system may be declared fully operational again.

8.49. Modifications performed on design, layout or procedures of the facility might adversely affect security equipment and vice versa. For example, malfunction of safety equipment might damage nearby security equipment. Therefore, in addition to the safety review, the interface of proposed modifications with security should be evaluated before approval and implementation to verify that they do not compromise each other: see Requirement 75 of SSR-4 [1].

8.50. The modifications made to a facility (including those to the operating organization) should be reviewed on a regular basis to ensure that the cumulative effects of a number of modifications with minor safety significance do not have unforeseen effects on the overall safety of the facility. This should be part of (or additional to) the periodic safety review or an equivalent review process.

8.51. The modification control documentation (see para. 9.57(f) of SSR-4 [1]) should be retained at the facility in accordance with national requirements.

CONTROL OF NUCLEAR CRITICALITY HAZARDS

8.52. The requirements for criticality safety in MOX fuel fabrication facilities are established in Requirement 66 and paras 9.83–9.85 and 9.87 of SSR-4 [1], and general recommendations are provided in SSG-27 [4]. The procedures and measures for controlling criticality hazards should be strictly applied.

8.53. Operational aspects of the control of criticality hazards in MOX fuel fabrication facilities should be taken into consideration, including the following:

- (a) Prevention of unexpected changes in conditions that could increase the probability of a criticality accident; for example, unplanned accumulation of PuO₂ or MOX powder (e.g. in gloveboxes or ventilation ducts) or hydrogenated materials;
- (b) Management of moderating materials, particularly hydrogenated materials such as those used for the decontamination of gloveboxes, and leakages of oils from gear boxes;
- (c) Management of mass in transfers of plutonium and uranium (procedures, mass measurement, systems and records) for which mass control is used;
- (d) Reliable methods for detecting the onset of any of the foregoing conditions;
- (e) Periodic calibration or testing of systems for the control of criticality hazards (e.g. control of

movements of material, balances, scales);

- (f) Evacuation drills to prepare for the occurrence of a criticality and/or the actuation of an alarm.

8.54. The tools used for the purposes of nuclear material accounting and control, such as the instruments used to conduct measurements of mass, volume or isotopic compositions and the software used for these purposes, may also have application in the area of criticality safety. However, if there is any uncertainty about the characteristics of fissile material, conservative values should be used for parameters such as the plutonium content and the isotopic composition.

8.55. Criticality hazards might be encountered when performing maintenance work. Waste and residues arising from decontamination and maintenance activities should be collected in containers with a favourable geometry approved for the work and should be stored in criticality controlled areas. Maintenance instructions and procedures for equipment that possibly contain fissile material should be reviewed and approved by criticality safety staff before the work starts. Special care including the effect of moderation (including by a human body) should be taken to ensure the proper spacing of vessels or installation parts that may contain fissile material.

RADIATION PROTECTION

8.56. The requirements for radiation protection in operation are established in Requirement 67 and paras 9.90–9.101 of SSR-4 [1] and in GSR Part 3 [17]; recommendations are provided in IAEA Safety Standards Series No. GSG-7, Occupational Radiation Protection [32]. The operating organization should have a policy to optimize protection and safety and is required to ensure doses are below national dose limits and within any dose constraints set by the operating organization (see para. 9.91 of SSR-4 [1]).

8.57. In a MOX fuel fabrication facility, the main radiological hazard for both the personnel and the public is from the inhalation of airborne plutonium oxide or MOX powder. Plutonium oxide and MOX powders pose a particular hazard because of their long biological half-lives (and therefore effective half-lives)⁵, and their typically relatively small particle size (typically a few micrometres in diameter) when encountered in MOX fuel fabrication facilities. Thus, close attention should be paid to the confinement of plutonium oxide and MOX powders and the control of contamination in the workplace.

8.58. For MOX fuel fabrication facilities, in normal operation, the external dose rate from beta and gamma radiation and neutron emission is relatively low. A high external dose rate might be encountered in the case of a criticality accident.

8.59. The doses caused by plutonium should be controlled by integrity of the first confinement barrier, which should be monitored close to the workplace of the operator, by means of continuous air-sampling and routine monitoring for surface contamination.

8.60. Workplace monitoring for purposes of radiation protection inside and outside the MOX fuel fabrication facility buildings should be complemented by regular, routine monitoring by trained personnel. This should be organized to provide, as far as practicable, regular workplace monitoring of the whole MOX fuel fabrication facility site. Particular attention should be paid to the recording, labelling or posting where necessary, evaluating and reporting of abnormal radiation levels or abnormal situations. The frequency of workplace monitoring should be related to the relative risk of radiation or contamination in the individual areas. Radiation protection personnel should consider assigning a

⁵ The biological half-life is the time taken for the amount of a material in a specified tissue, organ or region of the body to halve as a result of biological processes. The effective half-life is the time taken for the activity of a radionuclide in a specified place to halve as a result of all relevant processes.

frequency for monitoring of each facility area based upon easily identified boundaries. The use of photographs or drawings of the area or equipment should be considered for reporting the findings.

8.61. Radiation protection personnel should be part of the decision making processes associated with the application of the requirements for minimization of exposure (e.g. for the early detection and mitigation of hot spots) and proper housekeeping (e.g. waste segregation, packaging and removal).

8.62. Interventions for maintenance and/or modifications are activities that require justification and optimization of protective actions as specified in GSR Part 3 [17]. The procedures for intervention should include the following:

- (a) Estimation of doses due to external exposure before the intervention.
- (b) Preparatory activities to minimize the doses due to occupational exposure, including:
 - (i) Identifying specifically the risks associated with the intervention;
 - (ii) Specifying in the work permit protective measures for the intervention such as for the individual and collective means of protection (e.g. use of masks, clothing and gloves, and time limitation).
- (c) Measurement of the doses due to occupational exposure during the intervention.
- (d) Implementation of feedback of information for identifying possible improvements.

8.63. The risks of exposure of members of the public should be minimized by ensuring that, as far as reasonably practicable, radioactive material is kept away and/or removed from ventilation exhaust gases to prevent its entrainment in the effluent waste stream and subsequent discharge to the atmosphere.

8.64. The monitoring results from the radiation protection programme should be compared with the operational limits and conditions, and corrective actions are required be taken if necessary (see para. 9.34 of SSR-4 [1]). Furthermore, these monitoring results should be used to verify the dose calculations made in the initial environmental impact assessment.

8.65. Internal exposure should be controlled by the following means:

- (a) Performance targets should be set for all parameters relating to internal exposure, e.g. levels of contamination.
- (b) Enclosures and ventilation systems should be routinely inspected, tested and maintained to ensure that they continue to fulfil their design requirements. Regular flow checks should be performed at ventilation hoods and entrances to confinement areas. Pressure drops across air filter banks should be checked and recorded regularly.
- (c) Operators should be made aware of and specially trained in the immediate actions necessary in the event of the puncture of a glove and/or a breach of confinement integrity.
- (d) A high standard of housekeeping should be maintained at the facility. Cleaning techniques should be used that do not give rise to airborne radioactive material, e.g. the use of vacuum cleaners with HEPA filters.
- (e) Regular contamination surveys of areas of the facility and equipment should be performed to confirm the adequacy of cleaning programmes.
- (f) Contamination zones should be delineated and clearly indicated.
- (g) Continuous air monitoring should be performed to alert facility operators if levels of airborne radioactive material exceed predetermined action levels.
- (h) Mobile air samplers should be used at possible sources of contamination as necessary.
- (i) An investigation should be conducted promptly in response to the detection of high levels of airborne radioactive material.
- (j) Personnel and equipment should be checked for contamination and should undergo decontamination if necessary, before leaving contamination zones. Entry to and exit from the work area should be controlled to prevent the spread of contamination. In particular, changing rooms

and decontamination facilities should be provided.

- (k) Temporary means of ventilation and means of confinement should be used when intrusive work increases the potential for causing contamination by airborne radioactive material (e.g. during periodic testing, inspection or maintenance).
- (l) Personal protective equipment (e.g. respirators, gloves, clothes) should be made available and should be used when dealing with possible releases of radioactive material from its normal means of confinement in specific operational circumstances (e.g. bag-out and/or bag-in operations, certain maintenance operations or changing of gloves of gloveboxes).
- (m) Personal protective equipment should be maintained in good condition, should be cleaned as necessary, and should be periodically inspected.
- (n) Any personnel having wounds should protect them with an impervious covering for work in contamination zones.

8.66. In vivo monitoring and biological sampling should be available as necessary as a complementary measure for monitoring doses due to occupational exposure. Whole body measurements should also be performed periodically to check for internal exposure of workers.

8.67. The extent and type of workplace monitoring should be commensurate with the expected level of airborne activity, contamination levels and radiation type, and the potential for any of these parameters to change.

8.68. For exposures which are expected to be low, the method for assessing doses due to internal exposure should be based on the collection of data from air sampling in the workplace, in combination with personnel occupancy data. This method should be assessed and should be reviewed as appropriate by the regulatory body.

8.69. In performing the activities for periodic testing, inspection and maintenance, precautions should be taken to limit, by the use of temporary enclosures and ventilation systems, the spread of radioactive material.

8.70. On completion of maintenance work, the area concerned should be decontaminated and air sampling and smear sampling of surfaces should be performed to confirm that the area can be returned to normal use.

8.71. Estimates should be regularly made, by means of monitoring data on effluents, of doses due to internal exposure received by members of the public who live in the vicinity of the site.

8.72. External exposure due to gamma radiation from americium (and residual fission products from uranium oxide where appropriate) and neutron radiation from plutonium oxide should be controlled by means of an appropriate combination of requirements on time, distance and shielding. Radioactive sources are used in a MOX fuel fabrication facility for scanning rods and in the laboratory.

8.73. Although most of the processes in a MOX fuel fabrication facility are automated, there are some actions that require manual work in gloveboxes. Owing to the proximity of the hands of operators to plutonium oxide when work in gloveboxes is being performed, the hands are more susceptible to exposure than other parts of the body. The dose to the hands should therefore be monitored (by extremity dosimetry) together, when necessary with doses to the lens of the eye.

8.74. External exposure should be controlled by the following:

- (a) Training of personnel in radiation hazards and the use of dose monitoring equipment;
- (b) Removing plutonium oxide and other radioactive material from process areas in use for extended maintenance work;

- (c) Ensuring that radiation sources are changed by suitably qualified and experienced persons;
- (d) Avoiding unnecessary presence in the vicinity of gloveboxes;
- (e) Using individual and temporary shielding;
- (f) Performing routine surveys of radiation dose rates.

INDUSTRIAL AND CHEMICAL SAFETY

8.75. The requirements relating to industrial and chemical safety are established in Requirement 70 of SSR-4 [1].

8.76. A mixture of argon and hydrogen is generally used in the sintering furnaces in MOX fuel fabrication facilities. Nitrogen may be used in gloveboxes to ensure the quality of the product. Carbon dioxide may be used in automatic fire suppression systems except where it might cause a criticality hazard. A leakage of any of these gases may cause asphyxiation. Additionally, there is a potential for explosion at the location outside the main processing building where the mixing of hydrogen with argon is conducted.

8.77. The industrial and chemical hazards present in MOX fuel fabrication facilities may be summarized as follows:

- (a) Asphyxiation hazards due to the presence of argon or hydrogen or mixtures thereof, or of nitrogen or carbon dioxide;
- (b) Explosion of hydrogen storage bottles outside the main MOX processing building;
- (c) Fire hazards including metallic fires involving zirconium metal shavings;
- (d) Gas storage bottles becoming missiles;
- (e) Chemical hazards in the laboratory.

8.78. The exposure of personnel to chemical hazards should be assessed using a method similar to that for the assessment of radiation doses and should be based upon the collection of data from air sampling in the workplace, in combination with personnel occupancy data. This method should be assessed and reviewed as appropriate by the regulatory body. The acceptance levels of exposure for various chemical hazards in a MOX fuel fabrication facility can be found in Ref. [24].

8.79. The selection of personal protective equipment should be commensurate to the hazard present (e.g. acid filters for protective equipment for acids, particulate filters for particulates and combination filters where both hazards are present).

8.80. Gas storage bottles are used to store various gases such as carbon dioxide, hydrogen, and mixtures of argon and hydrogen. Procedures should be developed and used to ensure the proper storage and handling of gas storage bottles to prevent them from becoming missiles.

8.81. Chemicals are used mostly in the laboratory for performing product analyses. Personnel should be made aware of the potential chemical hazards. Written procedures should be developed and used to control the quantity and handling of chemicals in the laboratory to prevent events such as explosion, fire, high toxicity, undesirable chemical interactions. Chemicals should be stored in well aerated premises or in racks outside the process and laboratory area.

8.82. To minimize the fire hazard of pyrophoric metals (zirconium or uranium particles) locations where such materials could accumulate should be monitored, should be periodically checked and should be cleaned in accordance with procedures. In some cases, routine flushing out (i.e. high flow rate washing) of equipment may be necessary.

8.83. The procedures and training for response to fires in areas containing fissile material should pay

particular attention to the prevention of a criticality and preventing any unacceptable reduction of criticality safety margins.

8.84. The work permit and facility procedures and instructions should include an adequate assessment of and, as necessary, a check-sheet on the potential radiological consequences of fires resulting from activities that involve potential ignition sources (e.g. welding), and should define the precautions necessary for performing such work.

8.85. The prevention and control of accumulation of waste material (contaminated material and 'clean' material) should be rigorously enforced to minimize the fire load (fire potential) in all areas of the MOX fuel fabrication facility. Auditing for accumulation of waste material should be an important element in all routine inspection and surveillance activities by all levels of personnel. Periodic inspections by fire safety professionals should be part of the audit programme.

8.86. A health surveillance programme should be set up, in accordance with national regulations, for routinely monitoring the health of personnel who might be exposed to chemicals. Monitoring of the chemical effects of uranium and of the radiological effects of plutonium, as necessary, should be considered the core part of the health surveillance programme. The surveillance program should address short term effects (acute exposure) and long term effects (chronic exposure).

8.87. During an emergency, special consideration should be given to the presence of both chemical and radiological hazards.

MANAGEMENT OF RADIOACTIVE WASTE AND EFFLUENTS

8.88. The requirements relating to the management of radioactive waste and effluents in operation are established in Requirement 68 and paras 9.102–9.108 of SSR-4 [1].

8.89. Radioactive gases should be treated, where appropriate, by means of HEPA filters or equivalent (see para. 5.147). Performance standards should be set to specify performance levels at which filters or scrubber media should be changed, including filter age. After filter changes, tests should be performed to ensure that new filters are correctly seated and yield a removal efficiency as used in the analyses. Suitable storage and quality control measures should be implemented for new filters.

8.90. The generation of solid radioactive waste should be minimized by removing as much outer packing as possible before material is transferred to controlled areas. The operating organization should use the best available techniques in minimizing the generation of radioactive waste (including incineration, metal melting and compaction). As far as reasonably practicable, and in accordance with national regulations, radioactive material should be treated to allow its further use. Cleaning methods should be adopted at the facility that minimize the generation of waste.

EMERGENCY PREPAREDNESS AND RESPONSE

8.91. The requirements for emergency preparedness and response are established in Requirement 72 and paras 9.120–9.132 of SSR-4 [1], in GSR Part 7 [25], and recommendations are provided in GS-G-2.1 [26] and in IAEA Safety Standards Series No. GSG-2, Criteria for Use in Preparedness and Response for a Nuclear or Radiological Emergency [33]. The conditions at a MOX fuel fabrication facility that might require an off-site emergency response to be initiated include releases of plutonium, criticality accidents, fires and explosions and loss of services (see para. 9.126 (a) of SSR-4 [1]).

8.92. As part of emergency preparedness, arrangements should be developed for the interfaces with local, regional and national response organizations. These arrangements should be tested periodically to ensure effective operation during an emergency. Clear communication and authorization protocols

should be established with local authorities to ensure that the emergency response organization can respond effectively to an emergency at the facility.

8.93. The operating organization should ensure availability of personnel with specific expertise on the nature and extent of hazards in facility as well as availability and reliability of all supplies, equipment, communication systems, plans, procedures and other arrangements necessary for effective response in an emergency. The operating organization and response organizations should develop analytical tools that may be used early in an emergency response for supporting decision making on protective actions and other response actions.

8.94. As specified in GSR Part 7 [25], emergency plans, security plans and contingency plans should be developed in a coordinated manner, considering all responsibilities of the facility personnel and security forces, to ensure that in the case of an event when simultaneous response of both groups is needed, all crucial functions can be performed in a timely manner. Emergency response plans should consider nuclear security events as possible initiators of an emergency and their implications on emergency situations and should be coordinated with the security response. Strategies for rapidly determining the origin of events and deploying appropriate first responders (safety personnel, security forces or a combination of both) should be developed. These strategies should also include the roles and actions of security forces and emergency response personnel, with a focus on coordinated command and control interfaces and communications. The response to such events should be jointly exercised and evaluated by security forces and emergency response personnel. From these exercises or evaluations, lessons should be identified and recommendations should be made to improve the overall response to a potential event.

8.95. For establishing access control procedures for an emergency, when there is a necessity for rapid access and egress of personnel, safety specialists and security specialists should cooperate closely. Both safety objectives and security objectives should be met in an emergency, in accordance with regulatory requirements. When this is not possible, the best solution that takes into account both objectives should be pursued.

FEEDBACK OF OPERATING EXPERIENCE

8.96. Requirements on feedback of operating experience are established in paras 9.133–9.137 of SSR-4 [1]. Further recommendations on the operating experience programme are provided in SSG-50 [14].

8.97. The programme for the feedback of operating experience at MOX fuel fabrication facilities should cover experience and lessons identified from events and accidents at the facility as well as from other nuclear fuel cycle facilities worldwide and other relevant non-nuclear accidents. It should also include evaluation of trends in operational disturbances, trends in malfunctions, near misses and other incidents that have occurred at the MOX fuel fabrication facility and, as far as applicable, at other nuclear installations. The programme should include consideration of technical, organizational and human factors. Useful information on the causes and consequences of many of the most important anomalies and accidents that have been observed in MOX fuel fabrication facilities and other nuclear fuel cycle facilities is provided in Ref. [34].

9. PREPARATION FOR DECOMMISSIONING OF MOX FUEL FABRICATION FACILITIES

9.1. Requirements for the preparation for safe decommissioning of a MOX fuel fabrication facility are established in paras 10.1 – 10.13 of SSR-4 [1], and in IAEA Safety Standards Series No. GSR Part 6, Decommissioning of Facilities [35].

9.2. To facilitate the decommissioning the gloveboxes should be routinely cleaned in the operational stage, in accordance with the justification provided for the cleaning interventions (the balance of cost and benefit in respect of exposure and the generation of waste).

9.3. Special measures should be implemented during the preparatory works for decommissioning to ensure that criticality control is maintained when handling equipment containing nuclear material for whose subcriticality is controlled by geometry, moderation or absorption. Care should also be taken for possible changes in the fissile material form.

9.4. In addition to the general preparations for decommissioning described in IAEA Safety Standards Series No. SSG-47, Decommissioning of Nuclear Power Plants, Research Reactors and Other Nuclear Fuel Cycle Facilities [36] the following preparatory steps specific to MOX fuel fabrication facilities should be followed:

- (a) The facility status at the beginning of decommissioning, including the list of systems that should be operational, should be described.
- (b) During the transition period between shutdown and decommissioning, post-operational cleanout should be performed to remove all bulk amounts of plutonium oxide and MOX powder in gloveboxes in order to reduce the residual inventory of plutonium. The plutonium inventory should be determined on the basis of accounting data for nuclear material.
- (c) Any grounds (surface and subsurface), groundwater, parts of buildings and equipment contaminated with radioactive material or chemical material and their levels of contamination should be identified by means of comprehensive site characterization.
- (d) Parts of buildings and items of equipment that are contaminated with plutonium and their levels of contamination should be identified.
- (e) Decontamination methods of the facility to reach the levels required by the regulatory body for cleanup operations or the lowest reasonably achievable level of residual contamination should be determined.
- (f) Risk assessments and method statements for the decommissioning process should be prepared.
- (g) Preparations for the dismantling of process equipment, gloveboxes and ducts upstream of the HEPA filters (or equivalent) should be made including the following:
 - (i) Selection and justification of the dismantling methods and equipment (such as ventilated tents), with account taken of all the options for waste management (pre-treatment, conditioning and disposal);
 - (ii) Organization and planning of the dismantling interventions;
 - (iii) Assessment of the risks associated with dismantling, including emergency preparedness and response.

9.5. The developed decommissioning plan and the safety assessment should be periodically reviewed and updated throughout the commissioning and operation stages of the MOX fuel fabrication facility (see Requirements 8 and 10 of GSR Part 6 [35]) to take into account new information and emerging technologies to ensure that:

- (a) The (updated) decommissioning plan is realistic and can be implemented safely;
- (b) Updated provisions are made for adequate resources and their availability, when needed;

- (c) The radioactive waste anticipated remains compatible with available (or planned) storage capacities and disposal considering its transport and treatment.

REFERENCES


- [1] INTERNATIONAL ATOMIC ENERGY AGENCY, Safety of Nuclear Fuel Cycle Facilities, IAEA Safety Standards Series No. SSR-4, IAEA, Vienna (2017).
- [2] INTERNATIONAL ATOMIC ENERGY AGENCY, Safety of Uranium Fuel Fabrication Facilities, IAEA Safety Standards Series No. SSG-6 (Rev. 1), IAEA, Vienna (in preparation).
- [3] INTERNATIONAL ATOMIC ENERGY AGENCY, Safety of Nuclear Fuel Reprocessing Facilities, IAEA Safety Standards Series No. SSG-42, IAEA, Vienna (2017).
- [4] INTERNATIONAL ATOMIC ENERGY AGENCY, Criticality Safety in the Handling of Fissile Material, IAEA Safety Standards Series No. SSG-27, IAEA, Vienna (2009). (A revision of this publication is in preparation.)
- [5] INTERNATIONAL ATOMIC ENERGY AGENCY, Governmental, Legal and Regulatory Framework for Safety, IAEA Safety Standards Series No GSR Part 1 (Rev. 1), IAEA, Vienna (2016).
- [6] INTERNATIONAL ATOMIC ENERGY AGENCY, Nuclear Security Recommendations on Physical Protection of Nuclear Material and Nuclear Facilities (INFCIRC/225/Revision 5), IAEA Nuclear Security Series No. 13, IAEA, Vienna (2011).
- [7] INTERNATIONAL ATOMIC ENERGY AGENCY, Physical Protection of Nuclear Material and Nuclear Facilities (Implementation of INFCIRC/225/Revision 5), IAEA Nuclear Security Series No. 27-G, IAEA, Vienna (2018).
- [8] INTERNATIONAL ATOMIC ENERGY AGENCY, Leadership and Management for Safety, IAEA Safety Standards Series No. GSR Part 2, IAEA, Vienna (2016).
- [9] INTERNATIONAL ATOMIC ENERGY AGENCY, Application of the Management System for Facilities and Activities, IAEA Safety Standards Series No. GS-G-3.1, IAEA, Vienna (2006). (A revision of this publication is in preparation.)
- [10] INTERNATIONAL ATOMIC ENERGY AGENCY, The Management System for Nuclear Installations, IAEA Safety Standards Series No. GS-G-3.5, IAEA, Vienna (2009).
- [11] INTERNATIONAL ATOMIC ENERGY AGENCY, Leadership, Management Sy and Culture for Safety in Radioactive Waste Management, IAEA Safety Standards Series No. GSG-16, IAEA, Vienna (in preparation).
- [12] INTERNATIONAL ATOMIC ENERGY AGENCY, The Management System for the Safe Transport of Radioactive Material, IAEA Safety Standards Series No. TS-G-1.4, IAEA, Vienna (2008).
- [13] INTERNATIONAL ATOMIC ENERGY AGENCY, Safety Assessment for Facilities and Activities, IAEA Safety Standards Series No. GSR Part 4 (Rev. 1), IAEA, Vienna (2016).
- [14] INTERNATIONAL ATOMIC ENERGY AGENCY, Operating Experience Feedback for Nuclear Installations, IAEA Safety Standards Series No. SSG-50, IAEA, Vienna (2018).
- [15] INTERNATIONAL ATOMIC ENERGY AGENCY, Site Evaluation for Nuclear Installations, IAEA Safety Standards Series No. SSR-1, IAEA, Vienna (2019).
- [16] INTERNATIONAL ATOMIC ENERGY AGENCY, Site Survey and Site Selection for Nuclear Installations, IAEA Safety Standards Series No. SSG-35, IAEA, Vienna (2015).
- [17] EUROPEAN COMMISSION, FOOD AND AGRICULTURE ORGANIZATION OF THE UNITED NATIONS, INTERNATIONAL ATOMIC ENERGY AGENCY, INTERNATIONAL LABOUR ORGANIZATION, OECD NUCLEAR ENERGY AGENCY, PAN AMERICAN HEALTH ORGANIZATION, UNITED NATIONS ENVIRONMENT PROGRAMME, WORLD HEALTH ORGANIZATION, Radiation Protection and Safety of Radiation Sources: International Basic Safety Standards, IAEA Safety Standards Series No. GSR Part 3, IAEA, Vienna (2014).
- [18] INTERNATIONAL ATOMIC ENERGY AGENCY, Prospective Radiological Environmental Impact Assessment for Facilities and Activities, IAEA Safety Standards Series No. GSG-10,

- IAEA, Vienna (2018).
- [19] INTERNATIONAL ATOMIC ENERGY AGENCY, Seismic Hazards in Site Evaluation for Nuclear Installations, IAEA Safety Standards Series No. SSG-9 (Rev. 1), IAEA, Vienna (in preparation).
 - [20] INTERNATIONAL ATOMIC ENERGY AGENCY, Meteorological and Hydrological Hazards in Site Evaluation for Nuclear Installations, IAEA Safety Standards Series No. 18, IAEA, Vienna (2011).
 - [21] INTERNATIONAL ATOMIC ENERGY AGENCY, Volcanic Hazards in Site Evaluation for Nuclear Installations, IAEA Safety Standards Series No. SSG-21, IAEA, Vienna (2012).
 - [22] INTERNATIONAL ATOMIC ENERGY AGENCY, Design of Nuclear Installations Against External Events Excluding Earthquakes, IAEA Safety Standards Series No. SSG-68, IAEA, Vienna (in preparation).
 - [23] INTERNATIONAL ATOMIC ENERGY AGENCY, Safety Reassessment for Nuclear Fuel Cycle Facilities in Light of the Accident at the Fukushima Daiichi Nuclear Power Plant, IAEA Safety Reports Series No. 90, IAEA, Vienna (2016).
 - [24] AMERICAN CONFERENCE OF GOVERNMENTAL INDUSTRIAL HYGIENISTS, 2021 Threshold Limit Values (TLVs) and Biological Exposure Indices (BEIs), ACGIH, Cincinnati (2021).
 - [25] FOOD AND AGRICULTURE ORGANIZATION OF THE UNITED NATIONS, INTERNATIONAL ATOMIC ENERGY AGENCY, INTERNATIONAL CIVIL AVIATION ORGANIZATION, INTERNATIONAL LABOUR ORGANIZATION, INTERNATIONAL MARITIME ORGANIZATION, INTERPOL, OECD NUCLEAR ENERGY AGENCY, PAN AMERICAN HEALTH ORGANIZATION, PREPARATORY COMMISSION FOR THE COMPREHENSIVE NUCLEAR-TEST-BAN TREATY ORGANIZATION, UNITED NATIONS ENVIRONMENT PROGRAMME, UNITED NATIONS OFFICE FOR THE COORDINATION OF HUMANITARIAN AFFAIRS, WORLD HEALTH ORGANIZATION, WORLD METEOROLOGICAL ORGANIZATION, Preparedness and Response for a Nuclear or Radiological Emergency, IAEA Safety Standards Series No. GSR Part 7, IAEA, Vienna (2015).
 - [26] FOOD AND AGRICULTURE ORGANIZATION OF THE UNITED NATIONS, INTERNATIONAL ATOMIC ENERGY AGENCY, INTERNATIONAL LABOUR OFFICE, PAN AMERICAN HEALTH ORGANIZATION, UNITED NATIONS OFFICE FOR THE COORDINATION OF HUMANITARIAN AFFAIRS, WORLD HEALTH ORGANIZATION, Arrangements for Preparedness for a Nuclear or Radiological Emergency, IAEA Safety Standards Series No. GS-G-2.1, IAEA, Vienna (2007).
 - [27] INTERNATIONAL ATOMIC ENERGY AGENCY, Predisposal Management of Radioactive Waste, IAEA Safety Standards Series No. GSR Part 5, IAEA, Vienna (2009).
 - [28] INTERNATIONAL ATOMIC ENERGY AGENCY, The Safety Case and Safety Assessment for the Predisposal Management of Radioactive Waste, IAEA Safety Standards Series No. GSG-3, IAEA, Vienna (2013).
 - [29] INTERNATIONAL ATOMIC ENERGY AGENCY, Classification of Radioactive Waste, IAEA Safety Standards Series No. GSG-1, IAEA, Vienna (2009).
 - [30] INTERNATIONAL ATOMIC ENERGY AGENCY, Predisposal Management of Radioactive Waste from Nuclear Fuel Cycle Facilities, IAEA Safety Standards Series No. SSG-41, IAEA, Vienna (2016).
 - [31] INTERNATIONAL ATOMIC ENERGY AGENCY, Construction for Nuclear Installations, IAEA Safety Standards Series No. SSG-38, IAEA, Vienna (2015).
 - [32] INTERNATIONAL ATOMIC ENERGY AGENCY, INTERNATIONAL LABOUR OFFICE, Occupational Radiation Protection, IAEA Safety Standards Series No. GSG-7, IAEA, Vienna (2018).
 - [33] FOOD AND AGRICULTURE ORGANIZATION OF THE UNITED NATIONS,

- INTERNATIONAL ATOMIC ENERGY AGENCY, INTERNATIONAL LABOUR OFFICE, PAN AMERICAN HEALTH ORGANIZATION, WORLD HEALTH ORGANIZATION, Criteria for Use in Preparedness and Response for a Nuclear or Radiological Emergency, IAEA Safety Standards Series No. GSG-2, IAEA, Vienna (2011).
- [34] INTERNATIONAL ATOMIC ENERGY AGENCY, NUCLEAR ENERGY AGENCY, IAEA/NEA Fuel Incident Notification and Analysis System (FINAS), <http://finas.iaea.org/>.
- [35] INTERNATIONAL ATOMIC ENERGY AGENCY, Decommissioning of Facilities, IAEA Safety Standards Series No. GSR Part 6, IAEA, Vienna (2014).
- [36] INTERNATIONAL ATOMIC ENERGY AGENCY, Decommissioning of Nuclear Power Plants, Research Reactors and Other Nuclear Fuel Cycle Facilities, IAEA Safety Standards Series No. SSG-47, IAEA, Vienna (2018)

ANNEX I

TYPICAL PROCESS ROUTES IN A MOX FUEL FABRICATION FACILITY



ANNEX II
EXAMPLES OF STRUCTURES, SYSTEMS AND COMPONENTS IMPORTANT TO
SAFETY AND POSSIBLE CHALLENGES TO SAFETY FUNCTIONS FOR MOX
FUEL FABRICATION FACILITIES

Safety function:

- (1) Criticality prevention;
- (2) Confinement of radioactive material;
- (3) Protection against external exposure.

Process area	Structures, systems and components important to safety	Events	Safety function initially challenged
Receipt of PuO ₂ and MOX	Equipment for non-destructive analysis or destructive analysis of PuO ₂ for isotopic characterization ^a	Degradation of criticality safety margin (material out of specification)	(1)
Receipt of UO ₂	Equipment for non-destructive analysis or destructive analysis of UO ₂ for isotopic and stoichiometric characterization ^a	Degradation of criticality safety margin (material out of specification) Fire (spontaneous ignition of UO ₂ in air owing to stoichiometry being out of specification)	(1), (2)
Powder preparation	Equipment for powder metering (dosing) and weighing	Degradation of criticality safety margin (mass)	(1)
	Additive metering device	Degradation of criticality safety margin (moderation)	(1)
	Homogenizer mixer	Degradation of criticality safety margin (mass) Radiolysis due to hydrogenated additives	(1) (2)

Process area	Structures, systems and components important to safety	Events	Safety function initially challenged
	Gloveboxes	Release of radioactive material (glovebox leak, glove rupture)	(2)
	Shielding	Increase in dose rate to hands and body	(3)
Pellet manufacture	Pellet press design (oil volume limit)	Degradation of criticality safety margin (moderation — oil leak) Fire (oil leak)	(1), (2)
	Sintering furnace design (gas mixture control, leaktightness, airlocks)	Release of radioactive material (explosion in sintering furnace)	(2)
	Gloveboxes	Release of radioactive material (glovebox leak, glove rupture)	(2)
	Shielding	Increase in dose rate to hands and body	(3)
	Grinding dust cleaning system	Increase in dose rate (if system fails and dust accumulates in glovebox)	(3)
Pellet storage	Pellet storage rack structure	Degradation of criticality safety margin (geometry)	(1)
	Ventilation and air cooling device	Degradation of neutron absorber (due to heating of plutonium)	(1)
Fuel rod manufacture	Gloveboxes	Release of radioactive material (glovebox leak, glove rupture)	(2)
	Glovebox fire protection systems	Fire (zirconium particles)	(2)

Process area	Structures, systems and components important to safety	Events	Safety function initially challenged
	Shielding	Increase in dose rate to hands and body	(3)
Fuel rod inspection	Rod testing equipment for leaktightness	Release of radioactive material	(2)
	Shielding	Increase in dose rate to hands and body	(3)
	Rod X ray scanner	External exposure	(3)
	Rod transfer machines	Breakage	(2)
Fuel rod storage	Fuel rod structure	Degradation of criticality safety margin (geometry)	(1)
	Ventilation and air cooling devices	Degradation of neutron absorber (due to heating of plutonium)	(1)
Fuel rod assembly manufacture	Handling machines on assembly lines	Degradation of criticality safety margin (geometry, neutron absorber, moderation) Rod breakage (release of radioactive material) External hazard (time and/or proximity to rods)	(1) (2) (3)
	Fire protection systems	Fire (zirconium particles)	(2), (3)
	Cranes	Dropped assembly	(1), (2)
	Washing unit	Degradation of criticality safety margin (geometry, moderation, reflection)	(1)
Fuel assembly storage	Fuel assembly storage structure	Degradation of criticality safety margin (geometry)	(1)
	Ventilation and air cooling devices	Degradation of neutron absorber (due to heating of plutonium)	(1)
	Shielding	Increase in dose rate	(3)

Process area	Structures, systems and components important to safety	Events	Safety function initially challenged
MOX scrap recovery	Gloveboxes	Release of radioactive material	(2)
	Shielding	Increase in dose rate to hands and body	(3)
	Characterizing devices for plutonium content and moderation	Degradation of criticality safety margin (mass, moderation) Radiolysis due to hydrogenated additives	(1) (2)
Laboratory	Gloveboxes	Release of radioactive material	(2)
	Storage of samples	Increase of dose rate	(1)
	Use of chemicals	Chemical reactions including fire Radiolysis	(2) (2)
Waste handling	Measuring devices for plutonium content	Degradation of criticality safety margin (mass)	(1)
	Fire protection systems in the radioactive waste storage area	Fire	(2)
All process areas	Building structure, including wall penetrations and doors between fire areas and between confinement areas	Loss of integrity	(2)
	Ventilation systems and controls	Loss of dynamic confinement with release of radioactive material into the workplace The amount of accumulation of radioactive and fissile materials on the first stage filters	(2) (1), (3)
	Filters inside the process areas	Fire Degradation of criticality safety margin (mass)	(2) (1)

Process area	Structures, systems and components important to safety	Events	Safety function initially challenged
	Process gas in ventilation ducts	Degradation of criticality safety margin (mass — accumulation of material)	(1)
	Measurement devices for activity in waste air	Release of radioactive material	(2)
	Emergency power supply system	Release of radioactive material (loss of dynamic confinement — ventilation system shutdown) Loss of instrumentation and control	(2) (2)
	Fire protection systems	Fire	(2)

^a If the quality assurance by the supplier and the MOX fuel fabrication facility is considered adequate, the measurements conducted on PuO₂ or MOX before their transfer to the facility may be sufficient.

ANNEX III
EXAMPLES OF PARAMETERS FOR DEFINING OPERATIONAL LIMITS AND
CONDITIONS FOR MOX FUEL FABRICATION FACILITIES

Safety function:

- (1) Criticality prevention;
- (2) Confinement of radioactive material;
- (3) Protection against external exposure.

Process area (including storage areas)	Safety function	Control parameter for operational limits and conditions
Area for receipt of PuO ₂ and MOX	(1)	Isotopic composition (fissile isotopes and minimum value of ²⁴⁰ Pu)
	(1)	Limited moderation (moisture)
	(1)	PuO ₂ content in MOX
	(2)	Specific heat of PuO ₂
	(2)	Total amount of plutonium allowed on the site
	(3)	Isotopic composition, for neutron and gamma exposure (americium, etc.)
Area for receipt of UO ₂	(1)	Enrichment in ²³⁵ U (if >1%, then criticality concern)
	(1)	Limited moderation
Intermediate storage of PuO ₂ powder	(1)	Mass per container
Intermediate storage of UO ₂ powder (only if ²³⁵ U >1%)	(1)	Total mass or mass per container
Powder preparation	(1)	Total mass of fissile material in each process unit to correspond with the criticality analysis
	(1)	Content of PuO ₂ in each process unit to correspond with the criticality analysis
	(1)	Limited moderation (moisture, additives)

Process area (including storage areas)	Safety function	Control parameter for operational limits and conditions
	(1)	Operational controls to ensure homogeneity of MOX mixture before pellet manufacture
	(3)	Content of americium in the MOX
	(2)	Surface contamination of radioactive sources
Pellet manufacture	(1)	Total mass of fissile material in each process unit to correspond with the criticality analysis
	(1)	Limited moderation (moisture)
	(1)	Size of pellets is within the limits of the criticality analysis
	(1)	For pellets received from other facilities, enrichment of uranium in the uranium pellets is within the limits of the criticality analysis
	(2)	Composition of atmosphere in sintering furnace (gas mixture)
	(2)	Temperature of sintering furnace
	(2)	Surface contamination of radioactive sources
Fuel rod manufacturing and fuel rod inspection	(1)	Total mass of fissile material or number of rods in each process unit or manual rod transport container, to correspond with the criticality analysis
	(1)	Limited moderation (moisture)
	(1)	Fissile length of fuel pellets in rods and diameter of rods are within limits of criticality analysis
	(1)	For rods received from other facilities, isotopic content, PuO ₂ content and enrichment of uranium in the uranium rods are within the limits of the criticality analysis
	(2), (3)	Surface contamination of rods
	(2)	Surface contamination of radioactive sources

Process area (including storage areas)	Safety function	Control parameter for operational limits and conditions
Fuel assembly manufacturing	(1)	Operational controls to ensure that the types of rods are correct and the rods are in the correct locations in the assembly
	(1)	Operational controls to ensure that all rods have been installed into the assembly
	(2)	Surface contamination of radioactive sources
MOX scrap recovery	(1)	Total mass of fissile material in each process unit to correspond with the criticality analysis
	(2)	Surface contamination of radioactive sources
Laboratory	(1)	Mass of plutonium
	(2)	Surface contamination of radioactive sources
Radioactive waste treatment	(1)	Mass of PuO ₂ in containers and maximum number of containers in storage
	(2)	Surface contamination of radioactive sources
Ventilation system	(2)	Stages of pressure in the building
	(2)	Efficiency of last stage filters
	(2)	Minimum number of exhaust fans that are operational at any given time
	(2), (3)	Limits on radiation levels in flow going out to the environment
	(2)	Maximum pressure differential across filters
Gloveboxes	(1)	Total mass of fissile materials in each process unit (which can comprise one or more gloveboxes) to correspond with the criticality analysis
	(2)	Overpressure and underpressure values
	(2)	Detection limits or alarm level for detecting room contamination caused by glovebox leakage

CONTRIBUTORS TO DRAFTING AND REVIEW

Bogdanova, T.	Federal Environmental, Industrial and Nuclear Supervision Service of Russia, Russian Federation
Gater, R.	International Atomic Energy Agency
Groche, K.	Consultant, Germany
Khotylev, V.	Canadian Nuclear Safety Commission, Canada
Kyriazidis, G.	Atomic Energy Commission, France
Lecarme, C.	Institute for Radiological Protection and Nuclear Safety, France
Michaelson, T.	International Atomic Energy Agency
Rovny, J.	International Atomic Energy Agency
Tiktinsky, D.	Nuclear Regulatory Commission, United States of America
Shokr, A.	International Atomic Energy Agency