		COMMENTS BY REVIEWER	RESOLUTION				
Reviewer:							
Country/Or	ganization: In	dia / Atomic Energy Regulatory Board D					
Comment No.	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/re jection
1	2.17/5 th line	To maintain the facility in a safe state, some systems should operate continuously or should be restarted within a defined delay period if they become unavailable, for example: (a) Active heat removal systems used in storage areas or buffer tanks, accountancy vessels or for high activity waste packages to remove decay heat; (b) Exhaust ventilation systems which ensure dynamic containment of radioactive material (c) Dilution (gas flow) systems used to prevent hazardous concentrations of hydrogen; (d) Safety significant instrumentation and control systems and utility supply systems.	Ensuring dynamic containment (exhaust ventilation) in all operational states of the reprocessing plant is necessary to maintain facility in a safe state.				

Safety of Reprocessing Facilities (DS 360)

Note: The bold text with red font in yellow background is the proposed new text.

COMMENTS BY REVIEWER				RESOLUTION				
Reviewer: Japan NUSSC Page 1 of								
Country/Organization : Japan/NRA			Date: 21/10/2015					
No.	Para/	Proposed new text	Reason	Accept	Accepted, but	Rejecte	Reason for	
	Line No.			ed	modified as follows	d	modification/rejection	
1	4.5 (e)/L5	All processes involving fissile material	All processes involving					
		should be designed in such a way as to	fissile material must be					
		prevent an accidental criticality;	designed so as to assure					
			preventing criticality					
			regardless of					
			"accidental" or not.					
2	4.9/L3	The safety requirements relating to	"Design basis external					
		design basis accidents and design basis -	events" is not described					
		external events are established in NS-R-5	in NS-R-5 (Rev.1), and					
		(Rev.1) [1], paras. 6.4–6.9.	then suggested to be					
			deleted.					

Comments on DS360 "Safety of Nuclear Fuel Reprocessing Facilities"