

Date: 2013-08-20

# IAEA SAFETY STANDARDS

for protecting people and the environment

Draft J

Step 11: For the second review by the review Committees.

Still to be technically edited by NS-SSCS.

## Design of Electrical Power Systems for Nuclear Power Plants

**DS430**

**DRAFT SAFETY GUIDE**

New Safety Guide

Supersedes NS-G-1.8

**IAEA**

International Atomic Energy Agency

DRAFT

DRAFT

## CONTENTS

<b>1. INTRODUCTION.....</b>	<b>1</b>
BACKGROUND .....	1
OBJECTIVE.....	2
SCOPE.....	2
STRUCTURE.....	3
<b>2. ELECTRICAL POWER SYSTEMS AT NUCLEAR POWER PLANTS .....</b>	<b>7</b>
DESCRIPTION OF AN ELECTRICAL POWER SYSTEM AT A NUCLEAR POWER PLANT .....	7
<i>Off-site power system .....</i>	<i>7</i>
<i>On-site power system.....</i>	<i>8</i>
<i>Preferred power supply.....</i>	<i>8</i>
ROLE OF CODES AND STANDARDS.....	9
DESIGN CONSIDERATIONS IMPOSED BY REQUIREMENTS FOR NUCLEAR SAFETY .....	9
DESIGN CONSIDERATIONS IMPOSED BY CRITERIA FOR ELECTRICAL DESIGN.....	11
<i>Power plant as a generating facility connected to the grid .....</i>	<i>11</i>
<i>Personnel and equipment safety.....</i>	<i>11</i>
<b>3. CLASSIFICATION OF ELECTRICAL POWER SYSTEMS.....</b>	<b>11</b>
<b>4. DESIGN BASES FOR ELECTRICAL POWER SYSTEMS .....</b>	<b>13</b>
<b>5. GENERAL DESIGN GUIDELINES FOR ELECTRICAL POWER SYSTEMS .....</b>	<b>17</b>
GENERAL.....	17
<i>Anticipated electrical events.....</i>	<i>17</i>
<i>Station blackout.....</i>	<i>18</i>
DESIGN FOR RELIABILITY.....	19
<i>General.....</i>	<i>19</i>
<i>Redundancy .....</i>	<i>20</i>
<i>Independence .....</i>	<i>20</i>
<i>Diversity.....</i>	<i>23</i>
<i>Common cause failures.....</i>	<i>24</i>
<i>Failure modes.....</i>	<i>25</i>
<i>Protection coordination.....</i>	<i>26</i>
<i>Reliability confirmation.....</i>	<i>27</i>
RATING.....	28
<i>Motor loads .....</i>	<i>28</i>
ELECTRICAL EQUIPMENT AND RACEWAYS.....	29
<i>General.....</i>	<i>29</i>
<i>Rating and sizing.....</i>	<i>29</i>
<i>Installation.....</i>	<i>30</i>
<i>Cable separation.....</i>	<i>30</i>
GROUNDING PRACTICES .....	31
<i>General.....</i>	<i>31</i>
<i>Electrical safety.....</i>	<i>32</i>
<i>Functionality .....</i>	<i>32</i>
LIGHTNING AND SURGE PROTECTION .....	32
EQUIPMENT QUALIFICATION .....	34
<i>General.....</i>	<i>34</i>

<i>Suitability and correctness</i> .....	35
<i>Environmental qualification</i> .....	35
<i>Internal and external hazards</i> .....	36
<i>Electromagnetic qualification</i> .....	37
DESIGN TO COPE WITH AGEING.....	39
CONTROL OF ACCESS .....	40
SURVEILLANCE TESTING AND TESTABILITY.....	41
<i>Test provisions</i> .....	41
<i>Test programme</i> .....	41
MAINTAINABILITY.....	43
PROVISIONS FOR REMOVAL FROM SERVICE FOR TESTING OR MAINTENANCE .....	44
SHARING OF STRUCTURES, SYSTEMS AND COMPONENTS IN MULTI-UNIT PLANTS.....	44
MARKING AND IDENTIFICATION.....	45
CONTAINMENT ELECTRICAL PENETRATIONS.....	45
DISTRIBUTION SYSTEMS.....	46
<i>Capability</i> .....	46
<i>Protective devices of the main and branch circuits and loads</i> .....	47
CONTROLS AND MONITORING .....	47
SAFETY RELATED STANDBY AC POWER SOURCES.....	49
<b>6. DESIGN GUIDELINES FOR PREFERRED POWER SUPPLIES .....</b>	<b>49</b>
GENERAL.....	49
RELIABILITY OF PROTECTION DEVICES AND HIGH VOLTAGE EQUIPMENT .....	50
OFF-SITE POWER SUPPLIES.....	50
AVAILABILITY .....	51
INDEPENDENCE .....	52
SWITCHYARD .....	52
GRID STABILITY AND RELIABILITY.....	53
INTERFACE AND INTERACTION BETWEEN TRANSMISSION SYSTEM OPERATOR AND NUCLEAR POWER PLANT OPERATOR.....	53
RELIABILITY ASSESSMENT OF GRID CONNECTIONS.....	55
<b>7. DESIGN GUIDELINES FOR ELECTRICAL SAFETY POWER SYSTEMS.....</b>	<b>55</b>
GENERAL.....	55
<i>Anticipated electrical events</i> .....	55
<i>Bus monitoring and switching</i> .....	56
DESIGN FOR RELIABILITY.....	57
<i>Single failure criterion</i> .....	57
<i>Completion of protective action</i> .....	59
SAFETY STANDBY AC POWER SOURCES.....	59
<i>General</i> .....	59
<i>Testing</i> .....	62
<i>Performance criteria (transient and dynamic)</i> .....	62
<i>Relay protection of standby power sources</i> .....	62
<i>Support systems for standby AC power sources</i> .....	63
<i>Fuel for standby AC power sources</i> .....	63
DC POWER SYSTEMS .....	63
<i>General</i> .....	63

<i>Battery</i> .....	63
<i>Battery charger</i> .....	64
<i>Uninterruptible AC power system</i> .....	66
<i>Protection of DC power systems and uninterruptible AC power system</i> .....	66
<b>8. ALTERNATE AC POWER SUPPLIES</b> .....	<b>67</b>
<b>9. DESIGN CONFIRMATION AND DOCUMENTATION</b> .....	<b>69</b>
MANAGEMENT SYSTEM.....	69
VERIFICATION.....	69
<i>Testing</i> .....	70
DESIGN DOCUMENTATION.....	70
<b>REFERENCES</b> .....	<b>74</b>
<b>ANNEX I. DEFENCE IN DEPTH IN ELECTRICAL POWER SYSTEMS</b> .....	<b>76</b>
FIRST LEVEL.....	76
<i>Design bases</i> .....	76
<i>On-site power systems</i> .....	78
SECOND LEVEL.....	79
<i>Fault clearing system and protection coordination</i> .....	79
<i>Power transfer capability</i> .....	79
<i>House load operation possibilities</i> .....	80
THIRD LEVEL .....	80
<i>On-site standby AC power supplies</i> .....	80
<i>Safety power systems</i> .....	81
FOURTH LEVEL .....	82
<i>Alternate AC power supply</i> .....	82
<b>ANNEX II. ELECTRICAL SYSTEM ANALYSES FOR DESIGN VERIFICATION</b> .....	<b>84</b>
LOAD FLOW STUDIES.....	84
SHORT CIRCUIT STUDIES .....	85
ELECTRICAL PROTECTION COORDINATION STUDIES .....	86
LOSS OF VOLTAGE AND DEGRADED VOLTAGE STUDIES.....	87
TRANSIENT STABILITY STUDIES.....	88
LIGHTNING PROTECTION AND SYSTEM GROUNDING STUDIES .....	89
ELECTROMAGNETIC COMPATIBILITY STUDIES .....	90
<b>DEFINITIONS</b> .....	<b>92</b>

# 1. INTRODUCTION

## BACKGROUND

1.1. This Safety Guide is issued in support of the Safety Requirements publication on Safety of Nuclear Power Plants: Design SSR-2/1, Ref. [1], which establishes design requirements for nuclear power plants.

1.2. This Safety Guide provides recommendations on the characteristics that nuclear plant Electrical Power systems, and the processes for developing these systems, should have in order to meet the Specific Safety Requirements SSR-2/1, Ref. [1]. It reflects changes that were made to SSR 2/1, requirement 68 as a result of Fukushima accident lessons learned.

1.3. This publication is a revision of a previous Safety Guide issued in 2004 as Safety Guide NS-G-1.8, Ref. [2], Emergency Power Systems at Nuclear Power Plants, and supersedes it. This revision takes into account the developments in the design of Emergency Power Systems in nuclear power plants and expands the scope to include all electrical power systems that provide power to systems Important to Safety (See Figs 1 and 2).

1.4. NS-G-1.8, Ref. [2] also included guidance on non-electrical systems that provided emergency power. Guidance for such systems is to be located in a new Safety Guide on auxiliary systems.

1.5. Electrical systems that supply power to systems important to safety are essential to the safety of nuclear power plants. These systems include both the on-site and off-site power supply systems. The on-site and off-site systems work together to provide necessary power, in all plant conditions, so that the plant can be maintained in a safe state. Off-site power systems are not plant equipment. They are, nevertheless, essential to the safety of a nuclear power plant and have an important role in the defence in depth concept.

1.6. The preferred power supply identified in this Safety Guide is the power supply from the transmission system, or main generator up to the safety classified electrical power system. It is composed of the transmission system, switchyard, main generator and distribution system up to safety classified electrical power system. The portions of the preferred power supply that are part of the off-site power system (e.g., transmission system) are not plant equipment and, therefore, are not part of the safety classification scheme (see Fig. 2). The location of the boundary between the off-site and on-site power supplies will be a plant specific decision.

1.7. It might not be practicable to apply all the requirements of this Safety Guide to nuclear power plants that are already in operation or under construction. For the safety analysis of such designs, it is expected that a comparison will be made with the current standards, for example as part of the periodic safety review for the plant, to determine whether the safe operation of the plant could be further enhanced by means of reasonably practicable safety improvements.

## OBJECTIVE

1.8. The objective of this Safety Guide is to give recommendations and guidance on meeting the requirements for the design of electrical power systems established in Requirements 41 and 68, paras 6.43–6.45, and the general requirements of Sections 2–5 of SSR-2/1, Ref. [1]. It is intended for the use by those involved in the design, operation, maintenance, modification, assessment, and licensing of nuclear plants, including designers, reviewers, safety assessors, regulators and operators. The Safety Guide does not provide details of implementation processes, methods used, or technology, except as explanation.

## SCOPE

1.9. The Safety Guide makes recommendations and provides guidance on the electrical power systems provisions necessary for both new and operating nuclear power plants. It applies to all electrical power systems important to safety in nuclear power plants and to the preferred power supply.

1.10. This Safety Guide applies to all types of nuclear power plants. The extent of the electrical power systems important to safety and of safety power systems, given by classification of the electrical systems, differs between different designs. The minimum design requirements for electrical systems necessary at different voltage levels, for maintaining defence in depth and diversity, are outlined in this Safety Guide. In all cases, this Safety Guide should be used together with the plant's Safety Analysis Report in order to determine the safety significance and importance of different power supplies. For example, in plants with passive engineered safety features, the classification of the electrical power systems may be substantially different than shown in Fig. 2.

1.11. Additional recommendations applicable to electronic devices used in the control and protection of the plant electrical power systems are given in the Safety Guide for I&C systems, DS431, Ref. [3].

1.12. Figures 1, 2 and 3 show examples of nuclear power plant electrical power systems to illustrate the scope of this Safety Guide and terminology used in this Safety Guide. Further explanation is found in the section on definitions and abbreviations.

1.13. This Safety Guide is focused on the electrical power systems. Guidance on the specification of loads is outside the scope, but it is necessary that such specifications align with the design guidelines for the power systems.

1.14. Electrical power for security systems (e.g., fences, surveillance systems, entrance control) is outside the scope of this Safety Guide.

1.15. This Safety Guide should be used in conjunction with the other relevant safety standards issued in the IAEA Safety Standards Series.

1.16. Additional guidance for the design and development of electrical power systems and equipment are available from Member States and standards development organizations. Their publications give



much greater detail than is appropriate for IAEA safety standards. It is expected that this Safety Guide will be used in conjunction with an appropriate set of more detailed industrial standards.

## STRUCTURE

1.17. Section 2 introduces the main systems of a typical plant electrical power system and describes the fundamental goals to be met by each system.

1.18. Section 3 describes the application of safety classification to electrical power systems.

1.19. Section 4 outlines the content that should be included in the design bases for electrical power systems.

1.20. Section 5 provides general recommendations that apply to all electrical power systems. These recommendations are the minimum recommendations for systems that are not covered in sections 6 thru 9. For systems that are covered in sections 6 thru 9 the recommendations of section 5 should be used in conjunction with the specific recommendations.

1.21. Section 6 provides recommendations for the preferred power supplies, which are the normal supplies for all plant systems important to safety and are, if available, always the first and best choice of all plant power supplies.


1.22. Section 7 provides recommendations that are specific to the design of safety power systems, including safety standby power supplies.

1.23. Section 8 provides recommendations that are specific to the design of alternate AC power supplies. This supplements the guidance of section 5 for these systems. Alternate AC power supplies are often provided to protect against the simultaneous failure of off-site and emergency on-site AC power supplies.

1.24. Section 9 provides recommendations for activities to confirm the adequacy of the electrical power system design and the system level documentation that should be provided both to support the safety case for the plant and to support operations, maintenance, testing, and verification.

1.25. Annex I discusses the relationship between the design of electrical power systems and the concept of defence in depth as given in SSR-2/1, Ref. [1].


1.26. Annex II gives an example of electrical system analyses for design verification of the nuclear plant.



Note This figure is only an example. Various arrangements of buses, loads, generators, and interconnections will meet the requirements of SSR 2/1. Furthermore, many elements of the plant system, such as buses that are not important to safety, and DC power systems are not shown.

Dotted lines indicate not important to safety power supply.

*FIG. 1. Relationship of the plant power system, the off-site power system and the on-site power system.*



**Note** This figure is only an example. Various arrangements of buses, loads, generators, and interconnections will meet the requirements of SSR 2/1. Furthermore, many elements of the plant system, such as buses that are not important to safety, and DC power systems are not shown.

This figure is intended only to represent the relationship between the elements of the plant power systems that are within the safety classification scheme and the Preferred Power Supply. The elements of the Preferred Power Supply that are not within the bounds of the Important to safety Power Supply are outside of the scope of the plant safety classification.

The system elements included in the important to safety power supplies will differ according to plant design and the classification methods applied in the different Member States.

Some plant designs do not require safety standby power sources. All nuclear power plants are expected to have safety DC power supplies.

Dotted lines indicate not important to safety power supply.

**FIG. 2. Relationship of power supplies important to safety, safety power supplies, and the preferred power supply.**




FIG. 3. Schematic representation of the different parts of the plant power supplies discussed in this Safety Guide, with their boundaries. (Typical for one train.)

## 2. ELECTRICAL POWER SYSTEMS AT NUCLEAR POWER PLANTS

### DESCRIPTION OF AN ELECTRICAL POWER SYSTEM AT A NUCLEAR POWER PLANT

2.1. Figures 1, 2, and 3 show examples of the outline of a nuclear power plant's electrical power system. The design of a specific plant's electrical power system will depend upon the grid, the design of plant systems, and engineering design decisions that are beyond the scope of this Safety Guide. Therefore, Figs. 1, 2, and 3 are not to be taken as a recommended design for any specific plant.

2.2. The safety power system can be supplied by either the preferred power supplies or the standby power sources. Alternate alternating current (AAC) power supplies can also supply the safety power systems in design extension conditions.

2.3. This Safety Guide discusses three major subsystems of the plant power system: the on-site power system, the off-site power system, and the preferred power system. The paragraphs below explain these terms as they are used in this Safety Guide. The use of these terms in a specific plant will depend upon details of the plant design and may differ from the use in this Safety Guide.

#### **Off-site power system**

2.4. The off-site power system is composed of the transmission system (grid) and switchyard connecting the plant with the grid. The off-site power system will ideally provide AC power to the plant during all modes of operation and in all plant states. It also provides transmission lines for outgoing power. (See Fig. 1.) The boundary between on-site and off-site power systems is at the point where the items controlled by the transmission system operator connect to equipment controlled by the nuclear power plant operator. The boundary is often at the bushings on the grid side of the transformer that connects to the transmission voltage, or on the grid side of the high voltage breaker closest to the plant.

2.5. The off-site power system performs an important role in terms of safety in order to supply the onsite power systems with reliable power from multiple power sources: (1) Main generator via auxiliary transformers (2) Grid power supply via the standby transformers. The off-site power system is part of the preferred power supply (see Fig.2).

2.6. An intrinsically robust grid system provides a highly reliable off-site power supply as it rapidly dampens the effects of grid perturbations during normal conditions and minimizes the voltage and frequency deviations in the connected nuclear plant electrical system. Similarly, large nuclear units with fast turbine governor and generator excitation systems can impart considerable robustness to a grid system. Because of this interdependency, good design functional integration and good operational co-ordination between the grid and nuclear operators during major operating changes on either the grid or at the nuclear plant are important requirements for safe and reliable operation of both.

## **On-site power system**

2.7. The on-site power system (See Fig. 1) is composed of distribution systems and power supplies within the plant. It includes the AC and DC power supplies necessary to bring the plant to a controlled state following anticipated operational occurrences or accident conditions and to maintain it in a controlled state, or safe state, until off-site supplies can be restored. Stand-alone power supplies, such as separate power for security systems, are not included. The on-site power systems are separated according to their safety significance: important to safety (safety systems, safety related systems) and systems not important to safety (See Fig. 2).

2.8. The major components of the on-site power system include the main generator, generator step up transformer, auxiliary transformer, standby transformer and the distribution system feeding unit auxiliaries, service auxiliaries, switchgear, batteries, rectifiers, inverters/uninterruptible power supplies, cables and standby AC power sources. Portions of the on-site power system are part of the preferred power supply.

2.9. The on-site electrical power systems are generally divided into three types of electrical systems according to the different power requirements of the loads:

- An alternating current (AC) power system. The functions of the assigned AC loads will tolerate a certain interruption in the power supply. Usually the AC power system includes a standby AC power sources and an Alternate (dedicated) AC power source. Protective relays detect loss of the preferred AC power supply to the electrical power systems and automatically start a standby electrical power sources. In most cases the plant safety analyses assume that the standby AC power source will be used for plant shutdown following design basis accidents, and the alternate AC source for Design Extension Conditions (DEC).
- A direct current (DC) power system. This supplies DC loads, without interruption, from batteries. The DC system includes battery chargers that are connected to the AC system of the electrical power systems. Sometimes separate DC power systems are provided to support loads of different safety classification.
- A uninterruptible AC power system which supplies power from inverters or motorgenerator sets that are in turn supplied from a DC source such as the DC power system or dedicated batteries with rectifiers, and include a bypass circuit to allow feeding safety loads directly from safety class AC power systems.

## **Preferred power supply**

2.10. The preferred power supplies are the normal supplies for all plant systems important to safety. They are, if available, always the first and best choice of power supply to the safety electrical power systems. The preferred power supply includes portions of both the on-site and off-site systems (See Fig. 2).

## ROLE OF CODES AND STANDARDS

2.11. SSR-2/1 Requirement 9 states that:

“Items important to safety for a nuclear power plant shall be designed in accordance with the relevant national and international codes and standards.”

2.12. The off-site power system should satisfy the nuclear safety criteria established in national and international standards, the grid code and electrical design criteria (as imposed by national electrical codes).

2.13. The plant electrical system should be designed and constructed in accordance with national and international nuclear standards and national safety codes to ensure a high level of reliability and availability during all modes of plant operation.

2.14. National safety codes provide guidance on acceptable design requirements for safe and reliable operation of electrical systems. Compliance with these safety codes generally provides reasonable assurance for the capability of the electrical power systems in the nuclear power plant.

## DESIGN CONSIDERATIONS IMPOSED BY REQUIREMENTS FOR NUCLEAR SAFETY

2.15. The electrical power systems and components at a nuclear power plant supply electrical power to the plant’s auxiliary systems from off-site and on-site power supplies.

2.16. The off-site power and off-site system for a nuclear power plant should be robust, and highly reliable in all plant states and operating conditions. The design of the on-site power system should take into consideration the limitations of off-site power system and its impact on nuclear safety.

2.17. A stable and reliable grid (with reliable production units and transmission and distribution systems) is fundamental to the safety of the nuclear power plant.

2.18. Grid disturbances can challenge nuclear safety when the nuclear power plant acts as a:

- Production unit,
- Consumer during startup and shutdown, or
- High priority emergency load during certain events and operational occurrences.

2.19. Robust systems should have sufficient margins and built in conservatisms such that equipment ratings, capabilities and capacities required to meet intended goals are not easily challenged; equipment protection set points chosen to accommodate anticipated variations in operation of on-site and off-site power systems; the ability to support emergency operations involving sustained overload or overvoltage conditions, and protective actions that are initiated, when necessary to preserve the functionality of the safety power systems.

2.20. The electrical power systems, at all voltage levels, are support systems for many plant equipment. A reliable power supply is critical for maintaining control during anticipated deviations

from normal operation, as well as to power, control and monitor relevant plant safety functions during design basis accidents and design extension conditions.

2.21. During shutdown parts of the nuclear power plant power supply systems may be out of service for testing or maintenance. The challenges to the robustness, reliability, and availability of the electrical power system when the plant is shutdown will differ from those that must be addressed during power operation.

2.22. SSR-2/1 requirement 4 and paragraph 4.1 states that:

“Fulfilment of the following fundamental safety functions shall be ensured for all plant states: (i) control of reactivity; (ii) removal of heat from the reactor and from the fuel store; and (iii) confinement of radioactive material, shielding against radiation and control of planned radioactive releases, as well as limitation of accidental radioactive releases.

“A systematic approach shall be taken to identifying those items important to safety that are necessary to fulfil the fundamental safety functions, and to identifying the inherent features that are contributing to fulfilling, or that are affecting, the fundamental safety functions for all plant states.”

2.23. A systematic approach should be followed to identify the electrical power systems, structures and components necessary in order that items necessary to fulfil the fundamental safety functions can be powered from electrical supplies with appropriate safety classification and reliability.

2.24. Reliability means that the proper implementation of the design, testing, operation and maintenance, provide assurance that electrical systems can perform their mission with a minimum of disturbances.

2.25. A number of measures can be taken on and off site to achieve the required reliability of the electrical power supplies. Such measures may involve increasing the reliability of the plant's normal power supply (the preferred power supply), or providing other sources of power to the electrical power systems when the normal power supply might not be available. This may also include the use of dedicated power sources for safety systems of special importance.

2.26. Elements in a defence against common cause failure are good understanding of events that could challenge the electrical systems and a robust defence against these challenges, clearly defined design bases that are regularly confirmed and a suitable diversity of the power supplies.

2.27. The interface between the safety systems and systems of lower safety classification should be carefully designed to ensure that there is no adverse impact on safety equipment from non-safety equipment as a result of disturbances in the plant electrical systems.



## DESIGN CONSIDERATIONS IMPOSED BY CRITERIA FOR ELECTRICAL DESIGN

2.28. SSR-2/1 requirement 41 states that:

“The functionality of items important to safety at the nuclear power plant shall not be compromised by disturbances in the electrical power grid, including anticipated variations in the voltage and frequency of the grid supply.”

2.29. Design should consider transient and quasi-stationary variations of voltage and frequency that affect the electrical systems and components of the nuclear power plant.

2.30. The protection scheme of the plant and the design of the plant's components should be such that disturbances in the preferred power supply do not jeopardize the required operation of safety power systems and connected loads.

2.31. During emergency activation, equipment protection may be reduced to the essential set in order to give priority to the safety action.

### **Power plant as a generating facility connected to the grid**

2.32. In accordance with national legislation, national grid codes or bilateral agreements between each transmission system operator and each power generating facility, a power generating facility should be designed in such a way that it supports highly reliable grid system operation.

2.33. High grid reliability is important for safe and reliable electrical power supply in a nuclear power plant. The transmission system operator has the responsibility to ensure reliable electrical power supply to the nuclear power plant as well as the responsibility for transmitting its power to the electrical distribution operators.

2.34. Grid codes should recognize the specific features and design requirements of nuclear power plants.

### **Personnel and equipment safety**

2.35. Electrical power systems should be designed to minimize personnel risk and equipment damage due to high temperatures, arc flash or mechanical stress caused by rated current, overcurrent, or any internal mechanical stresses to the equipment.

2.36. Electrical systems should be designed and erected in such a way that they can withstand voltages that can be expected to occur in any plant state or operating mode.

## **3. CLASSIFICATION OF ELECTRICAL POWER SYSTEMS**

3.1. SSR 2/1 Requirements 18 states:

The engineering design rules for items important to safety at a nuclear facility shall be specified and shall comply with the relevant national or international codes and standards and

with proven engineering practices, with due account taken of their relevance to nuclear power technology.

3.2. SSR 2/1 Requirement 22 states:

All items important to safety shall be identified and shall be classified on the basis of their function and their safety significance.

3.3. SSR 2/1 paragraph 5.34 states:

The method for classifying the safety significance of items important to safety shall be based primarily on deterministic methods complemented, where appropriate, by probabilistic methods, with due account taken of factors such as:

- (a) The safety function(s) to be performed by the item;
- (b) The consequences of failure to perform a safety function;
- (c) The frequency with which the item will be called upon to perform a safety function;
- (d) The time following a postulated initiating event at which, or the period for which, the item will be called upon to perform a safety function.

3.4. SSR 2/1 paragraph 5.36 states:

Equipment that performs multiple functions shall be classified in a safety class that is consistent with the most important function performed by the equipment.

3.5. The draft Safety Guide DS 367 Safety Classification of Structures, Systems and components in Nuclear Power Plants, Ref. [4] provides recommendations and guidance on how to meet the requirements established in Refs. [1] and [5] for the identification of SSCs important to safety and for their classification on the basis of their function and safety significance.

3.6. The safety classification process recommended in Ref. [4] is consistent with the concept of defence in depth set out in Ref. [1]. The functions performed at the different levels of defence in depth are considered.

3.7. For a specific nuclear facility, the classification process should primarily consider:

- The design basis of the plant and its inherent safety features;
- The list of all postulated initiating events, as required in Ref. [1], Requirement 16. The frequency of occurrence of the postulated initiating events, as considered in the design basis of the facility, should be taken into account.

3.8. The possibility that the failure or spurious operation of an item important to safety may directly cause a PIE or make the consequences of a PIE worse should be considered when the list of PIE is established.

3.9. All Electrical system functions and design provisions necessary to achieve the main safety functions, as defined in Ref. [1], Requirement 4, for the different plant states, including all modes of normal operation, should be identified.

3.10. The Electrical system functions should then be categorized on the basis of their safety significance, using a constant risk approach, with account taken of the three following factors:

1. The consequences of failure to perform the function;
2. The frequency of occurrence of the postulated initiating event for which the function will be called upon;
3. The time following a postulated initiating event at which, or the period of time during which, the function will be required to be performed.

3.11. The Electrical systems and components performing each function assigned in a safety category should be identified and classified. They should be primarily classified according to the category assigned to the function that they perform.

3.12. Off-site power systems and main generator systems also have an essential role in ensuring performance of fundamental safety functions, but are not classified according to the plant safety classification scheme.

3.13. When assigning the safety classification, the timeliness and reliability with which alternative actions can be taken and the timeliness and reliability with which any failure in the Electrical system can be detected and remedied should be considered.

3.14. In the Safety Guide DS 367, three safety categories for functions and three safety classes for SSCs are recommended, based on the experience of the Member States. However, a larger or smaller number of categories and classes may be used if desired.

#### **4. DESIGN BASES FOR ELECTRICAL POWER SYSTEMS**

4.1. SSR-2/1 Requirement 14 and paragraph 5.3 states that:

“The design basis for items important to safety shall specify the necessary capability, reliability and functionality for the relevant plant operational states, for accident conditions and for conditions generated by internal and external hazards, to meet the specified acceptance criteria over the lifetime of the nuclear power plant.

“The design basis for each item important to safety shall be systematically justified and documented. The documentation shall provide the necessary information for the operating organization to operate the plant safely.”

4.2. Requirements 15 to 19 of SSR-2/1, Ref. [1] elaborate on specific topics to be considered in the development of system design bases.

- 4.3. Design basis should be specified for each electrical system in the nuclear power plant.
- 4.4. The design bases should specify the required functional tasks, the necessary characteristics, the performance objectives, the operating and environmental conditions, and the necessary reliability.
- 4.5. For each electrical power supply system in the plant the voltage and frequency range for continuous operation of connected loads should be defined.
- 4.6. The permissible transient and quasi-stationary voltage and frequency range for continued operation of connected loads should be defined for each electrical power supply system in the plant.
- 4.7. Transients to be considered include internal events and external events including grid events that are described in paragraph 5.4.
- 4.8. The design bases should cover all modes of operation and take into account all possible events that could impact the electrical system in the nuclear power plant, including:.
- a. Symmetrical and asymmetrical faults,
  - b. Sub-synchronous resonance phenomena,
  - c. Large motor starts,
  - d. Momentary perturbations in the grid system such as switching surges or lightning strikes,
  - e. Capacitor bank switching,
  - f. Loss of transmission system elements, including single phase open conditions, and
  - g. Formation of grid islands and resulting frequency and voltage excursions.
- 4.9. The design bases should be confirmed when major replacements and major modifications of the electrical power system (on-site or off-site) as well as changes in loading are implemented and a cumulative evaluation performed periodically, e.g., as part of periodic safety reviews.
- 4.10. The design basis should describe for each subsystem of the plant power systems:
- a. The plant operational states in which the system is required.  
These include plant operation from startup to maximum licensed power with maximum auxiliary loading, plant shutdown from full power, and safe shutdown following a trip and a design basis accident.
  - b. Voltage and frequency range for continuous operation;  
This range defines the operating requirements for equipment such as motors, pumps, inverters, battery chargers and valve actuators.
  - c. Capacity requirements;  
The equipment credited in the accident analyses normally defines capacity. Capacity, from an electrical point, includes for instance simultaneous start or reacceleration of components.

- d. Steady state, short term operation and transient conditions to which the systems might be subjected when they are required to perform;

Steady state conditions include, for example:

- Voltage ranges and frequency variation for heavy and light load conditions, for all plant states, and for house load operation where applicable
- Deviating grid voltage or frequency
- Float and charging voltage for DC systems

Transient conditions include, for example:

- Switching surges
- Lightning surges
- Voltage interruptions caused by electrical faults off-site and on-site
- Voltage sags and swell in conjunction with loss of load, motor starts, and clearing of faults on the on-site electrical system or the off-site grid
- Voltage and frequency variations and transients when the grid (and main generator) are affected by faults
- Harmonics due to switching surges or rotating equipment
- Faults in the transmission system or on-site power system (all voltage levels) cleared by first step or backup protection
- Events involving loss of synchronism between the plant and the grid
- Fault or open condition in a single phase
- Main generator excitation malfunctions (high and low excitation)
- Open conductors
- Solar activity and geomagnetic induced currents.

- e. Variables, such as system voltage, system current and frequency, of the main bus bars should be monitored;

This includes variables necessary for accident and post-accident monitoring.

- f. Actuation conditions for operating standby electrical power sources;

This includes variables that are used to initiate required actions.

- g. Environmental and electromagnetic conditions to which components and cables will be subjected;

Environmental conditions include:

- Normal conditions,
  - Abnormal conditions,
  - Accident conditions,
  - Natural phenomena,
- h. Identification of all loads indicating safety classification and electrical characteristics;  
This includes motor input power at run-out when applicable.
- i. Required performance characteristics of all components;
- j. Requirements for maintaining and testing;  
Including test acceptance criteria.
- k. Protective schemes and coordination of protection;  
Protective schemes are to consider both symmetrical and asymmetrical faults. Refer to Annex II for details.
- l. Design acceptance criteria;  
Design acceptance criteria include, for example:
- Standards to be used or considered, and
  - Requirements for design characteristics (e.g., independence characteristics, compliance with single failure criteria, and diversity requirements.)
- m. Reliability and availability goals for systems and key components;  
For example, the reliability of the standby power supplies.  
  
System and component reliability and unavailability limits may be specified using probabilistic criteria, deterministic criteria (e.g., compliance with single failure criterion), or both.
- n. Voltage, speed, time to start and load, and other limits applicable to standby power supplies and their prime movers.
- o. The maximum time for standby power supplies to start and accept loading in a specified load sequence.  
  
The equipment credited in the accident analyses normally defines permissible starting time.
- p. The required performance characteristics of standby power supplies, including the capability for no load, light load, rated load, starting load as well as, in certain member states, overload operation for the required time periods.
- q. The capability for step loading of the standby power supplies over the entire load range;  
  
The step load capability specifies the conditions of voltage and frequency that the standby power supply has to maintain in order not to degrade the performance of any load below its

minimum requirements, even during excursions caused by the addition or removal of the largest load.

- r. Conditions that should be permitted to shut down or disconnect safety power sources.  
For example, the need to protect equipment from catastrophic failures.
- s. The minimum time for which on-site power is to be capable of operating independently of off-site power and without replenishing consumable items from off-site.  
This will be considered, for example, in setting the required capacity of batteries, emergency generator fuel and lubricating oil storage, and the required storage of other consumables such as air filters.
- t. The variables, or combination of variables, to be monitored;
- u. The control functions required, and identification if actions are to be performed automatically, manually, or both, together with the location for the controls.

## **5. GENERAL DESIGN GUIDELINES FOR ELECTRICAL POWER SYSTEMS**

### **GENERAL**

5.1. Electrical systems important to safety should fully implement the requirements of their design bases.

### **Anticipated electrical events**

5.2. The nuclear power plant electrical power systems should meet all functional requirements under steady state, short term operation and transient conditions defined by the design basis.

5.3. Events can cause symmetrical and asymmetrical perturbations in the plant and can be initiated:

- In the transmission system with the plant on line, off line and shutdown, or as a consequence of the plant separating from the grid due to anticipated faults or voltage and frequency variations beyond an acceptable level.
- By the main generator tripping leaving the on-site power systems connected to the off-site or on-site power systems.
- In the on-site power systems as a result of an electrical event such as motor starting, phase to ground fault or switching surges.

5.4. The impact of such events on all the on-site electrical power systems (AC and DC) (see Fig. 5) should be evaluated and confirmed by specific analysis that the allowable voltage and frequency requirements are not exceeded and the protection system is adequate.

5.5. The grid transient system stability analyses should demonstrate that the plant could ride through and remain connected to the grid for perturbations that do not result in the generator losing synchronism with the transmission system voltage.

5.6. The electrical fault clearing time should be defined by the grid operator.

5.7. This desired defence in depth capability supports the preferred power supply operation.




FIG. 4. Relationship between the preferred power supply and other elements of the electrical power system.

### Station blackout

5.8. International operational experience has shown that loss of the preferred power supply concurrent with a turbine trip and unavailability of the emergency AC power system is a credible event. Such an event may affect a single unit, and even all units on one site. Such an event is called station blackout and its frequency of occurrence should be low enough to be considered and analysed as a DEC event.



The term station blackout does not include the simultaneous failure of uninterruptible AC power supplies or DC power sources, or the failure of alternate AC power sources that are diverse in design and not susceptible to the events that caused the loss of on-site and off-site power sources.

5.9. The plant's capability to maintain fundamental safety functions and to remove decay heat from spent fuel should be analysed for the period that the plant is in a blackout condition and adequate provisions should be included in the design to prevent any significant fuel damage for the period that the plant is in a blackout condition.

5.10. Several design measures are possible as a means of increasing the capability of the electrical power systems to cope with a station blackout. These measures include, for example, increasing the capacity of batteries to supply power to safety instrumentation and control equipment, and to other vital equipment, use of unit to unit connections, or installing an alternate AC power source that is diverse in design and protected from elements that can degrade the normal and standby power sources.




FIG. 5. Voltage swell and sag (note that initial conditions could be anywhere within the continuous band).

## DESIGN FOR RELIABILITY

### General

5.11. SSR-2/1 Requirement 23 states that:

“The reliability of items important to safety shall be commensurate with their safety significance.”

5.12. In the design of electrical systems important to safety, design features such as redundancy, diversity, tolerance of random failure, independence of equipment and systems, tolerance of common cause failures, testability and maintainability, fail-safe design, and selection of high quality equipment, are typically used to provide the specified reliability of safety functions.

### **Redundancy**

5.13. Electrical systems important to safety should be redundant to the degree necessary to meet design basis reliability requirements.

5.14. Redundancy is commonly used in electrical power systems important to safety to achieve system reliability goals or conformity with the single failure criterion. For redundancy to be fully effective, independence is also necessary. Taken alone, redundancy increases the reliability of safety actions, but it also increases the probability of spurious operation.

5.15. Operating experience indicates that additional redundancy within a train or division provides operational flexibility and increased availability.

### **Independence**

5.16. SSR-2/1 Requirement 24 states that:

“The design of equipment shall take due account of the potential for common cause failures of items important to safety, to determine how the concepts of diversity, redundancy, physical separation and functional independence have to be applied to achieve the necessary reliability.”

5.17. SSR-2/1 Requirement 21 states that:

“Interference between safety systems or between redundant elements of a system shall be prevented by means such as physical separation, electrical isolation, functional independence and independence of communication (data transfer), as appropriate.”

5.18. SSR-2/1 Paragraph 5.35 states that:

“The design shall be such as to ensure that any interference between items important to safety will be prevented, and in particular that any failure of items important to safety in a system classified in a lower safety class will not propagate to a system classified in a higher safety class.”

5.19. Independence is provided to prevent a failure or internal or external hazard from affecting redundant elements of safety systems. It also prevents a failure or hazard from affecting systems that provide different levels of defence in depth. Failure processes to be considered include: failures resulting from design basis events, exposure to the same internal or external hazards, failure of common support systems, electrical connections between systems or divisions, data exchange between systems or divisions, or common errors in design, manufacture, operations, or maintenance.

5.20. Safety items should be independent of the effects of the accidents to which they respond.

5.21. Safety systems should be independent from systems of lower safety classification as necessary to ensure that the safety systems can perform their safety functions during and following any event that requires these functions.

5.22. Redundant portions of safety groups should be independent from each other to ensure that the safety group can perform its safety functions during and following any event that requires these functions.

5.23. Failure of one part of the electrical power systems, structures and components should not render other parts inoperable when they are required to function.

5.24. The functional failure of the support features of safety systems should not compromise the independence between redundant portions of safety systems or between safety systems and systems of lower safety classification.

5.25. For example, assigning a safety system support feature such as room ventilation to the same division as the safety system it supports prevents the loss of mechanical function in one division causing a loss of electrical system function in another division.

5.26. When isolation devices are used between systems of different safety importance, they should be a part of the system of higher importance.

5.27. The adequacy of design features provided to meet the independence requirements should be justified.

#### *Physical separation*

5.28. Physical separation:

- Protects against common cause failure due to the effects of internal hazards. Internal hazards of concern include: water hazard protection from direct and indirect sources of water, such as spray and seepage through roofs, walls, raceways, and conduits, fire, missiles, steam jets, pipe whip, chemical explosions, flooding, and failure of adjacent equipment.
- May be used to protect against common cause failure due to normal, abnormal, or accident environments, the effects of design basis accidents, or the effects of internal and external hazards. Environmental, seismic, and electromagnetic qualification may also be used by themselves, or in conjunction with physical separation, to protect against the effects of accidents, internal hazards, or external hazards.
- Might reduce the likelihood of common cause failures as a result of events that have localized effects (e.g., small aircraft impact).

- Reduces the likelihood of inadvertent errors during operation or maintenance on redundant equipment.

5.29. Physical separation is achieved by barriers, distance or a combination of the two.

5.30. NS-G-1.7, Ref [5] and NS-G-1.11, Ref. [6] give guidance on protection against fires and other internal hazards.

5.31. Some areas that might present difficulties due to convergence of equipment or wiring are:

- Containment penetrations,
- Motor control centres,
- Switchgear areas,
- Cable spreading rooms,
- Equipment rooms,
- The main and other control rooms, and
- The plant process computer.

#### *Electrical isolation*

5.32. Electrical isolation is used to prevent electrical failures in one system from affecting connected systems. Electrical isolation controls or prevents adverse interactions between equipment and components caused by factors such as electromagnetic interference, electrostatic pickup, short circuits, open circuits, grounding, or application of the maximum credible voltage (AC or DC).

5.33. As far as reasonable practicable, non-safety loads should not be powered by safety electrical power systems.

5.34. If it is necessary to power non-safety loads from the safety electrical power systems they should be considered isolated by safety classified isolation devices.

5.35. An example of a preferred isolation device is a circuit breaker that is automatically tripped by an accident signal or loss of voltage signal generated within the same safety division as the isolation device.

5.36. Redundant divisions of safety classified electrical power systems should not be interconnected.

5.37. Temporary connections between redundant divisions may be made during operation if a safety assessment confirms the reliability of a power supply is increased significantly and sufficient independence of the redundant divisions is ensured.

5.38. Temporary connections between redundant divisions may be made during shutdown after a safety assessment confirms the following:

- The interconnections have interlocks that cannot be defeated by simple switch operation; and
- The effect of these connections on the reliability of plant safety functions and their vulnerability to common cause failure is acceptable.

5.39. These interconnections could also be used in station blackout conditions.

5.40. Examples of provisions for electrical isolation include circuit breakers, relays, electronic isolating devices, optical isolating devices (including optical fibre), cable or component shielding, separation distance, internal mechanical structures, or combinations of them.

5.41. Qualification for electromagnetic compatibility complements electrical isolation by protecting against electromagnetic interference and electrostatic pickup.

#### *Associated circuits*

5.42. When it is impractical to provide adequate physical separation and isolation from electrical faults between a safety circuit and a circuit of a lower class function, the lower class circuit (associated circuit) should be:

- Analysed or tested to demonstrate that the association does not unacceptably degrade the safety class circuits with which it is associated,
- Identified as part of the safety division with which it is associated, and
- Physically separated from other components in the same manner as the circuits of the safety division with which it is associated.

#### **Diversity**

5.43. Safety power systems should be supplied from diverse power supplies.

5.44. Diversity in power sources is usually inherent in the architectural design of the power system.

5.45. Typically safety power system loads can be supplied from:

- The off-site power system, via the preferred power supply;
- The main generator, which is the normal power source and in-house load scenarios will supply power;
- The standby power source, which will supply the safety power systems on loss of off-site power; or
- Alternate AC power source during station blackout conditions.

5.46. DC loads can be supplied from batteries or (via rectifiers) from any of the above sources.

5.47. Uninterruptible AC power system loads can be supplied from batteries or battery chargers (via inverters) or from safety system AC buses using bypass switches.

5.48. Where the design basis requires diversity for software based devices of an electrical power system, the guidance of DS-431, Ref. [3] should be followed.

5.49. Diversity of power supply sources for specific loads, e.g., I&C systems, might often improve the availability of the overall system.

5.50. If non-electrical systems are provided as a diverse means of accomplishing a given safety function, any of their associated power supplies, instrumentation and control systems, should be independent of the system to which they are intended to be diverse.

5.51. This recommendation applies to multiple non-electrical systems that are diverse as well as non-electrical power systems that are provided for diversity from electrical power systems (such as steam or engine driven pumps).

5.52. In addition to physical separation and electrical isolation, diversity might be necessary to increase independence between redundant systems or between systems supporting different levels of the defence in depth concept. This may be achieved by the use of dedicated power sources or by supply from uninterruptible power supplies.

#### **Common cause failures**

5.53. SSR-2/1 Requirement 24 states that:

“The design of equipment shall take due account of the potential for common cause failures of items important to safety, to determine how the concepts of diversity, redundancy, physical separation and functional independence have to be applied to achieve the necessary reliability.”

5.54. The possibility of common cause failures, which could render the safety power systems unavailable to perform their safety functions when called upon, should be considered in the design, maintenance, testing and operation of the safety power systems and their support systems.

5.55. The principles of diversity and independence (physical separation and functional isolation) should be applied to protect against credible common cause failures originating either within the equipment of the safety system itself, switching surges or voltage/frequency excursions from connected systems or from human involvement (e.g. in operations and maintenance).

5.56. The use of principles of independence and diversity helps to ensure, but does not fully guarantee, that common cause failures will not be the primary cause to system unavailability.

5.57. As the nuclear power plant is normally connected to only one transmission system, one event on the grid could influence redundant parts of the safety power systems. If the nuclear power plant has two turbines and two generators, the common cause failure possibilities will decrease. If the redundant safety power systems are fed from independent connections to the grid the common cause failure possibilities will also decrease.

5.58. Operating experience of events related to voltage transients, both on off-site and on-site power supplies, has demonstrated the need for increased attention to the design of the electrical power systems in order to minimize the risk for common cause failures. A ‘no interruption’ concept is desirable, realized as a series of design means to minimize the impact from transients (see Fig. 5).

5.59. Due to the voltage, frequency and phase angle excursions that can occur in a generating facility, operating experience from industrial applications is of limited value when screening for common cause failure vulnerability from the preferred power supply.

5.60. The primary protections against common cause failures originating from the grid are:

- Comprehensive design bases and guidelines that identify all possible events that could challenge the safety power systems;
- Verified capability of the safety power systems to cope with these events, either by built in features or by relay protection; and
- Verified capability not to transmit voltage and frequency excursions to buses fed from rectifiers and inverters.

5.61. After an event that ends in a loss of off-site power and if the safety power systems is not fed from the main generator(s), the standby power sources will start and supply the safety power systems. Even if the safety power systems are divided into different divisions, the starting sequence of the standby power sources has a potential for common cause failure as the same physical properties are used to initiate all divisions.

5.62. The primary protection against common cause failures for the standby power sources is:

- Comprehensive design bases and guidelines that identify all possible events that could challenge the standby power sources control, start and operation;
- Verified capability of the standby power sources to cope with these events, either by built in features or by relay protection. This also includes the transient performance during loading of the standby power sources; and
- Proper redundancy of control circuits and equipment to ensure reliability in starting, endurance in operation and prevent unnecessary tripping.

5.63. In order to minimize common cause failure risks for software based devices, appropriate design principles for I&C equipment given in DS-431, Ref. [3] should be used.

## **Failure modes**

5.64. SSR-2/1 Requirement 26 states that:

“The concept of fail-safe design shall be incorporated, as appropriate, into the design of systems and components important to safety.”

5.65. The failure modes of electrical components important to safety should be known and documented.

5.66. Knowledge of component failure modes is necessary in order to apply the fail-safe concept.

5.67. Failures of electrical components important to safety should be detectable by periodic testing or revealed by alarm or anomalous indication.

5.68. It is preferred that failures be self-revealing except when such a design might result in an unsafe state or cause a spurious actuation of safety systems.

### **Protection coordination**

5.69. The electrical protection scheme should prevent failures from disabling safety functions to below an acceptable level.

5.70. The protective actions of each load group should be independent of the protective actions provided by a redundant load group.

5.71. Protective relays should be used for the prompt removal from service of any element of a power system when abnormal conditions occur such that operating equipment might degrade or fail.

5.72. Selective tripping of breakers should be used to minimize the impact of fault conditions.

5.73. The protection scheme should be capable of the following:

- a. Operating the required devices upon detection of unacceptable conditions to reduce the severity and extent of electrical system disturbances, equipment damage, and potential personnel and property hazards;
- b. Monitoring the connected preferred power supply with provisions to automatically or manually initiate transfer to alternative supply;

The alternative supplies in this case may be different off-site supplies or standby AC power supplies. Fast bus transfers using state of the art technology and adequate interlocks with protective schemes can reduce stresses on operating equipment.

- c. Providing indication and identification of the protective operations;
- d. Monitoring the availability of protection control power; and
- e. Ensuring that only faulted equipment is disconnected from the power source with minimum impact on operating equipment.

5.74. A protection scheme that disconnects only faulted equipment will include the following characteristics.

- In case of short-circuit and overload situations, protection devices are designed to operate selectively in all planned connection circumstances of the electrical power systems.
- Protective devices are designed to initiate the breaker clearing fault currents rapidly enough to avoid hazards and to minimize disturbances.



- The plant's switchgear are provided with reliable arc protection, or other appropriate protection, to minimize switchgear damage caused by potential arc faults and to protect the safety of the plant and its operating and maintenance personnel.
- Individual protection devices installed to protect components during testing are listed and designed such that their operation does not endanger a system's capability to operate during an actual event.

5.75. The protection scheme should take into consideration reacceleration currents after voltage sags and interruptions or bus transfer.

5.76. The design of protection devices should consider both symmetrical and asymmetrical faults.

5.77. Faults to be considered include all possible types of series and shunt faults, including events like loss of a phase and ground faults in systems not connected to ground. Protection coordination also includes measuring principles.

5.78. Provision of means to capture transients during events is desirable in order to support verification of performed analysis and protection coordination.

5.79 Digital protection devices should be verified for use in accordance with the safety duty they are intended to provide.

5.80. The design of the protection devices of electrical power systems and components of nuclear power plants should also comply with national standards that apply to the safety of electrical equipment and electrical installations, as well as other relevant electrical regulations.

#### **Reliability confirmation.**

5.81. For all systems important to safety a systematic assessment should be conducted to confirm that the design achieves the reliability requirements of system design bases.

5.82. This demonstration may be based on a balance of application of deterministic criteria and quantitative reliability analysis that considers design features such as, for example, redundancy, testability, failure modes, and rigor of qualification.

5.83. The use of software or complex multi-element logic modules might create difficulty in justification of reliability and sensitivity to common cause failures. The reliability confirmation may therefore depend on assurances of freedom from error in the design and implementation process. DS-431, Ref. [3] guide provides further discussion and guidance on this topic.

5.84. Test facilities that are part of the safety system should be considered when determining system availability.

## RATING

5.85. All equipment used in the electrical systems in the plant should have sufficient margin in operating parameters when compared to their nominal rating.

5.86. Analyses and simulations to confirm the design margins should be performed, using conservative assumptions and qualified methods.

5.87. The adequacy of the margin in equipment rating should be confirmed regularly; at least in conjunction with major component replacements, plant modifications, and periodic safety reviews.

5.88. Electrical equipment should be specified with adequate design margin to ensure that future plant upgrades and modifications can be implemented without exceeding equipment rating.

## Motor loads

### *General*

5.89. Motors for items important to safety should be designed with pull-out torque high enough to permit starting with minimum allowable design voltage, as defined by the design bases of the electrical system.

5.90. Motors and other devices for items important to safety connected to the power system should withstand the over- and undervoltage as well as the over- and under frequency that could result from the applicable steady state, short term operation and transient conditions that are specified in the design basis.

5.91. The loads used for motor rating and design of components in safety power systems as well as settings for overload protective devices should consider the actual motor loads and, where applicable run-out torque.

5.92. Valve actuators should be designed in order to close with enough torque at low voltage and frequency, not exceed maximum permissible torque at high voltage and frequency, and be able to open the valve at low voltage.

5.93. Protection devices for motor drive actuators should be coordinated with torque switch settings to avoid nuisance trips during operation.

### *Design for overload operation*

5.94. Electrical equipment and cables, should be designed to permit necessary overload operation without exceeding their rating.

5.95. It might be necessary in some situations to operate the equipment for a short time period in overload. Typically this might occur when large pumps start with minimum backpressure resulting in operation under run-out conditions. For example, the set points of circuit protective devices may be set higher than the levels that protect the equipment from damage due to continuous overloads.

5.96. Cables should be protected against overload in accordance with their continuous current carrying capability.

5.97. Where operation of overloaded equipment is permitted, such operation should not adversely affect other circuits or associated equipment.

5.98. The continued operation of safety system equipment under overloaded conditions with the consequent risk of its damage should not be credited in the safety justification for operation under accident conditions.

5.99. Sustained loading above continuous rating should be indicated in the control room.

5.100. If circuit protective devices are set at a higher level, an undetected overload could remain in the system under normal operating conditions, thus possibly accelerating the failure of the equipment necessary in the particular situation.

## **ELECTRICAL EQUIPMENT AND RACEWAYS**

### **General**

5.101. Electrical equipment is defined here as switchgear, motor control centres, transformers and cable systems.

5.102. Electrical equipment should be selected, rated, and qualified for their service and environmental conditions.

5.103. Electrical equipment should be sufficiently fire retardant to prevent the propagation of fires.

5.104. Aspects of fire protection are considered in NS-G-1.7, Ref. [5].

### **Rating and sizing**

5.105. Electrical equipment should have a voltage rating greater than (typically 110% of) the nominal system voltage and an impulse rating greater than any transient voltage to which the equipment might be subjected.

5.106. Electrical equipment should be sized:

- a. To carry safely the currents of the main circuits and branch circuits required under voltage variations;
- b. To meet the demands of the loads without exceeding rated temperature;
- c. To withstand short circuits (e.g. fault current during the specified fault clearing time); and
- d. To withstand peak currents without exceeding mechanical strength.

5.107. Factors to be considered in calculation of conductor temperatures include:

- Maximum environmental temperatures;
- Normal and fault currents;

- Load factors;
- The arrangements of other cables in the same or nearby raceways; and
- The influence of cable supports, wall penetrations, floor penetrations, fire stops and fire retardant coatings on cable heating.

## **Installation**

5.108. Buses, raceway (i.e., tray or conduit), and their supports should be designed to withstand, with an appropriate margin, the mechanical loads, imposed by the cables and their associated fittings.

5.109. Safety system buses, cubicles, and cables should be adequately protected against the hazards that might result from postulated initiating events.

5.110. Hazards that could affect buses, cubicles and cables include: the effects of fire, and the failure or malfunction of fluid systems and mechanical or structural components.

5.111. Generally the design ensures that cables, that are part of safety systems, are routed or protected so that neither fire nor failure of mechanical equipment can affect more than is justified in the safety analysis report (normally one division of any safety group). Failure of mechanical equipment includes the possible effects of pipe whip, jet impingement, and the generation of missiles as a result of the failure of rotating equipment or other high energy systems. Recommendations and guidance on protection against the failure of mechanical equipment are provided in NS-G-1.11, Ref. [6].

5.112. Raceways and cables should be permanently identified with their respective divisions.

5.113. Common practice is to permanently identify raceways and cables at each end and at regular intervals (except for cables in closed raceways). Raceway identification also normally includes cable voltage class.

5.114. Each cable, on installation, should be given adequate identification to ensure its installation in the proper raceway.

5.115. In general, the use of cable splices should be prohibited in raceway.

5.116. Cable splices may be used for connections between field cables and equipment provided that they are qualified for the service. Such termination techniques may be necessary for safety cables and equipment in containment to protect against high leakage currents that might be caused by exposure to environments created by accident conditions.

## **Cable separation**

5.117. Physical separation by use of appropriate methods (e.g. distance or physical barrier) should be provided between:

- a. Cables classified as safety and cables without safety classification;
- b. Cables belonging to different safety divisions; and

- c. Cables of different voltage classes.

5.118. Separation by safety classification is intended to avoid damage to safety classified cables as a result of failures in lower classified systems or cables. Separation between cables of different safety divisions is intended to prevent a single hazard from affecting more than one redundancy in a safety system. Separation by voltage classes is intended to prevent electromagnetic interference expected in higher energy circuits from unacceptably affecting lower energy circuits.

5.119. Physical separation should be provided between cables in the following voltage classes:

- a. Instrumentation and control cables;
- b. Low voltage power cables (1 kV or less);
- c. Medium voltage power cables (35 kV or less); and
- d. High voltage power cables (greater than 35 kV)

5.120. High voltage power cables are not commonly used in on-site power systems.

5.121. Only cables of the same voltage class should be placed in the same raceway (i.e. ladder, tray or conduit).

5.122. Cables and raceway of different voltage classes should be separated according to class by means of either spatial separation or barriers that prevent one class from having a detrimental effect on the other.

5.123. Grounded metallic conduit represents an acceptable separation barrier.

## GROUNDING PRACTICES

### General

5.124. Grounding serves both to assure electrical safety and electrical power system and I&C functionality. Detailed design guidelines for grounding are available in national and international standards.

5.125. In any generating station there are generally four conceptually identifiable, but not necessarily physically distinct, grounding systems: personnel safety, lightning, electrical power system and I&C system including signal grounding.

5.126. All grounding systems should be connected to a single grounding grid.

5.127. The ground resistance value should take into consideration:

- a. Fault current capacity of equipment, and
- b. Personnel safety; i.e., the allowable step and touch voltage with assumed lightning discharge or fault current to the ground.

5.128. International standards describe a number of solutions for I&C grounding. Typically, generating stations use one of two approaches for I&C grounding: single point grounding or multiple point grounding. The selected solution is design specific.

5.129. The grounding approach used should be justified and coordinated with the overall electromagnetic compatibility design provisions.

### **Electrical safety**

5.130. Overall grounding should be designed installed and maintained to effectively protect people, buildings and equipment as well as electrical power and I&C systems against damage.

5.131. The metallic frames of all equipment and apparatus should be connected to ground, except when the connection will interfere with the functionality.

5.132. If frames are not connected to ground, additional provisions for assuring personnel safety should be made.

5.133. In the design of the grounding systems, electrical systems should be considered one entity, since inadequate grounding of even one part of the system might affect the entire system.

### **Functionality**

5.134. Medium voltage AC electrical power systems should preferably be high impedance grounded.

5.135. High impedance grounding limits fault current and allows continued operation of the affected equipment.

5.136. Other grounding solutions such as solid grounded or insulated system may be used when justified.

5.137. In high impedance grounded systems, the electrical system should be monitored for ground faults at every voltage level and allow easy identification of the failure location.

5.138. Detection of low impedance to ground should alarm only and allow the equipment to perform its function.

5.139. Protective schemes may trip equipment on multiple faults.

### **LIGHTNING AND SURGE PROTECTION**

5.140. Provision should be made that a lightning strike will not prevent the power and I&C systems from fulfilling their required safety function.

5.141. The systems for achieving this may rely on external or internal protection. Typically a combination of both methods will be necessary.

5.142. External provisions will normally include either lightning conductors or a Faraday cage comprising the metal parts of the building that shield the building and its equipment from the effects

of a lightning strike. Internal provisions could include specific electromagnetic shielding for rooms in order to create a protected environment for electromagnetic hazards.

5.143. Internal lightning protection will normally include shielding and surge arresters to protect against both the induced high voltage caused by the lightning current and the high transferred voltage caused by voltage differences between the ground and parts of the external lightning protection system and the associated grounding connections.

5.144. To protect the safety power system from induced voltages, safety classified raceways and cables should not be located close to the outer walls of buildings.

5.145. External lightning protection should be grounded in order to conduct the lightning current to ground outside the building.

5.146. The internal protection grounding should be connected to the rest of the lightning grounding in such a way it prevents high transferred potentials from injuring personnel or damaging equipment.

5.147. Connections of lightning protection systems to ground should be routed so that the effects of lightning discharges do not jeopardize either the safety functions of safety power systems or the lightning protection grounding.

5.148. The plant grounding may be supplemented by specific ground connections.

5.149. Structures that are not an inherent part of the plant, such as warehouses, offices and workshops for maintenance and support staff should generally not be supplied from plant power distribution systems.

5.150. If plant buses are used to supply power to ancillary buildings, adequate measures should be taken to ensure that electrical noise and voltage perturbations generated by equipment in these buildings does not adversely impact the plant power systems.

5.151. Power systems for control and monitoring should not be distributed outside a plant in order to minimize the risk for disturbances due to induction or other influence.

5.152. Connections to other buildings, with adequate protection against induced voltages and ground potential rise caused by lightning, such as grounded steel walls, can be justified if the cable route is protected in a similar way.

5.153. Voltage surge suppressors or arresters should be provided to prevent surges from exceeding the allowable voltage limits set for equipment or its insulation.

5.154. Overvoltage surges can be caused by lightning strikes, electrical faults, or switching phenomena. Suppressors might be necessary on various voltage levels.

5.155. Switching operations, rectifiers, inverters and rotating equipment can generate harmonics and electrical noise that may be detrimental to equipment designed to operate at nominal frequency and

voltage. Additional equipment to filter or suppress unwanted electrical noise may be necessary for reliable operation of equipment sensitive to electrical noise in the power system.

## EQUIPMENT QUALIFICATION

### General

5.156. SSR-2/1 Requirement 30 states that:

“A qualification programme for items important to safety shall be implemented to verify that items important to safety at a nuclear power plant are capable of performing their intended functions when necessary, and in the prevailing environmental conditions, throughout their design life, with due account taken of plant conditions during maintenance and testing.”

5.157. Electrical systems and components important to safety should be qualified for their intended function during their service life.

5.158. The qualification should provide confidence commensurate with the system or component safety classification.

5.159. The qualification programme(s) should address all topics affecting the suitability of the system or component for its intended functions important to safety, including:

- a. Suitability and correctness of functions and performance,
- b. Environmental qualification of components,
- c. Seismic qualification of components, and
- d. Electromagnetic qualification.

5.160. Qualification should be based upon an appropriate combination of methods, including for example:

- a. Use of engineering and manufacturing processes in compliance with recognized standards;
- b. Reliability demonstration;
- c. Past experience in similar applications;
- d. Type testing;
- e. Testing of supplied equipment; or
- f. Analysis to extrapolate test results or operating experience under pertinent conditions.

5.161. It is generally not necessary to apply all of the methods mentioned. The specific combination of methods will depend upon the system or component under consideration. For example, the qualification of pre-existing items might place more emphasis on past experience and analysis to compensate for a lack of completely documented verification and validation during engineering and manufacturing.

5.162. The method, or combination of methods used for equipment qualification should be justified.



5.163. Where operating experience is used to support equipment qualification, it should be shown to be relevant to the proposed use and environment of the target application.

5.164. Analysis that is part of the evidence of equipment qualification should include a justification of the methods, theories and assumptions used.

5.165. For example, the validity of the mathematical models used for equipment qualification may be justified on the basis of experimental data, test data, or operating experience.

5.166. Traceability should be established between each installed system and component important to safety and the applicable evidence of qualification.

5.167. This includes traceability not only to the component itself, but traceability between the qualified configuration and the installed configuration.

### **Suitability and correctness**

5.168. The equipment qualification programme should demonstrate that the design of electrical systems, structures, components and software meet all capability, capacity, and reliability requirements important to safety contained in the applicable design bases and equipment specifications.

5.169. Examples of reliability requirements include, for example, requirements for fail-safe behaviour, conformance with the single failure criterion, independence, failure detection, maintainability, and service life.

5.170. The equipment qualification programme should demonstrate that the as-built electrical power systems and installed components correctly implement the qualified design.

### **Environmental qualification**

5.171. In this Safety Guide environmental qualification is qualification for temperature, pressure, humidity, chemical exposure, radiation, meteorological conditions, submergence, and ageing mechanisms that might affect the proper functioning of components under those conditions.

5.172. Systems, structures and components important to safety should be designed to accommodate the effects of, and be compatible with, the environmental conditions associated with all plant states in which they are required to function.

5.173. Components important to safety should be shown to meet all design basis requirements when subjected to the range of environmental conditions specified in the design basis.

5.174. A component might have a safety function even when full operability is not required, for example, to maintain mechanical integrity, or to not fail in certain modes.

#### *Components exposed only to mild environments*

5.175. Environmental qualification of electrical power system components important to safety whose environmental service conditions during accidents are at no time significantly more severe than conditions during normal operations (mild environments) may be based upon supplier certification that the components are suitable for the specified operating conditions.

#### *Components exposed to harsh environments*

5.176. Environmental qualification of safety classified electrical power system components whose environmental service conditions during accidents are at any time significantly more severe than the conditions during normal operations (harsh environments) should show that the component is, at the end of its qualified life, capable of performing its safety functions under the full range of specified service conditions.

5.177. Showing that components can function as required at their end of life involves addressing significant ageing effects (e.g., radiation and thermal ageing) to show that required functionality is maintained at the end of qualified life. Normally, this includes providing further conservatism, where appropriate, to allow for unanticipated ageing mechanisms.

5.178. In defining the equipment qualification programme, the worst credible combinations of environmental service conditions, including synergistic effects between service conditions, should be addressed.

5.179. If it is necessary to separately test for different environmental conditions (e.g., separate tests for radiation and temperature effects) the sequence in which these tests are conducted should be justified as one that appropriately simulates the degradation caused by the combined environments.

5.180. The most rigorous environmental qualification methods may be applied only to safety components.

5.181. Environmental qualification of safety components that are expected to operate in harsh environments should include type testing.

5.182. When protective barriers are provided to isolate equipment from possible environmental effects, the barriers themselves should be subject to a qualification programme to validate their adequacy.

#### **Internal and external hazards**

5.183. The plant design basis and the plant's safety analysis will identify internal and external hazards, such as fire, flooding and seismic events, which the plant is required to tolerate for operation or which the plant is required to withstand safely, and for which protection or system qualification is necessary.

5.184. Electrical power systems and components should be protected against the effects of fire and explosion in accordance with the guidance of NS-G-1.7, Ref. [5].

5.185. Electrical power systems and components should be protected against the effects of other internal hazards in accordance with the guidance of NS-G-1.11 Ref. [6].

5.186. Electrical power systems and components should be designed and qualified to withstand seismic hazards in accordance with the guidance of NS-G-1.6, Ref. [7].

5.187. Electrical power systems and components should be protected against or designed and qualified to withstand other external hazards in accordance with the guidance of NS-G-1.5, Ref. [8].

### **Electromagnetic qualification**

5.188. The undisturbed operation of electrical and electronic systems and components depends upon the electromagnetic compatibility of components with their operating environment, i.e. a component's capability to withstand more disturbances than caused by the components around it or connected to it.

5.189. Equipment and systems important to safety, including associated cables, should be designed and installed to withstand the electromagnetic environment in which they are located.

5.190. Significant sources of electromagnetic interference include, for example, fault current clearance by switchgear or circuit breaker or fuse operation, electric fields caused by radio transmitters, natural sources such as lightning strike, and other human made sources internal or external to the plant.

5.191. Electromagnetic qualification of electrical power systems and components depends upon a combination of system and component design to minimize the coupling of electromagnetic noise to electrical components, testing to demonstrate that components can withstand the expected levels, and testing to demonstrate that electromagnetic emissions are within tolerable levels.

5.192. Techniques for minimizing the production and coupling of electromagnetic noise include:

- Suppression of electromagnetic noise at the source;
- Separation and isolation of instrument and control signal cables from power cables;
- Shielding of equipment and cables from external magnetic and electromagnetic sources;
- Filtering noise before it can couple to sensitive electronic circuits;
- Neutralization or isolation of electronic equipment from ground potential differences; and
- Proper grounding of electrical equipment, raceway, cabinets, components, and cable shields.

5.193. Detailed electromagnetic compatibility requirements should be determined for all electrical systems and components and their compliance with the requirements demonstrated.

5.194. Appropriate installation and maintenance practices should ensure the proper implementation and continued effectiveness of these provisions.

5.195. International electromagnetic compatibility standards for industrial environments may serve as the basis for the requirements provided that they are supplemented, where necessary, to cover the

electromagnetic compatibility environments of generating power plant components, which might be more demanding. Determining the electromagnetic compatibility requirements includes considering the exposure of components to possible repetitive (e.g. switching off of inductive loads and ringing of relays) and high energy surges (e.g. power faults and lightning).

5.196. Establishing the electromagnetic compatibility environment of electrical systems and components at each nuclear power plant unit involves unit specific analyses based on which the adequacy of each electrical component's electromagnetic compatibility requirements is evaluated.

5.197. The types of electromagnetic interference, to be considered in the design of electrical systems and components include:

- Emission of and immunity to radiated electromagnetic disturbances;
- Emission and conduction of electromagnetic disturbances via cables;
- Electrostatic discharge;
- Switching transients and surges;
- The emission characteristics of wireless systems and devices used at the plant as well as those of repair, maintenance and measuring devices. Wireless systems and devices include, for example, mobile phones, radio transceivers, and wireless data communication networks.

Wireless systems and devices include, for example, mobile phones, radio transceivers, and wireless data communication networks.

5.198. In the vicinity of certain sensitive equipment it may be necessary to establish exclusions zones where operation of wireless devices and other portable electromagnetic interference sources (e.g., welders) is not permitted.

5.199. Limits on radiated and conducted electromagnetic emissions should be established for all plant equipment.

5.200. Any electrical or electronic equipment in the plant will contribute to the electromagnetic environment. Therefore, the need to apply limits to electromagnetic emissions applies to all plant equipment, not just equipment important to safety.

5.201. Emission limits placed on individual components should be below the electromagnetic interference operating envelope by an amount that is sufficient to ensure that no single item makes a significant contribution to the electromagnetic interference hazard.

5.202. The equipment qualification programme should show that electromagnetic emissions of all plant equipment are within the defined limits.

5.203. Equipment and systems, including associated cables, should be designed and installed to appropriately limit the propagation (both by radiation and conduction) of electromagnetic interference among plant equipment.

5.204. Instrumentation cables should have twisting and shielding sufficient to minimize interference from electromagnetic and electrostatic interference.

5.205. DS-431, Ref. [3] gives additional recommendations for electromagnetic compatibility of the electronic elements of the electrical power system.

#### DESIGN TO COPE WITH AGEING

5.206. SSR-2/1 Requirement 31 states that:

“The design life of items important to safety at a nuclear power plant shall be determined. Appropriate margins shall be provided in the design to take due account of relevant mechanisms of ageing, neutron embrittlement and wear out and of the potential for age related degradation, to ensure the capability of items important to safety to perform their necessary safety functions throughout their design life.”

5.207. SSR-2/1 Paragraph 5.51 states that:

“The design for a nuclear power plant shall take due account of ageing and wear out effects in all operational states for which a component is credited, including testing, maintenance, maintenance outages, plant states during a postulated initiating event and plant states following a postulated initiating event.”

5.208. SSR-2/1 Paragraph 5.52 states that:

“Provision shall be made for monitoring, testing, sampling and inspection to assess ageing mechanisms predicted at the design stage and to help to identify unanticipated behaviour of the plant or degradation that might occur in service.”

5.209. SSR-2-1 requirement 31 and paragraphs 5.51 and 5.52 are aimed at ensuring that ageing effects will not impair the ability of safety components to function under severe environmental conditions. Such degradation might exist well before the functional capabilities under normal conditions are noticeably affected.

5.210. Ageing mechanisms that could significantly affect electrical components, and means for following the effects of these mechanisms, should be identified during design.

5.211. Identification of potential ageing impacts involves initially understanding of the relevant ageing phenomena, which forms part of the design process.

5.212. Ageing is most commonly due to heat, and radiation exposure, but other phenomena (e.g., mechanical vibration or chemical degradation) might be important ageing mechanisms for certain components.

5.213. Maintenance, surveillance, and ageing management programmes should include activities to identify any trend towards degradation (ageing) that could cause the equipment to become incapable of performing its safety function.

5.214. Examples of monitoring techniques include:

- Testing of plant components or components subject to ageing representative of plant components;
- Visual inspections; and
- Analysis of operating experience.

5.215. Examples of means to address ageing impacts include:

- Component replacement before the end of its qualified life;
- Adjustment of functional characteristic to account for ageing effects; and
- Changes to maintenance procedures or environmental conditions that have the effect of slowing the ageing process.

5.216. The qualified life of safety components that must perform their safety function in harsh environments should be determined.

5.217. Safety classified components should be replaced before the end of their qualified life.

5.218. Ongoing qualification might show that the qualified life of a component is validated or is indicated to be different than the expected lifetime. Information from ongoing qualification may be used to increase or decrease the qualified life of a component.

5.219. NS-G-2.12, Ref. [9] gives additional guidance on ageing management including the interface between equipment qualification and the ageing management programme.

## CONTROL OF ACCESS

5.220. SSR-2/1 Requirement 39 states that:

“Unauthorized access to, or unauthorized interference with, items important to safety, including computer hardware and software, shall be prevented.”

5.221. Access to equipment in systems important to safety should be limited to prevent unauthorized access and to reduce the possibility of error.

5.222. Effective methods include appropriate combinations of physical security, e.g., locked enclosures, locked rooms, alarms on enclosure doors, and administrative measures.

5.223. Areas of particular concern are access to set-point adjustments and calibration adjustments, because of their importance in preventing degraded system performance due to potential errors in operation or maintenance.

5.224. IAEA Nuclear Security Series No. 4, Ref. [10], and No. 13, Ref. [11] give guidance on security for nuclear power plants and the coordination of nuclear safety and nuclear security.

5.225. DS-431, Ref. [3], gives additional recommendations for access control and security of computer based applications used in electrical power systems.

## **SURVEILLANCE TESTING AND TESTABILITY**

### **Test provisions**

5.226. All systems important to safety should include provisions for testing, including built-in test capabilities where appropriate.

5.227. Design of test provisions must be coordinated with the design of the operational test programme in order that availability requirements of the systems and components are fulfilled. This includes establishing test frequencies that take into consideration failure rates of components. It is envisaged that certain tests could only be performed during refuelling outages.

5.228. Arrangements for testing include procedures, test equipment interfaces, installed test equipment, and built in test facilities.

5.229. Testing and calibration of safety system equipment should be possible in all modes of normal operations, including power operation, while retaining the capability of the safety systems to accomplish their safety functions.

5.230. Periodic tests during plant operation will normally be necessary to achieve the reliability required of safety systems; however it is sometimes desirable to avoid conducting tests during operation if they put at risk safe plant operation.

5.231. The capability for testing and calibration during power operation is not necessary if doing so would adversely affect the safety or operability of the plant.

5.232. If means are not provided for testing safety equipment during power operation the following should be provided:

- a. Justification that the reliability of the functions affected is acceptable, and
- b. The capability for testing during shutdown.

### **Test programme**

5.233. The design of systems important to safety should include identification of a testing programme that supports implementation of the guidance given in NS-G-2.2, Ref. [12]; NS-G-2.4, Ref. [13], NS G 2.6, Ref. [14]; and NS-G-2.14, Ref. [15].

5.234. A test programme will normally include:

- A description of programme objectives;
- Identification of systems and components to be tested;
- A master test schedule;
- Bases and justification for the tests to be conducted and test intervals;
- Acceptance criteria;
- A description of required documentation and reports;
- Periodic review of programme effectiveness;
- The individual test procedures that will be used to control the conduct of tests.

5.235. The scope and frequency of testing should be justified as consistent with functional and availability requirements.

5.236. Implementation of the test programme should provide:

- a. Objective information on system or component status;
- b. Assessment of component degradation;
- c. Data on trends to assist in detecting degradation;
- d. Indications of incipient failure within the system; and
- e. Requirements for evaluations that must be conducted before repetition of the failed test can be credited as establishing operability.

Implementation of this recommendation involves evaluating and documenting the reasons for, root causes of, and actions taken after a failed test before the results of a repeated test can be used to demonstrate operability of the system or component involved.

Corrective actions may, for example, include maintenance or repair of components, or changes to test procedures.

If corrective actions are determined to be unnecessary the reasons are to be documented.

5.237. Evaluation and documentation of the root causes of a failed test, and remedial actions taken, are necessary before the results of a repeated test can be used to demonstrate operability of the systems or component involved. Corrective actions may, for example, include calibration or repair of components, or changes to test procedures.

5.238. The test programme for electronic components of electrical power systems, including electronic protective devices, should also meet applicable parts of guidance in Ref. [3].

5.239. The test programme should define processes for periodic tests that: Ensure the safety of the plant during the actual testing;



- a. Neither compromise the independence of safety systems nor introduce the potential for common cause failure;
- b. Should not cause deterioration of any plant component beyond that provided for in the design;  
For example, the operability or reliability of diesel engines might be degraded by operation under no-load conditions or frequent rapid starts.
- c. Order tests into a sequence such that the overall condition of the systems or components can be immediately assessed;
- d. Confirm that design basis functional and performance requirements are met;
- e. Include acceptance criteria;
- f. Test all inputs and output functions important to safety, such as alarms, indicators, control actions, and operation of actuation devices;
- g. Minimize the possibility of spurious initiation of any safety action and any other adverse effect of the tests on the availability of the plant;
- h. Minimize the time interval during which equipment is removed from service;
- i. Wherever possible, be accomplished under actual, or simulated, operating conditions present when the system is called upon;
- j. Require post-test verification that any items that were disturbed for periodic testing have been properly returned to their original operating state; and
- k. Forbid the use of makeshift test set-ups, temporary jumpers, or temporary modification of computer code or data in plant components.

Test equipment may be temporarily connected to equipment important to safety if the equipment to be tested has facilities specifically designed for the connection of this test equipment.

## MAINTAINABILITY

5.240. The design of electrical systems should include maintenance plans for all systems and components.

5.241. Electrical power systems important to safety should be designed and located to make surveillance and maintenance simple, to permit timely access and, in the case of failure or error, to allow easy diagnosis and repair and minimize risks to maintenance personnel.

5.242. Design to facilitate maintenance, troubleshooting, and repair includes:

- Avoiding locating equipment in areas where conditions of extreme temperature or humidity are normal.
- Avoiding locating equipment in areas where there is a risk of high radiation levels.
- Design that takes account of human capabilities and limitations in performing the required maintenance activities.

- Leaving sufficient room around the equipment to ensure that the maintenance staff can perform their tasks under normal working conditions.

5.243. Means provided for the maintenance of electrical power systems important to safety should be so designed that any effects on the safety of the plant are acceptable.

#### PROVISIONS FOR REMOVAL FROM SERVICE FOR TESTING OR MAINTENANCE

5.244. Provisions for removing electrical equipment from service should ensure the equipment is properly isolated in order to protect the safety of personnel and to avoid spurious operation.

5.245. If use of a facility for testing or maintenance can impair a function, the interfaces should be subject to hardware interlocking to ensure that interaction with the test or maintenance system is not possible without deliberate manual intervention.

5.246. There should be a design solution in place to assure evidence that system is ready for operation.

5.247. Removal from service of any single safety system component should not result in loss of the required minimum redundancy unless the acceptably reliable operation of the system can be adequately demonstrated.

5.248. Safety systems designs that comply with the recommendation of paragraph 5.247 will include provisions to allow periodic tests of part of a safety system while the parts remaining in service can perform the required safety task.

5.249. Inoperability or bypass of safety system components should be indicated in the control room.

5.250. For items that are frequently bypassed or frequently rendered inoperable, these indications should be automatic.

5.251. NS-G-2.6, Ref. [14] provides guidance for returning systems and equipment to service after testing and maintenance.

#### SHARING OF STRUCTURES, SYSTEMS AND COMPONENTS IN MULTI-UNIT PLANTS

5.252. SSR-2/1 Requirement 33 states that:

“Safety systems shall not be shared between multiple units unless this contributes to enhanced safety.”

5.253. Each unit in a multi-unit power plant should have separate and independent power systems important to safety.

5.254. Electrical power systems or components important to safety should not be shared between reactor units unless it can be shown that such sharing will not significantly impair their ability to perform their safety functions, including a simultaneous accident in all shared units.

5.255. Any demonstration that sharing of systems or components between units does not increase the likelihood or consequences of an accident should consider potential common cause failures and the possibility that one or more units are shut down while maintenance is performed on common parts of shared systems.

5.256. In applying the single failure criterion to units with shared systems the analysis should show the following conditions are met regarding the units sharing systems or components:

- a. The safety systems of all units can perform their required safety functions assuming a single failure in the shared systems or components or in the supporting features or other systems with which the shared systems interface; and
- b. The safety systems of each unit can perform their required safety functions, with concurrent single failures in the non-shared systems of each unit.

5.257. It is not necessary to show that conditions a) and b) can be simultaneously met.

#### MARKING AND IDENTIFICATION

5.258. SSR-2/1 Paragraph 5.33 states that:

“Safety system equipment (including cables and raceways) shall be readily identifiable in the plant for each redundant element of a safety system.”

5.259. A consistent and coherent method of naming and identifying all electric power components should be determined and followed throughout the design, installation and operation phases of the plant.

5.260. Such identification should not require frequent reference to drawings, manuals, or other material.

5.261. The components of different safety divisions should be easily distinguishable from each other and from components of lower safety classification.

5.262. Identification may, for example, take the form of tagging or colour coding.

5.263. Coherent and easily understood naming and identification of systems and components reduces the likelihood of operating, maintaining, testing, modifying, repairing, or calibrating an item other than the one intended.

5.264. Components or modules mounted in equipment or assemblies that are clearly identified do not themselves need identification. Configuration management is generally sufficient for maintaining the identification of such components, modules and embedded computer software.

#### CONTAINMENT ELECTRICAL PENETRATIONS

5.265. Electrical penetrations are elements of accomplishing the containment safety function and should always be safety classified.

5.266. Structural integrity functions include the ability to withstand rated and fault currents without the penetration leak rate exceeding requirements. The safety classification of a penetration's electrical functions that do not affect structural integrity will follow the safety classification of the in-containment items that depend upon the penetration. .

5.267. An electrical penetration assembly should be considered as part of the cable system between the load and the primary interrupting device.

5.268. Containment penetrations should be rated:

- a. For continuous service at a voltage that is greater than or equal to the voltage of the systems of which the conductors are a part;
- b. For impulse voltages that are greater than or equal to the maximum credible transient voltage;
- c. To continuously carry demands from loads expected during all plant states without exceeding allowable conductor temperatures or degrading the assembly pressure boundaries;
- d. To safely carry short circuits over the period of time required for the protective device to clear fault currents, accounting for credible voltage variations; and
- e. To withstand, without loss of mechanical integrity, the maximum possible overcurrent condition that could occur following a single random failure of devices protecting against circuit overload.

5.269. The setting of the protection devices should consider the continuous current ratings and capabilities of the electrical penetrations.

5.270. Conductors in containment penetrations should be protected by redundant safety protective devices that operate separate interrupting devices.

5.271. A single passive protective device (e.g. a fuse) may be used if analysis of compliance with the single failure criteria shows with high confidence that a failure of that passive protective device is very unlikely and its function remains unaffected by the postulated initiating event.

5.272. A containment penetration that can indefinitely withstand the maximum current available due to a fault inside the containment does not need redundant protection.

5.273. The penetrations should meet the same separation criteria as the cables to which they are connected.

## DISTRIBUTION SYSTEMS

### Capability

5.274. Each distribution system should have sufficient capacity and capability to:

- a. Supply the required loads under all required operating conditions;
- b. Withstand the maximum credible overcurrent under electrical fault conditions;
- c. Withstand transient conditions without damage to, or adverse effects on, any of its components; and

- d. Switch power supplies and loads as demanded.

#### **Protective devices of the main and branch circuits and loads**

5.275. All main and branch circuits should be protected against overloads and short circuits and be supervised for ground faults and protected when applicable.

5.276. The protective devices for safety systems should be part of the safety system.

5.277. Protective devices should be located in enclosures and structures designed to protect them from environmental conditions, to limit electromagnetic emissions, and to protect personnel.

5.278. The coordination of the protective devices should be such that only the faulty part of the power system is isolated and the remaining intact circuits are unaffected.

5.279. The function of the protective devices is to minimize equipment damage and any unnecessary interruption of electrical service resulting from mechanical or electrical failures or other unacceptable conditions. Protection includes equipment required to support the safety power system in the performance of its safety function, and components whose function is to increase the availability and reliability of the safety equipment.

5.280. Protective devices should be properly sized, set, and coordinated to protect equipment, buses and cables of the main and branch circuits from damage in overload and fault conditions.

#### **CONTROLS AND MONITORING**

5.281. Sufficient instrumentation and control equipment should be provided in the main control room to monitor and control the on-site and off-site power systems.

5.282. The human machine interface (HMI) for electrical power systems should comply with the HMI recommendations of DS431, Ref. [3].

5.283. Adequate methods of monitoring should be provided to assess the operability of the safety power systems. This includes display of:

- a. Breaker positions (safety power system, power sources and large loads);
- b. Busbar voltage and current; and
- c. Standby power source voltage, current and frequency.

5.284. Indication of bypasses and equipment taken out of service should be provided.

5.285. Procedures should exist for operation of the power systems during all plant states and electrical events.

5.286. Sufficient instrumentation and control equipment should be provided in the supplementary control room to monitor and control the safety power systems necessary for performance of safety functions that are assigned to that location.

5.287. The alarm and annunciation systems relating to the electrical power systems should be designed for efficient and error free detection, diagnosis and action by operators.

5.288. Alarms warning about the loss of the operational status of the safety power supplies should be actuated by de-energized logic.

5.289. Means should be provided to automatically initiate and control all safety actions.

5.290. When a claim that manual action alone is acceptable, it should be shown that:

- a. The operator has sufficient and clearly presented information from sensors and equipment of the safety system to make reasoned judgements on the need to initiate the required safety actions;
- b. The operator is provided with written procedures and training for the safety tasks;
- c. The operator is allowed sufficient time to evaluate the status of the plant and to complete the required actions;
- d. The operator is provided with sufficient means of plant control to perform the required actions; and
- e. The communication links between operators carrying out the actions are adequate to ensure the correct performance of these actions.

5.291. Means should also be provided to manually initiate safety actions at system level and at component levels.

5.292. Manual initiation of safety action provides a form of defence in depth for abnormal situations and supports long term post-accident operation.

5.293. Controls for on-site power systems should include the following capabilities:

- a. Automatic selection of alternative off-site power supply when the normal off-site power supply is not available;
- b. Manual or automatic transfer to this alternative supply;
- c. Automatic disconnection of loads (as specified in the design basis) and all other power supplies from a division of safety power system when the preferred power supply is degraded and not restored;
- d. Automatic start and connection of the standby AC power source and loads to the safety power system in the specified sequence;
- e. Manual selection of the alternate AC power supply;
- f. Synchronization of the safety power system back to the normal power supply when the latter is being reinstated; and
- g. Manual switching to facilitate testing, maintenance and repair during normal operation or shutdown;

5.294. Automatic load sequencers should work correctly irrespective of the actual sequence of demand, i.e., the loss of off-site power and an accident signal can occur in any sequence.

## SAFETY RELATED STANDBY AC POWER SOURCES

5.295. Some designs have standby AC power sources that are not safety classified. The general guidance for safety standby AC power sources applies, but the degree of equipment qualification, design confirmation and documentation is according to principles for safety related components.

5.296. Plants which do not require safety classified standby AC power sources should have safety related standby AC power sources to provide reliable power for defence in depth functions that supplement and reduce the challenges to the safety systems.

5.297. Standby power sources should consist of an electrical generating unit complete with all auxiliaries and dedicated separate and independent stored energy supply for both starting and running the prime mover.

5.298. The standby power source should have sufficient capacity and capability to start and supply all loads as specified in the design basis.

## 6. DESIGN GUIDELINES FOR PREFERRED POWER SUPPLIES

### GENERAL

6.1. SSR-2/1 Requirement 41 states that:

“The functionality of items important to safety at the nuclear power plant shall not be compromised by disturbances in the electrical power grid, including anticipated variations in the voltage and frequency of the grid supply.”

6.2. The transmission system should be able to supply the nuclear power plant with power during startup, shutdown and during emergency situations in a stable and continuous way.

6.3. The preferred power supply to the safety power systems is from the grid. During power operation the power supply is normally from the main generator, connected to the grid. The generator will act as a stabilizer against voltage variations on the grid and can power the on-site power systems during house load operation.

6.4. The transmission system should be able to dispatch the energy from the NPP in a stable and continuous way.

6.5. This applies also after anticipated grid events when the plant stays connected to the grid.

6.6. The preferred power supply could also come from a separate connection to the grid. In order to minimize the risk for common cause failure caused by events on the grid, switchyard or main generator, it might be investigated if the different divisions of the nuclear power plant electrical power systems could be connected to different preferred power supplies without significantly increased risk for undue trips and other disturbances.

## RELIABILITY OF PROTECTION DEVICES AND HIGH VOLTAGE EQUIPMENT

6.7. The design of the connection to the grid, the control circuits, and the relay protection should be of high quality and contribute to a reliable preferred power supply.

6.8. Events to be considered in the design of the grid connection and relay protection include:

- Anticipated electrical events including loss of load and out of step scenarios,
- Anticipated electrical events during shutdown,
- Pollution of outdoor equipment,
- Geomagnetic storms, and
- Events such as winding to winding faults in transformers and loss of one phase of the grid connection.

6.9. In areas with high risk of pollution increased insulator length may be necessary to ensure that insulator contamination is not a threat of common cause failure of off-site supplies.

## OFF-SITE POWER SUPPLIES

6.10. The offsite power supply should have adequate capacity and capability to power plant loads during all modes of the nuclear power plant's operation.

6.11. Note that voltage levels on the grid might be different when the plant is shutdown.

6.12. The transmission system is the source of power to the on-site power system. The transmission system is also a significant contributor to the defence in depth strategy of the plant's safety design. The means for safe shut down of a nuclear power plant during transients and accidents, as well as normal shutdown, are more flexible and more reliable if off-site power is available. Therefore, the power supply should have adequate capacity and capability.

6.13. Off-site power should be supplied by two or more physically independent off-site supplies designed and located in order to minimize, to the extent practical, the likelihood of their simultaneous failure.

6.14. The total number of transmission line connections to the electrical grid will depend on the capabilities of the entire grid and on the design of the nuclear power plant itself.

6.15. A single transmission line for each off-site power supply may be acceptable if the safety analysis report shows that this achieves the technical safety objectives as defined in SSR-2/1, Ref. [1]. For example, single off-site power supply might be acceptable for reactor designs that employ passive engineered safety features.

6.16. Nuclear power plants with a single transmission line might have a higher forced outage rate owing to line tripping. This should be considered particularly important in areas where the frequency



of lightning strikes on the line is high. In such cases, the nuclear power plant may prematurely reach design thermal stress cycles unless the plant is designed to withstand the effects of the forced outages or that measures are taken to reduce the number of forced outages, possibly by adding additional transmission lines and greater level of protection.

6.17. As a minimum, each offsite power supply should have the capacity and capability to power all electrical loads required to mitigate the consequences of all design basis accident and anticipated operational occurrences.

6.18. Each offsite supply required for normal plant operation, start up and shutdown should have the additional capability to power the normal loads.

6.19. At multi-unit sites, each unit should be connected to two off-site power supplies such that the technical safety objectives as defined in SSR-2/1, Ref. [1] are fulfilled simultaneously for all units.

6.20. The off-site power supplies provided to meet this recommendation may be shared among two or more plants or units, or they may have separately dedicated circuits.

6.21. For multi-unit sites, a single off-site power supply may be acceptable for some reactor designs if it is shown in the safety analyses report that it is sufficient with one off-site power connection.

6.22. Where off-site supplies are shared between multiple units the ability to disconnect a unit should not affect the availability of off-site supply to any other units.

#### AVAILABILITY

6.23. It is preferable if at least one off-site power circuit is directly connected to each division of the safety power systems without intervening connections to non-safety buses. See Figs 1, 2, and 3 for examples.

6.24. A minimum of one off-site circuit should be designed to be automatically available to provide power to its associated safety divisions within a few seconds following a design basis accident to meet the accident analysis requirements.

6.25. A second off-site circuit should be designed to be available within a short time period.

6.26. Preferably the second circuit would also be available within a few seconds following a design basis accident.

6.27. The transfer scheme of the auxiliary loads should be evaluated as a part of the safety requirements of the design.

6.28. The transfer to the second circuit should be easy to accomplish, both manually and automatically.

6.29. Switching between two live circuits is not performed without risk and the transfer capability should only be used when actually necessary.

6.30. It is preferred to energize from the second circuit after loss of voltage from the primary circuit. Interlocks between breakers may be used to preclude paralleling circuits that may result in adverse voltage or current conditions on common buses.

6.31. The design of the transfer sequence should consider variations in voltage and inrush currents during the transfer.

6.32. The more reliable power supply should be selected for use during normal plant operation.

6.33. Selection of the most reliable supply for normal plant operation minimizes the transfer demands on switchgear.

6.34. Some nuclear power plants are designed for load rejection on separation from the transmission lines and for the subsequent reduction of the reactor output and generator power output to levels sufficient to meet the electrical power needs of the disconnected plant (the house load) without tripping the steam supply or the turbo generator. This transfer to house load operation will result in frequency and voltage excursions before stable operation is achieved.

6.35. In plants designed for house load operation the on-site power system should be designed to accommodate the variations and transients of voltage and frequency from the generator when transferring from normal source of supply to house load operation.

6.36. A generator circuit breaker may be used as a means to immediately power the on-site AC power systems from the off-site circuits following a main generator trip. Generator load break switches can be used for this purpose, but the switchover will not be immediate.

## INDEPENDENCE

6.37. Two off-site circuits should be designed and located to minimize, to the extent practical, the likelihood of their simultaneous failure under all plant conditions and design basis environmental conditions.

6.38. Examples of events that could cause simultaneous failure of both off-site circuits include:

- The use of a common take-off structure for both off-site circuits;
- Failure of a single breaker, switchyard bus cable, or control power supply that causes failure of both off-site circuits.

## SWITCHYARD

6.39. The physical design of the switchyard should minimize the possibility that a single equipment failure will cause the failure of off-site circuits that are credited with supplying safety loads.

6.40. At least two supplies should not share the same control power source.

6.41. The switchyard control power should be unique to the switchyard and not be fed from the nuclear power plant safety control power supplies.

6.42. Control circuits to outdoor switchyards should be equipped with overvoltage protection when entering the plant and be isolated from the control circuits inside the plant.

6.43. Switchyard equipment should be designed to withstand the stresses of worst case faults.

6.44. Protective systems should minimize the probability of failure of both off-site circuits that are credited with supplying safety loads.

6.45. Design features suggested for consideration include:

- Primary and backup relay systems,
- Breaker failure relaying,
- Dual battery systems, and
- Dual breaker trip coils.

#### GRID STABILITY AND RELIABILITY

6.46. The electric grid should provide stable off-site power; that is, it should be capable of withstanding load variations without exceeding the specified voltage and frequency limits.

6.47. The grid should have enough running inertia in order to make certain that loss of a big generating unit, a trip of the nuclear power plant or busbar faults in the grid do not jeopardize the grid stability.

6.48. The degree to which the grid can maintain an uninterrupted power supply to the nuclear power plant with sufficient capacity (e.g. voltage and frequency) is a measure of grid reliability.

#### INTERFACE AND INTERACTION BETWEEN TRANSMISSION SYSTEM OPERATOR AND NUCLEAR POWER PLANT OPERATOR

6.49. The nuclear power plant operator and transmission system operator should identify and establish the equipment interface and communication interface requirements including:

- a. Channels of communications,
- b. Operating procedures,
- c. Preferred corridors to supply energy to the nuclear power plant during shutdowns or accident conditions,
- d. Operating experience feedback,
- e. Coordination of maintenance and outage planning,
- f. Maintenance requirements,
- g. Coordinate circumstances and conditions arising from receipt of a sustained degraded voltage condition at the nuclear plant that may necessitate manual disconnection of the offsite power supply by the nuclear plant operator.

6.50. In many Member States the energy market is going toward liberalization with splitting of the electrical system and establishment of production companies, transmission companies and distribution companies.

6.51. The nuclear power plant requires particular coordination between the transmission system operator and the nuclear power plant operator for the purpose of ensuring safe plant operation and shutdown. This cooperation is based on the common goal to assure nuclear safety and electrical system security (the former prevailing upon the latter). One or more transmission system operators can supply the nuclear power plant.

6.52. Experience has shown that a formal agreement between Nuclear power plant operator and transmission system operator on coordination of planning, including definition of responsibilities, is beneficial.

6.53. The nuclear power plant operator should notify the transmission system operator regarding outages, modifications and maintenance activities as well as any changes to the plant design, configuration, operations, limits, electrical protection systems, or capabilities that would impact the ability of the transmission system operator to meet the current requirements.

6.54. The transmission system operator should notify the nuclear power plant operator regarding outages, modifications and maintenance activities that could impact the availability and reliability of the grid connection of the nuclear power plant. Examples of such activities are maintenance work in substations served by the transmission lines to the nuclear power plant.

6.55. The nuclear power plant operator should coordinate electrical protection schemes with the transmission system operator in order to maximize the availability of the plant and grid supply in case of grid faults.

6.56. This coordination also applies to plant or grid modifications that could influence the interaction between grid and plant.

6.57. The nuclear power plant operator should coordinate with the transmission system operator and validate the accuracy and conservatism of the post-trip voltages predicted by the online grid analyses tools.

6.58. The nuclear power plant operator should ensure that the licensing and design requirements of the plant are understood by the transmission system operator in order to prevent challenges to nuclear safety as a result of transmission system disturbances, transients, or operating conditions.

6.59. Because of the need for secure grid connections to the nuclear power plant, it might be necessary to reach an agreement with the transmission system operator that the grid equipment (including control and electrical protection equipment) in the nuclear power plant switchyard, and the transmission circuits that connect to it, is maintained to a higher standard, or is tested or inspected more frequently, than other grid equipment.

6.60. Note that structures, systems, and components of preferred power supply (e.g., switchyard or grid) that are not under the direct control of the plant operator and the nuclear regulator, are nevertheless site characteristics required to maintain plant safety.

6.61. The preferred power supply characteristics that are essential to plant safety should be documented in the plant safety analysis and ensured by the licensee.

## RELIABILITY ASSESSMENT OF GRID CONNECTIONS

6.62. The analyses to ensure that the nuclear power plant has adequate electrical power (voltage and frequency) from the grid, should be performed on a regular basis.

6.63. Factors to be considered in these analyses include loss of generation by the nuclear plant, any other critical generation source, or loss of power from a transmission system element, the failure rate of protection devices and transmission system breakers and other equipment.

6.64. D-NG-T-3.8, Ref. [16] gives additional background on integration of nuclear power plants and the power grid.

## 7. DESIGN GUIDELINES FOR ELECTRICAL SAFETY POWER SYSTEMS

### GENERAL

7.1. The variations of voltage and frequency in the nuclear power plant's electrical power system during any mode of plant operation should not degrade the performance of any safety system equipment.

### Anticipated electrical events

7.2. A systematic approach should be taken to identify the voltage and frequency variations and transients on the safety classified buses that could result from events on the preferred power supply or in any of the on-site electrical power systems, and to confirm the adequacy of the protection scheme.

7.3. Examples of events to consider are given in chapter 5.

7.4. Standby power supplies used for on-site power systems will have voltage and frequency variations during load sequencing.

7.5. The magnitude of these variations should not impact equipment that is starting, already sequenced or operating.

7.6. The analyses should consider all modes of operation and both symmetrical and asymmetrical events. An event could challenge different components in the electrical systems, depending on rise time, fault time, amplitude or asymmetry.

## Bus monitoring and switching

7.7. Degradation of the preferred power supply of each safety power system bus (i.e. overvoltage, undervoltage, overfrequency, and underfrequency) should be detected on the buses of the safety AC power systems.

7.8. Buses affected by degradation of the preferred power supply should be automatically disconnected from its power source if the degradation exceeds the levels specified in the design requirements.

7.9. After a bus is disconnected from a degraded preferred power supply, the bus should be automatically connected directly to alternative sources in the order given below.

- a. The alternative off-site power source,
- b. The standby power source for that division of the safety power system,

7.10. A time delay may be associated with the disconnection to allow the system to ride through minor disturbances.

7.11. The time delay should be supported by the assumptions in the accident analyses.

7.12. It is preferred that two breakers be provided to disconnect each preferred power supply feed to a safety system bus. See, for example, Fig. 3.

7.13. If automatic connection to the alternative preferred power supply is not used, it should be shown that this is in accordance with the safety criteria of the plant.

7.14. The parameters of the safety power systems, including the availabilities claimed in the design analysis, that are relevant to the safe operation of the plant in operational states and under design basis accident conditions should be identified and used in the establishment of operational limits for the plant.

7.15. Each division should have an independent scheme of detection and protection to disconnect the safety buses from the preferred power supply, shed loads from the safety buses, and start the standby power sources in the event of degraded voltage, degraded frequency, or loss of voltage.

7.16. Bus voltage and frequency monitoring schemes for protection against degraded voltage, degraded frequency, or loss of voltage should meet the following criteria.

- a. Bus voltage and frequency should be detected directly from the safety system buses to which the standby power sources are to be connected.
- b. Voltage or frequency degradation should be alarmed in the MCR.
- c. Voltage or frequency degradation below acceptable limits should automatically disconnect the affected supply from the safety buses.

Two levels of voltage protection with different time delays are necessary: one level to detect loss of off-site power at the safety buses; and a second level for degraded voltage.

- d. On sensing unacceptable high voltage on a preferred power supply, the affected preferred power supply should be automatically disconnected from the safety system buses.
- 4. The set point and time delay should be coordinated with the overvoltage capability of connected equipment.
- 5. The reset value of the monitoring equipment should be lower than the lowest anticipated operating range of voltage of the standby supply.
- e. Each scheme should monitor all three phases.
- f. Measuring circuits should be immune to harmonics.
- g. The protection system design should be redundant.
- h. Failures in the measuring circuits should not cause incorrect operation nor prevent correct operation of the scheme.
- i. The design should minimize unwanted disconnection of the preferred power supply.  
The use of coincident logic and time delays to override transient conditions is a way to minimize unwanted disconnection.
- j. A capability for test and calibration during power operation should be provided.
- k. Indications should be provided in the main control room for any bypasses incorporated in the design.

7.17. Voltage monitoring, used only for alarms, does not have to meet the guidance of paragraph 7.15.

7.18. The undervoltage and time delay set points for degraded voltage protection should be determined from an analysis of the voltage requirements of the safety loads at all on-site system distribution levels.

7.19. Improper voltage protection logic can cause adverse effects on the safety systems and equipment such as spurious shedding of safety loads from the standby diesel generators and spurious separation of safety systems from off-site power due to normal motor starting transients.

## DESIGN FOR RELIABILITY

### Single failure criterion

7.20. SSR-2/1 Requirement 25 states that:

“The single failure criterion shall be applied to each safety group incorporated in the plant design.”

7.21. SSR-2/1 Paragraph 5.39 states that:

“Spurious action shall be considered to be one mode of failure when applying the concept to a safety group or safety system.”

7.22. SSR-2/1 Paragraph 5.40 states that:

“The design shall take due account of the failure of a passive component, unless it has been justified in the single failure analysis with a high level of confidence that a failure of that component is very unlikely and that its function would remain unaffected by the postulated initiating event.”

7.23. While SSR-2/1, Ref. [1] applies the single failure criterion only to safety systems, application of concepts of the criterion is a powerful technique to assuring high functional reliability for any system.

7.24. Normally concepts such as redundancy, independence, testability, continuous monitoring, environmental qualification, and maintainability are employed to achieve compliance with the single failure criterion.

7.25. Each safety group should perform all actions required to respond to a postulated initiating event in the combined presence of the following:

- a. Any single detectable failure within the safety system;
- a. Any undetectable failures, i.e., any failure that cannot be detected by periodic testing, alarm or anomalous indication;
- b. All failures caused by the single failure;
- c. All failures and spurious system actions that cause, or are caused by, the design basis event requiring the safety function; and
- d. The removal from service or bypassed of part of the safety system for testing or maintenance that is allowed by plant operating limits and conditions.

7.26. In justifying non-compliance with the single failure criterion it is advisable to pay particular attention to the possibility of low frequency external hazards and to the long term availability of support systems that are necessary for the operation of power supplies.

7.27. Non-compliance with the single failure criterion should be exceptional and should be clearly justified in the safety analysis.

7.28. Non-compliance with the single failure criterion may be justified for:

- Very rare postulated initiating events;
- Very improbable consequences of postulated initiating events;
- Withdrawal from service of certain components for purposes of maintenance, repair or periodic testing, for limited periods of time;
- Features that are provided only for design extension conditions; and
- Postulated failures whose likelihood can be shown to be sufficiently remote as to be discounted.



7.29. Reliability analysis, probabilistic assessment, operating experience, engineering judgment or a combination of these may be used to establish a basis from excluding a particular failure from consideration when applying the single failure criterion.

7.30. If the single failure criterion is not met during testing or maintenance activities, the time period during which the equipment is out of service should be evaluated for significance and potential impact on core damage frequency.

7.31. The situations in which the single failure criterion is not met in the case of maintenance, repair or testing should be consistent with plant operating limits and conditions.

7.32. Where compliance with the single failure criterion is not sufficient to meet reliability requirements, additional design features should be provided or modifications to the design should be made to ensure that the system meets reliability requirements.

### **Completion of protective action**

7.33. The safety power systems and its protective devices and automatic features should be designed so that, once initiated automatically or manually, the intended sequence of protective actions continues until completion.

7.34. Deliberate operator action should be required to return the safety power systems to normal standby conditions.

## **SAFETY STANDBY AC POWER SOURCES**

### **General**

7.35. SSR-2/1 Requirement 68 states that:

“The emergency power supply at the nuclear power plant shall be capable of supplying the necessary power in anticipated operational occurrences and accident conditions, in the event of the loss of off-site power.”

7.36. Standby AC power sources should consist of an electrical generating unit complete with all auxiliaries and dedicated separate and independent stored energy supply for both starting and running the prime mover.

7.37. The preferred approach is to have only one standby power source per division, avoiding the necessity of parallel operation of generators.

7.38. If multiple power sources are used per division it should be demonstrated that this is a reliable configuration.

7.39. The standby power source should have sufficient capacity and capability to start and continuously supply all loads in its division under the full range of conditions, including allowances for conditions such as:

- a. Loads that might operate at runout conditions,
- b. Loads that might operate in an overload condition,
- c. Changes in load characteristics due to generator operation at the lower or upper end of the allowable voltage and frequency range,
- d. Engine derating, due for example, to higher temperature in intake air, environmental conditions or fuel temperature, and
- e. Future load growth.

7.40. Diesel generators are specified to operate at a fixed voltage and frequency during the emergency mode of operation. In general, the steady state voltage and frequency is maintained within an allowable tolerance of  $\pm 2\%$  relative to the specified value. When electric motors are subjected to voltages, below the nameplate rating, some of the characteristics will change slightly and current consumption will increase.

7.41. The continuous rating of the standby source prime mover preferably allows 3000 to 4000 hours of continuous operation without major overhaul. A 10–15 % overload capacity for a minimum of two hours in a 24 hour period is typically provided. This provides assurance that the power source can handle the short time loading at the onset of an event when engineered safety feature systems are realigning for injection or cooling system operation and their pumps are operating at run out conditions or with higher flow than assumed in thermo hydraulic analyses. The thermo hydraulic analyses are normally conservative in such a way that the expected power consumption of motors might be underestimated.

7.42. The capability of motor driven pumps to deliver required flows should be evaluated for the generator operation at lower end of frequency.

7.43. A variation in frequency affects the torque developed by motors.

7.44. It should be demonstrated that the standby power source could operate continuously for the required time period set out in the design bases without any stops for maintenance activities.

7.45. The standby AC power source should have an automatic start upon loss of preferred power supply to the essential buses.

7.46. The standby AC power source may also have an automatic start upon actuation of an emergency signal (without loss of power to the safety bus).

7.47. The times to start the standby AC power source and to connect loads to this source should be consistent with the startup time assumptions of the safety analysis.

7.48. On-site sources of fuel and other consumables (such as lube oil) should be sufficient to operate the standby power sources until off-site power supply can be restored.

7.49. Off-site sources of fuel and other consumables may be depended upon if sources of replenishment are identified and on-site sources are sufficient for the time required to replenish

supplies. In most member states on-site sources are sized for 1 to 2 weeks of operation without replenishment from external sources.

7.50. Standby power sources should be independent of electrical power and I&C sources other than those in their own division.

7.51. I&C used for the starting, coupling, running and protection of a standby power source should be supplied by batteries within its own division.

7.52. The loss of the DC power source within the same division as the standby power source could lead to the unavailability of the standby AC power source, but it would also cause loss of other functions in the division, making the standby AC supply in that division not required.

7.53. When using batteries specifically dedicated to the standby power source, they should be subject to an adequate surveillance to detect deterioration and failure and is applied to the same extent as it is on any safety system battery.

7.54. Standby power sources should only be used for the period of time necessary to reconnect to reliable and stable preferred or alternative power supplies.

7.55. The use of standby power sources as peaking generation should not be allowed.

7.56. The safety power system may supply loads of lower safety classification (including not important to safety), provided that the independence requirements of this Safety Guide are met.

7.57. Equipment that is not safety classified should be automatically disconnected on an accident signal.

7.58. The isolation devices between a safety power system and equipment of lower safety classification should be part of the safety system.

7.59. The load sequencer should automatically shed all the non-safety loads and should not automatically start non-safety loads.

7.60. The load sequencer should only permit start of non-safety loads after safety loads are started and it is determined that there is enough capacity for start and operation of the non-safety load.

7.61. Transfer of a safety power system bus from its standby AC source to a preferred power source should require manual action.

7.62. When multiple safety power divisions are transferred from their standby power source to preferred power sources; only one division should be transferred at a time.

7.63. After a safety division is returned to the preferred power source the associated standby AC power source should be made operable in normal standby conditions before transferring another division to the preferred power source.

## Testing

7.64. Means should be provided for the periodic testing of standby power sources during plant operation.

7.65. The design of the test provisions should ensure that the standby power source can continue to perform its safety function during testing.

7.66. Arrangements for testing should neither compromise the independence of safety systems nor introduce the potential for common cause failures.

7.67. Examples are the formation of soot in diesels being tested under no-load conditions, inadequate provisions for restoring to normal standby conditions after completion of the test or introducing human errors when testing redundant equipment.

### Performance criteria (transient and dynamic)

7.68. The variations in voltage and frequency in power supplied from the standby AC power source should be shown to be within the design basis of the connected loads and the prime mover.

7.69. It is expected that voltage and frequency variations will remain within the range for continuous operation. Deviations outside the range during the loading sequence and for short time periods is permitted, if voltage and frequency is restored well before the next load is connected and if the voltage on motor terminals is sufficient for starting of the loads in each sequential step.

7.70. The performance of the standby power source during sequential loading, with continuous loads that only exist during accident conditions, is normally determined by a mixture of testing and analyses.

### Relay protection of standby power sources

7.71. Trip devices that protect the power supply from a standby power source against immediate catastrophic failures should be in service during all modes of standby power source operation.

7.72. Examples of such devices include those that protect the:

- Standby power source from catastrophic failure, such as over speed and generator differential protection,
- Safety power system from catastrophic failures, such as backup overcurrent and low impedance ground fault protection.

7.73. Trip devices that protect the standby power source from non-catastrophic failures should be bypassed when the standby power source is supplying safety loads during emergency operation, but should be in service during normal operation and testing.

7.74. The design should provide for individually testing each trip and bypass function.

7.75. All protection trip actuations for the standby power source should be annunciated in the main control room.

#### **Support systems for standby AC power sources**

7.76. Support system equipment (e.g. ventilation, cooling water pumps and lubrication) for redundant division of the standby power sources should be supplied with power from the division it serves in order to preserve the redundancy and independence of the divisions.

7.77. The auxiliary and support systems of standby AC power sources should be sized for multiple starts.

7.78. Starting systems typically have the capacity to support at least 5 starts. In order to support this, it is normally necessary to abort any starting attempt after a specified time to preserve resources.

#### **Fuel for standby AC power sources**

7.79. It should be shown that fuel for standby AC power sources can be stored for long periods.

7.80. Fuel oil at a nuclear power plant is stored for extended durations. Some fuel is chemically unstable when stored for long durations. Fuel ageing and oxidation can lead to high acid numbers, high viscosity, and the formation of gums and sediments that clog filters. Degradation of fuel quality could cause a common cause failure of the standby AC power sources.

7.81. Every fuel delivery should be tested to verify that it meets specifications.

7.82. Normally samples for testing of fuel will be taken on site.

### **DC POWER SYSTEMS**

#### **General**

7.83. Each division of a DC safety power system should consist of at least one battery, one battery charger, and a distribution system.

7.84. In order to have more flexibility for maintenance, two battery chargers and two parallel batteries are preferred in each division.

7.85. The connected DC loads should be rated for float voltage and equalizing voltage.

7.86. To have sufficient battery capacity the float voltage is higher than the nominal DC bus voltage and the end voltage after discharging is low.

#### **Battery**

7.87. Each battery set should, without battery charger, be capable of meeting all required load demands and conditions (including duty cycles and electrical transients) occurring in the plant states specified in the design basis, with account taken of such factors as design margins, temperature effects, any recent discharge, and deterioration with age.

7.88. The limiting case for battery capacity sizing is normally station blackout.

7.89. Ventilation should be provided in battery rooms to maintain the concentrations of combustible gases below prescribed levels.

7.90. If forced ventilation is necessary:

- a. The battery room ventilation system should be powered from the same division as the battery in the affected room; and
- b. Hydrogen monitoring should be considered as a precautionary measure.

7.91. Batteries should be periodically tested in order to demonstrate the operability of the system and to detect any degradation.

7.92. Periodic testing will usually be based on recommendations for each type of battery and typically a battery capacity test on an interval of 1 to 5 years, depending upon battery condition, as well as frequent verification of the following as applicable:

- Trickle charge current,
- Electrolyte level of each cell,
- Specific gravity of the electrolyte of a representative cell,
- Voltage of a representative cell, and
- Temperature of a representative cell.

7.93. The temperature of the battery rooms should be monitored.

7.94. Battery capacity and lifetime is temperature dependent.

7.95. Battery fuses should be monitored.

### **Battery charger**

7.96. Each battery should have its own battery charger.

7.97. Each battery charger should have sufficient capacity to:

- a. Maintain the battery in a fully charged condition during normal operation;
- b. Restore the battery from a fully discharged condition to a minimum charged state within an acceptable period of time while at the same time supplying the highest combined demands of the various steady state and accident loads following loss of normal power.

7.98. When a rectifier is used as power supply for an inverter it should be self-protected.

7.99. The power supply protection to be provided includes: reverse current protection, current limiting features or overload protection, and output undervoltage and overvoltage protection.

7.100. Each battery charger should shield its DC system from transients on the AC system and shield its AC supply from transients on the DC system.

7.101. Battery chargers should keep the output voltage within the operating range of DC voltage:

- a. When the AC input voltage goes low during fault clearing on the supply side and returns to a high voltage.

When clearing faults on the transmission system close to the plant, typical duration is 100 – 250 ms, and when faults happen in the on-site power system the typical duration is up to 100 ms. After a fault on the grid is cleared, the supply voltage will rise to a level determined by the generator acting as supply. (See Fig. 6.) This voltage sag and swell with short rise time might cause severe overvoltage on the DC side of a battery charger.

An effective way is to automatically, with no time delay, shut down the battery charger on AC undervoltage and restart when the supply voltage is normal. This might shield the DC (and uninterruptible AC) power systems from voltage transients induced from grid events.

- b. In loss of load scenarios when the input voltage goes high.

The voltage rise will be determined by the previous active and reactive loading of the generator. The overvoltage will typically be 130–150 %. (See Fig. 7)




FIG. 6. Typical on-site voltage profile during clearing of transmission system fault, a. Voltage during fault, b. Rapid voltage rise, c. Voltage swell due to generator excitation and return to normal voltage.




FIG. 7. Typical on-site voltage profile after loss of load (transfer to house load operation).

7.102. Battery chargers should be able to supply the loads without any battery connected.

7.103. The ability to supply DC loads directly from the battery charger is part of the diversity in power supply of DC systems. Operation in this mode is not normally expected.

7.104. Each battery charger should have disconnecting devices in the AC and DC circuits to enable the battery charger to be isolated.

### **Uninterruptible AC power system**

7.105. Uninterruptible AC safety power systems should be provided where necessary to supply loads for equipment important to safety that requires continuous AC power.

7.106. Some plant designs will not need uninterruptible AC power systems. With modern I&C systems it is feasible to power all loads requiring continuous power with DC. Such an approach eliminates a source of failure.

7.107. Each division of an uninterruptible AC safety power system should consist of a power supply from a DC safety power system to an inverter, a power supply from the AC bus of the same division, and a device for automatically switching between the two supplies.

7.108. Alternatively the uninterruptible AC safety power supply may be in the form of an uninterruptible power supply with dedicated battery charger, battery and inverter.

7.109. If an uninterruptible power supply is used, the guidance given here for battery chargers and batteries also applies.

7.110. The electrical characteristics and the continuity of the uninterruptible AC power supply should meet the design requirements of the loads to be served by the system.

7.111. The limiting case for capacity is normally station blackout.

7.112. An uninterruptible power supply might experience a perturbation in its output, such as voltage sag or an interruption to the cycle, provided that such a perturbation does not result in a loss of the required function of the equipment being served by the supply or in any undesired action by the equipment.

7.113. The design of uninterruptible power supplies should be consistent with the characteristics and design requirements of the loads and the interactions between loads connected to the uninterruptible AC system.

7.114. For example, the design of static inverters should ensure that the voltage harmonics produced by the inverter itself, as well as by any non-sinusoidal loads, do not degrade the functions of the systems being supplied.

### **Protection of DC power systems and uninterruptible AC power system**

7.115. Battery chargers, inverters and motor generator sets are sources of limited short-circuit current. This will affect the sensitivity requirements for their protective devices.



7.116. The protection for battery chargers, inverters, and motor generator sets should be coordinated with their associated alternative supplies, inverters, static switches, battery chargers, distribution panels, instrumentation panels and racks, and other equipment that they power.

7.117. The DC power and uninterruptible AC power systems should be provided with undervoltage and overvoltage protection.

7.118. Ground detection monitoring should be provided for isolated (ungrounded) DC power systems.

7.119. The ground detection monitoring is to give an alarm before the impedance to ground falls below a value at which any malfunctions could occur.

7.120. The DC power distribution system should be provided with coordinated protection.

7.121. Coordination for DC power system circuits involves main bus protective devices and the protective devices used in branch circuits, in switchgear control circuits, in relay and process control panels, and in battery chargers.

7.122. In performing coordination analysis of DC protective devices it is necessary to use appropriate correction factors or DC trip characteristic curves for protection devices.

7.123. The uninterruptible AC safety power system should be provided with coordinated protection.

7.124. It is preferred that the inverter does not have an over voltage protection on the DC side.

7.125. Coordination involves the main bus protective devices and the protective devices used in branch circuits.

7.126. The battery charger, the battery, and the inverter (or motor generator set) is a functional unique system because these elements create the “power supply chain” for many uninterruptible loads and have strong interactions among them. Consequently, properly coordinated protection settings will preserve the safety functions. For example, in case of overvoltage on the AC supply to the battery charger, the battery charger will limit the transfer of the disturbance to the DC side to a level that would not cause trip of other safety loads – including the uninterruptible power supply itself.

7.127. Uninterruptible AC power systems should be provided with underfrequency and overfrequency protection.

## **8. ALTERNATE AC POWER SUPPLIES**

8.1. An alternate AC power supply should be provided at or near the plant if the plant’s design depends upon AC power to bring the plant to a controlled state following loss of offsite power.

8.2. Alternate AC power supplies are provided including necessary connecting points, to protect the electrical systems against the simultaneous failure of off-site and emergency AC power supplies. This involves AC power sources that are diverse in design and not susceptible to the events that caused the loss of on-site and off-site power sources.

8.3. The alternate AC power supplies with auxiliaries should be qualified for its intended application.

8.4. Alternate AC power supplies should have sufficient capacity to operate systems necessary for coping with a station blackout for the time required to bring the plant to and maintain it in a controlled state.

8.5. Ensuring that the alternate AC power supplies can cope with station blackout involves ensuring that the alternate supply is sufficient for simultaneous removal of reactor decay heat, ensuring primary circuit integrity, maintaining the reactor sub-critical, and for removing decay heat from spent fuel for all served units for a period of time that is sufficient for reliable restoration of other power sources.

8.6. Units that have more than the required redundancy of standby AC power sources may use one of these sources for an AAC source, provided that it meets the other criteria of this section.

8.7. If an alternate AC power source serves more than one unit at a site where safety standby AC power sources are shared between units, the alternate AC power source should have sufficient capacity to operate systems necessary for coping with a station blackout for the time required to bring all units that share the safety AC power sources to, and maintain them in a controlled state.

8.8. The alternate AC power source for one unit should not normally be connected to the on-site power system of that unit.

8.9. Support systems that maintain the AAC source in readiness may be powered from one or more units, providing it does not affect the operability of the alternate AC power source.

8.10. There should be a minimum potential for common cause failure of any safety Standby AC Power Source and the alternate AC power source.

8.11. No single point of vulnerability should exist whereby a weather related event, external event, or single active failure could disable any of a unit's safety standby AC power supply and simultaneously fail all off-site power supplies and the alternate AC power supplies.

8.12. Provisions should be made for connecting the alternate AC power supply to one or all safety power system buses.

8.13. The safety power systems should be fed from the alternate AC power supply only after it has been disconnected from other power supplies.

8.14. The alternate AC power supply may also have the capability to power certain loads necessary from defence in depth aspects.

8.15. Alternate AC power supplies should be capable of supplying the required loads within the time specified in the plant safety analysis and the plant station blackout coping analysis.

8.16. Preferably the Alternate AC power supplies will be capable of supplying loads as soon as is reasonably practicable. Restoring AC power as soon as possible after a station blackout restores a

degree of defence in depth to the electrical power systems, restores safety systems that depend on AC power, and restores support systems (e.g., lighting and habitability systems) that significantly enhance the operators' ability to respond to an event.

## **9. DESIGN CONFIRMATION AND DOCUMENTATION**

### **MANAGEMENT SYSTEM**

9.1. The design of electrical systems important to safety should be conducted within the framework of an overall management system that meets the requirements of GS-R-3, Ref. [17] and follows the recommendations of GS-G-3.1, Ref. [18], and GS-G-3.5, Ref. [19].

### **VERIFICATION**

9.2. The capacity and capability required of electrical power systems should be determined by analysis and verified by tests. (Refer to annex II.)

9.3. As part of the design and design verification, the following should be performed and documented in a form suitable for auditing:

- a. Demonstration that the electrical power systems are capable of fulfilling their safety functions as set out in their design bases;
- b. Demonstration that the electrical power systems design requirements are met;
- c. Demonstration that electrical safety power systems comply with the single failure criteria;
- d. Demonstration that electrical power systems meet design basis reliability requirements;
- e. Demonstration that operation of protective devices have been adequately coordinated;
- f. Demonstration that adequate mitigating measures against station blackout are implemented;
- g. Demonstration that the reliability of off-site circuits credited with supplying safety loads meets and will continue to meet availability requirements after planned changes to transmission and generation facilities;
- h. Demonstration that the off-site circuits credited with supplying safety loads will continue to have their required capacity and capability in the presence of: loss of the nuclear plant, loss of the largest generating unit, loss of the largest transmission circuit or intertie, or loss of the largest load.
- i. Demonstration that each offsite power supply has the capacity and capability to power all electrical loads required to mitigate the consequences of all design basis accidents and anticipated operational occurrences.

9.4. The demonstration should cover all modes of operation of the nuclear plant.

9.5. The demonstration of the off-site circuits' reliability and availability should be performed together with the transmission system operator. (Refer to Section 6.)

9.6. For all systems important to safety a systematic assessment should be conducted to confirm that the design achieves the reliability requirements of the system design basis.

9.7. This demonstration may be based on a balance of application of deterministic criteria and quantitative reliability analysis that considers design features such as, for example, redundancy, testability, failure modes, and rigor of qualification.

9.8. The use of software or complex multi-element logic modules might provide difficulties in justification of reliability and sensitivity to common cause failures. The reliability may therefore depend on assurances of freedom from error in the design and implementation process.

9.9. Test facilities that are part of the safety system should be considered when determining system availability.

9.10. Analytical tools used in design and analysis of electrical systems should be qualified and the validity of the mathematical models should be justified on the basis of experimental data or operating experience.

9.11. The analyses recommend by paragraph 9.2–9.10 are part of the plant safety assessment. GS-R-4, Ref. [20] provides additional guidance on safety assessment.

## **Testing**

9.12. Provisions should be made in the design to ensure that the following test programmes can be implemented without endangering the safety of the plant during testing:

- a. A pre-operational test programme to demonstrate operation in all system modes (e.g., operational and emergency) to the extent practicable, to prove that the design requirements have been met, and to establish that each division is independent of other divisions.
- b. A test programme during operation that provides adequate assurance of the readiness of the systems to function upon demand.
- c. Periodic test procedures to demonstrate the continuing operability of the system and to detect and identify any degradation of the system or components within the system.

9.13. General recommendations on measures for verifying the adequacy of the design are given in GS-G-3.5, Ref. [19] paragraphs 5.114 to 5.134.

9.14. A major consideration of pre-operational test programmes for electrical power systems is to confirm, before entering into operation, and after major modifications, the independence between divisions of the safety power systems. Normally this involves testing to verify that all on-site power systems and their load groups can successfully operate and is in no way affected by the partial or complete failure of any other power source in other divisions.

## **DESIGN DOCUMENTATION**

9.15. Documentation of the electrical power systems should include:

- a. Design bases;
- b. A description of the overall power supply system including:
  1. Details of how the nuclear power plant is connected to the grid,

2. An explanation of the degree of redundancy of the electrical safety power system,
  3. Identification of interfaces with the auxiliary systems;
- c. A description of the separation criteria for installing equipment, cables and raceways, including wiring and components inside panels;
  - d. One-line diagrams, functional control diagrams, schematic diagrams, connection diagrams, panel wiring diagrams, and descriptions of systems;
  - e. Layout plans for the on-site electrical power system together with the arrangements of equipment and associated support systems.
  - f. Layout plans of cable routes, including trays, ducts and conduits, throughout the plant and identification of redundant divisions and cables and their routing;
  - g. Raceway schedules showing cables contained in each raceway segment and the fill percentage of each segment;
  - h. Circuit schedules identifying for each field cable its connection points, cable type, and routing through the raceway system;
  - i. An electrical load analysis showing the inventory of electrical loads and for electrical safety power systems showing a time dependent loading from which the capabilities of the necessary components of the power systems are calculated;
  - j. Operating procedures and maintenance manuals for electrical power systems and equipment;
  - k. Periodic test and maintenance requirements for electrical power systems and equipment;
  - l. Documentation of acceptance and commissioning tests for electrical power systems and equipment;
  - m. Quality assurance records;
  - n. Analysis of voltage and frequency transients, short circuit calculations, and voltage drop calculations:
    1. From the grid during power operation,
    2. From the on-site electrical distribution system,
    3. From the grid during shutdown, and
    4. From the main generator.
  - o. Steady state load and voltage profile studies that show the voltages throughout the power system for various modes of plant operation (and generator load/ power factor), including design basis events, at the time of normal and degraded voltage conditions.
  - p. Transient load and voltage studies that show the profile of the loads that are sequentially applied to the preferred and standby power supplies during various modes of plant operation.
  - q. A power system study that examines loading and voltages in the DC power systems supplying alternating current and direct current systems during various modes of plant operation.
  - r. A bus transfer study that analyses the impact of voltage, phase angle, frequency, and the effect of motor reacceleration on buses and motors before, during, and immediately after automatic bus transfers.

- s. Short-circuit studies to determine the maximum and minimum fault currents throughout the power system for various modes of plant operation, including design basis events, to be used to analyse the fault clearing capability of the electrical equipment.
- t. Protective device coordination and equipment protection studies that show proper set point selection in all of the protective schemes;
- u. Analysis of fuel storage capacities for standby power sources;
- v. Analysis of the consequences of partial or total loss of power supplies;
- w. Equipment qualification plans, analyses, and test reports, and
- x. Specifications for electrical power components.

DRAFT

## REFERENCES

- [1] INTERNATIONAL ATOMIC ENERGY AGENCY, Safety of Nuclear Power Plants: Design, IAEA Safety Standards Series No. SSR-2/1, IAEA, Vienna (2012).
- [2] INTERNATIONAL ATOMIC ENERGY AGENCY, Design of Emergency Power Systems for Nuclear Power Plants, Safety Standards Series No. NS-G-1.8, IAEA, Vienna (2004).
- [3] INTERNATIONAL ATOMIC ENERGY AGENCY, Design of Instrumentation and Control Systems for Nuclear Power Plants, Safety Standards Series No. DS431, IAEA, Vienna (Draft 03 August 2011).
- [4] INTERNATIONAL ATOMIC ENERGY AGENCY, Classification of Structures, Systems and Components in Nuclear Power Plants, Safety Guide DS 367, IAEA, Vienna (2013).
- [5] INTERNATIONAL ATOMIC ENERGY AGENCY, Protection against Internal Fires and Explosions in the Design of Nuclear Power Plants, Safety Standards Series No. NS-G-1.7, IAEA, Vienna (2004).
- [6] INTERNATIONAL ATOMIC ENERGY AGENCY, Protection against Internal Hazards other than Fires and Explosions in the Design of Nuclear Power Plants, Safety Standards Series No. NS-G-1.11, IAEA, Vienna (2004).
- [7] INTERNATIONAL ATOMIC ENERGY AGENCY, Seismic Design and Qualification for Nuclear Power Plants, Safety Standards Series No. NS-G-1.6, IAEA, Vienna (2003).
- [8] INTERNATIONAL ATOMIC ENERGY AGENCY, External Events Excluding Earthquakes in the Design of Nuclear Power Plants, Safety Standards Series No. NS-G-1.5, IAEA, Vienna (2003).
- [9] INTERNATIONAL ATOMIC ENERGY AGENCY, Ageing Management for Nuclear Power Plants, Safety Standards Series No. NS-G-2.12, IAEA, Vienna (2009).
- [10] INTERNATIONAL ATOMIC ENERGY AGENCY, Engineering Safety Aspects of the Protection of Nuclear Power Plants against Sabotage, Nuclear Security Series No. 4, IAEA, Vienna (2007).
- [11] INTERNATIONAL ATOMIC ENERGY AGENCY, Nuclear Security Recommendations on Physical Protection of Nuclear Material and Nuclear Facilities (INFCIRC/225/Revision 5), Nuclear Security Series No. 13, IAEA, Vienna (2007).
- [12] INTERNATIONAL ATOMIC ENERGY AGENCY, Operational Limits and Conditions and Operating Procedures for Nuclear Power Plants, Safety Standards Series No. NS-G-2.2, IAEA, Vienna (2000).



- [13] INTERNATIONAL ATOMIC ENERGY AGENCY, The Operating Organization for Nuclear Power Plants, Safety Standards Series No. NS-G-2.4, IAEA, Vienna (2002).
- [14] INTERNATIONAL ATOMIC ENERGY AGENCY, Maintenance, Surveillance and In-service Inspection in Nuclear Power Plants, Safety Standards Series No. NS-G-2.6, IAEA, Vienna (2001).
- [15] INTERNATIONAL ATOMIC ENERGY AGENCY, Conduct of Operations at Nuclear Power Plants, Safety Standards Series No. NS-G-2.14, IAEA, Vienna (2008).
- [16] INTERNATIONAL ATOMIC ENERGY AGENCY, Electric Grid Reliability and Interface with Nuclear Power Plants, D-NG-T-3.8, Vienna (2012).
- [17] INTERNATIONAL ATOMIC ENERGY AGENCY, The Management System for Facilities and Activities, Safety Requirements No. GS-R-3, IAEA, Vienna (2006).
- [18] INTERNATIONAL ATOMIC ENERGY AGENCY, Application for the Management System for Facilities and Activities, Safety Standards Series No. GS-G-3.1, IAEA, Vienna (2006).
- [19] INTERNATIONAL ATOMIC ENERGY AGENCY, The Management System for Nuclear Installations, Safety Standards GS-G-3.5, IAEA, Vienna (2009).
- [20] INTERNATIONAL ATOMIC ENERGY AGENCY, Safety Assessment for Facilities and Activities, General Safety Requirements No. GS-R-4, IAEA, Vienna (2009).
- [21] Nuclear Energy Agency, Defence in Depth in Electrical Systems and Grid Interaction, Final DIDELSYS Task Group Report, NEA/CSNI/R (2009)10, Paris (2009).
- [22] INTERNATIONAL ATOMIC ENERGY AGENCY, Safety Glossary, IAEA, Vienna (2007).

## ANNEX I.

### DEFENCE IN DEPTH IN ELECTRICAL POWER SYSTEMS

I-1. Nuclear power plants rely on electrical power for various safety functions and the reliability of the power supplies are important for the safety of the plant. Due to the design of electrical power systems, all parts of the systems are normally connected regardless of their safety classification.

I-2. The electrical power systems are support systems necessary for all levels of defence in depth. It is essential that the plant have a reliable power supply to control anticipated deviations from normal operation as well as to power, control and monitor the plant during all types of events challenging the barriers against radiological releases and also during design extension conditions.

I-3. Any electrical event or disturbance that happens in the electrical systems has to be handled in such a manner that the safety functions of the power plant can be carried out.

I-4. Operating experience shows that loss of transmission systems or failures in the on-site power systems could degrade the safety of the plant as described in Ref. [21].

I-5. Many overlapping system characteristics are provided to accomplish reliable and robust electrical systems that form the different levels of a defence in depth concept. These system characteristics cover grid and on-site systems both important to safety and not important to safety. Even though more stringent criteria are applied to safety power systems, and more verification is necessary, the complete on-site and off-site power systems contribute to the reliability and robustness.

I-6. Support features for the electrical power systems are control and monitoring, part of the main and supplementary control room complex, and procedures for operation of the power systems during all plant states and electrical events.

I-7. Table I-1 summarizes the electrical power system features that support the levels of defence in depth defined in SSR-2/1.

#### FIRST LEVEL

##### **Design bases**

I-8. The design bases for the on-site electrical systems are the fundamental base for reliability and robustness. The bases account for the continuous operating range of voltage and frequency, all possible events that could cause transient, dynamic or continuous variations of them, and internal and external hazards that threaten the availability of power supply to the plant. As a nuclear power plant is a generating facility, the voltage and frequency excursions that will arise from different events will be different from normal industrial events. Figure I-1 gives an example of voltage and frequency variations that will affect the on-site power systems in a generating unit during an anticipated operating event.

I-9. Incomplete design bases, resulting in equipment not qualified for the intended function, cannot be solved by redundancy or diversity.

TABLE I-1. ELECTRICAL POWER SUPPLY SUPPORT FOR THE PLANT DEFENCE IN DEPTH CONCEPT

Levels of defence in depth	Objective (From INSAG-12)	Essential means (From INSAG-12)	Applied to plant electrical power systems	Guidance in Safety Guide chapter
1	Prevention of abnormal operation and failures	Conservative design and high quality in construction and operation	Comprehensive design bases, robust and reliable grid, robust and reliable on-site power systems	4 Design bases, 5 General design guidelines, 6 Design guidelines for preferred power supplies
2	Control of abnormal operation and detection of failures	Control, limiting, and protection systems and other surveillance features	Robust and reliable fault clearing system and protection coordination, power supply transfer capability, house-load operation possibilities	5 Design for reliability, 6 Design guidelines for preferred power supplies
3	Control of accidents within the design basis	Engineered safety features and accident procedures	Robust and reliable Safety power systems, robust and reliable on-site standby AC power supplies,	7 Design guidelines for electrical safety power systems
4	Control of severe plant conditions, including prevention of accident progression and mitigation of the consequences of design extension conditions	Complementary measures and accident management	Robust and reliable alternate AC power supply	7 Design guidelines for electrical safety power systems 8 Alternate AC power supplies
5	Mitigation of radiological consequences of significant releases of radioactive materials	Off-site emergency response	Not part of this Safety Guide	


## The grid

I-10. The grid is part of the preferred power supply for the plant and the safety power systems. During power operation, the power supply to the plant is normally from the generator, which will dampen variations from the grid.

I-11. The grid has to provide stable off-site power; that is, it needs to be capable of withstanding load variations and anticipated events on the transmission system without exceeding the specified voltage and frequency limits. More aspects on integration of nuclear power plants and the grid are given in D-NG-T-3.8, Ref. [16].

## On-site power systems

I-12. The on-site power systems are linked together and an electrical event on a non-safety bus will in most cases also affect the safety power systems. A reliable on-site power system implies an installation with low possibility of failure of loads and other equipment. The substantial part of this is covered by national electrical codes, but qualification of equipment (environmental and electrical) as well as equipment specifications based on plant design bases contribute. Good housekeeping will lessen the risks for faults and a proper understanding of load behaviour will minimize the risk for overload of rotating equipment.



*FIG. I-1. Example of on-site voltage (y-axis) and frequency (x-axis) variations during fault clearing on the transmission system*

I-13. The deterministic analyses to design and verify the reliable and robust on-site system are part of the safety justification for the nuclear plant.

I-14. The on-site power systems' robustness and reliability should be analysed for all plant configurations including those where part of the electrical power system may be taken out of service, such as refuelling outages.

I-15. The possibility of common cause failures cannot not be ruled out, as during normal operation redundant divisions of the safety power system are connected to a common preferred power supply. Preventive measures such as diversity in power supplies (normally a built in feature by design) are essential.

I-16. Maintenance programmes and procedures aim for the highest standards, not only for safety systems but also for all parts of the on-site power. Surveillance testing or performance testing is one way of following any degradation of equipment.

I-17. Plant modifications usually have an impact on the electrical power systems. Changes in loads and load behaviour have to be evaluated. This includes changes in control systems as they might affect battery loading.

I-18. Power supplies for lighting and telecommunication play an important role in coping with operational disturbances and events, although they are not generally classified as important to safety.

## SECOND LEVEL

### **Fault clearing system and protection coordination**

I-19. In order to minimize the effect of any faults in the electrical power systems protection coordination and a fault clearing systems are provided that will disconnect only the faulted equipment. Backup features are also provided for the event that a primary protection or fault clearing device fails.

I-20. Since battery chargers, inverters, and motor generator sets are generally sources of limited short-circuit current, coordinating protective device sensitivity and system available fault current receives special attention.

I-21. Protection coordination is designed to work properly both during power operation and during shut down conditions.

### **Power transfer capability**

I-22. Off-site power is normally supplied by at least two physically independent off-site circuits designed and located in order to minimize, to the extent practical, the likelihood of their simultaneous failure. For some reactor designs (usually designs with passive safety features) it might be shown in the safety analyses report that only one off-site power connection is sufficient.

I-23. One of these connections is designed to be available within a few cycles following a loss of coolant accident to assure that core cooling, containment integrity, and other vital safety functions are maintained.

I-24. The transfer to the other off-site circuit is normally automatic but provisions are made to initiate the transfer either manually or automatically. Studies are performed that analyses the impact of voltage, phase angle, and frequency on buses and motors before, during, and immediately after a bus transfers. Also reacceleration of motors has to be considered in the study.

I-25. The supply of uninterruptible AC power systems will also involve provisions to transfer the supply from one source to another.

### **House load operation possibilities**

I-26. Some plants are designed to have the capability to withstand load rejection without undergoing a reactor trip or a turbogenerator trip, in order to continue to supply house loads.

I-27. The transfer to house load is complex, due to reactivity feedback and control of the power decrease. Experience shows that if the initial transient can be handled, operation can keep on for several hours. It adds diversity to power supplies for the plant.

I-28. To achieve house load operation, circuit breakers are necessary to separate the plant generator from the grid. This arrangement provides continuous power, either from the plant's turbogenerator or from the grid in all conditions except those where faults occur between the circuit breakers or where there are coincident faults in the plant generator and the grid.

## **THIRD LEVEL**

### **On-site standby AC power supplies**

I-29. The safety systems of the nuclear power plant normally operate from the preferred power supply (i.e. grid or main generator), or from the on-site standby AC power supply.

I-30. The operability of the standby AC supplies has to be verified regularly. Testing of the standby AC starting capability is normally designed in such a manner that the test does not have negative effects on the long term availability of the power source.

I-31. Verification of starting and loading capability of the standby AC sources normally has to be a combination of tests and analysis to capture design bases events.

I-32. Loads other than safety system loads may derive their power from the safety power system. These loads are not automatically started after a loss of off-site power as they might affect the availability of the safety loads. The non-safety loads may only be started after it is determined that there is enough capacity and capability for start and operation.

I-33. If an external hazard might jeopardize the first and second level of the defence in depth in electrical power systems (e.g. grid connections and house load), the on-site standby AC power supplies have to be protected against this hazard. Proper precautions will be based on the principles described in NS-G-1.5, Ref. [8] and NS-G-1.6, Ref. [7].

### **Safety power systems**

I-34. The safety power systems that supply different loads is of utmost importance for the possibility of the nuclear power plant to handle a wide spectrum of initiating events that could challenge the barriers to release of radioactive material from the plant.

I-35. Events on the electrical power systems with origin from preferred power supplies can cause common cause failures on all divisions. Hence during design, construction, and operation adequate countermeasures are essential. After loss of preferred power supplies, when the standby AC sources supply one division each, the risk for common cause failures from electrical events is negligible as there are no common parts (although the starting sequence of the standby source is sensitive to common cause failure). Experience shows that incomplete design bases are the dominating contributor to common cause failure, in which case component diversity does not lessen the risk.

I-36. Common cause failure for identical components can be screened out if:

- They perform different functions (one breaker in one system has to close, one breaker in the other system has to open), or
- They have different modes of operation (one of two parallel rectifiers is in operation, the other is switched off).

Common cause failure due to electrical events is not postulated for passive equipment like busbars, cables and transformers.

I-37. The DC systems are essential for the reliability of the safety power systems, as well as any other on-site or off-site power system. A governing principle is to not transmit any disturbances on the preferred power supply, with origin off-site or from the generator as a result of an off-site disturbance, to the DC power systems and consequently to the uninterruptible AC power systems. This is expected to be part of the design bases and can be achieved by design or protection devices.

I-38. In order to handle common cause failure risks for electronic protection devices the same design principles as for I&C equipment are used, refer to DS431, Ref. [3].

I-39. Part of the equipment specifications for electrical loads will be the operating range of voltage and frequency for the electrical systems, but knowledge of electrical transients and their impact on the loads is as essential. Understanding of the mechanical load characteristics is necessary in order to determine the load range and power consumption for different modes of operation. This will give the proper sizing of standby power sources and setting of protective devices.

#### FOURTH LEVEL

##### **Alternate AC power supply**

I-40. The dependence on electrical power for safety functions in a nuclear power plant implies that also station blackout scenarios have to be considered. Consideration of station blackout involved determining the time period for which a plant can cope with a loss of all AC power and making provisions to connect an alternate AC power supply to the plant before the end of that period.

I-41. Precaution is necessary to ensure that this supply is available and accessible to cope with external hazards and can be connected to the plant within the given time after e.g. earthquake, tsunami or during e.g. flooding, storm.

I-42. The alternate AC power source has to be as independent as possible from the other power sources that can supply the safety power system.

I-43. In multi-unit plants, connections between units can serve the same purpose if only one unit at a time is subject to station blackout.



DRAFT

## **ANNEX II.**

### **ELECTRICAL SYSTEM ANALYSES FOR DESIGN VERIFICATION**

II-1. Analytical studies demonstrate design margins and robustness of the electrical power system in a nuclear plant. The analyses and design capabilities have to be verified and validated by test or operating experience. This Annex describes some of the key elements of electrical system design that are normally performed as part of the power system analyses. The need for analyses applies to both AC and DC systems, but many of the specific topics mentioned apply only to AC systems.

#### **LOAD FLOW STUDIES**

II-2. Load flow analysis is an important part of power system calculations since it evaluates the network performance in its normal and emergency operating conditions and establishes the bounding limits for limiting conditions. Load flow studies are performed using computer software that simulates actual steady-state power system operating conditions, enabling the evaluation of bus voltage amplitude and load angle, active and reactive power flow, and losses. Conducting a load flow study using multiple scenarios helps ensure that the power system is adequately designed to satisfy performance criteria. Specifically, load flow studies are commonly used to investigate:

- Component or circuit loading,
- Bus voltage amplitude and load angle,
- Active and reactive power flow,
- Power system losses,
- Proper transformer tap settings,
- Limiting conditions for system operation,
- Bus transfer schemes,
- Optimization of circuit usage,
- Practical voltage profiles for postulated conditions, and
- Equipment specification guidelines

II-3. The following general criteria for design are typically considered acceptable when used in power flow studies:

- Steady state voltage drop at all buses to be within +/- 5% of the nominal rating for all operating conditions considered.
- Transient state voltage variation > 5% may be acceptable when sequencing load.
- Electrical circuits are not overloaded for any postulated operating condition.
- Reactive power flows (generation, import and export) are within specified limits for all operating conditions.
- During specified contingency conditions, the power quality is not degraded.

- Harmonic content is within set limits

II-4. The following study cases are specifically considered in power flow studies:

- Extreme operating conditions of maximum and minimum loading conditions to check the adequacy of the on-site and off-site power sources, during normal operation and plant shutdown.
- Contingency conditions such as outage of lines, transformers and generators for the off-site power supply coupled with minimum and maximum loading of plant auxiliary system including equipment required to mitigate consequences of an accident.
- Optimization of plant operating parameters such as transformer taps, generator excitation limits, reactive power compensations and cable sizing.
- Large motor starts. The starting current of most ac motors is several times larger than normal full load current when starting them directly on line at full rated voltage. Excessive starting current results in drop in terminal voltage and may result in failure of motor starting due to low starting torques, unnecessary operation of under voltage relays or stalling of other running motors connected to the network. Motor starting studies can help in the selection of best method of starting, the proper motor design, and the proper system design for minimizing the impact of the motor starting. This study might have to be re-evaluated after replacement of motors, depending on motor characteristics.

## SHORT CIRCUIT STUDIES

II-5. Short circuit calculations provide currents and voltages on a power system during fault conditions. This information is required to design an adequate protective relaying system and to determine interrupting requirements for circuit breakers at each voltage level during maximum fault current levels and verify timely fault clearance with enough available fault current to operate protective relaying by protective devices. The combination of timely fault isolation and coordination of protection provide for stable operation of the nuclear power plant electrical power system. Fault contributions from all operating sources at any given time have to be considered. Nuclear power plants have large motors that can provide a significant contribution to the available fault current in the plant power system. The short circuit calculations have to be confirmed when major replacements and major modifications of the electrical power system (on-site or off-site) are implemented and a cumulative evaluation performed periodically.

II-6. Fault conditions can be balanced or unbalanced shunt faults or series (open conductor) faults. Faults may be caused by either short-circuits to ground or between live conductors, or may be caused by broken conductors in one or more phases.

II-7. Fault studies have to be updated when major replacements and major modifications of the electrical power system (on-site or off-site) are implemented and a cumulative evaluation performed periodically, e.g., as part of Periodic Safety Reviews.

## ELECTRICAL PROTECTION COORDINATION STUDIES

II-8. A short circuit / coordination study establishes the magnitude of currents flowing throughout the power system at various time intervals after a fault occurs and evaluates the size and settings of a system's protective devices, such as relays, fuses and circuit breakers, and the circuits they protect. The goal is to provide power transformers, switchgear, motor control centres, distribution panel boards and other electrical equipment with the required protection. The study also assists with selecting appropriate types, ampere ratings and device settings to ensure selective and rapid interruption of circuits under overload and short circuit conditions to minimize isolation of essential equipment.

II-9. Protective relays are designed to rapidly actuate equipment used to isolate the faulted portion of the system to prevent equipment damage and with minimum system disruption to ensure continuity of power to unaffected portions of the power systems. When relays designed to protect specific equipment such as containment penetrations are postulated to fail, or primary zones do not operate and clear the fault in their primary protection zone, backup relays have to isolate the fault, after providing sufficient time for the operation of the primary zone relays. The relays also have to discriminate between faulted conditions, normal operating conditions and abnormal operating conditions and function for the specific protection for which they are designed. Relay coordination calculations consider the operating characteristics of the relays, normal operating and withstand characteristics of plant equipment and determine the optimum relay settings to achieve high reliability of the electrical systems.

II-10. Protective systems have to provide protection against 'thermal withstand' limits, motor stalling, negative sequence and direct current withstand limits, protection against abnormal frequencies, and protection against unbalance operating conditions as applicable to various plant components and operating situations. Protection coordination also includes measuring principles.

II-11. Typical protective relays studies include:

- Overload phase relays,
- Overcurrent phase fault relays,
- Ground fault relays,
- Coordination with maximum load current,
- Coordination with fuse characteristics,
- Coordination with maximum motor starting current and time,
- Coordination with transformer inrush current,
- Coordination with reacceleration currents,
- Coordination with primary back up pairs,
- Coordination with thermal withstand capabilities, and
- Coordination with safe stall limits for motors.

II-12. Ground fault protection requires unique consideration as fault current magnitudes depend on the system grounding method — solidly or low impedance grounded systems may have high levels of ground fault currents. These high levels typically require fast tripping to remove the fault from the system. Ground overcurrent and directional overcurrent relays are the typical ground fault protection solution for such systems. High impedance ground fault detection is difficult as special relays are necessary to measure the ground fault current combined with the unbalance current generated by line phasing and configuration and load unbalance.

#### LOSS OF VOLTAGE AND DEGRADED VOLTAGE STUDIES

II-13. In addition to protection schemes discussed above, safety equipment at nuclear plants is protected from a complete loss of preferred power (loss of voltage relay) to the safety buses and also from sustained degraded voltage conditions on the preferred power supply which can lead to malfunction or damage safety significant equipment.

II-14. Equipment that is considered important to safety has to be protected from two types of low voltage issues:

- A loss of voltage event which implies a sudden sharp voltage drop in the grid system. Typically a nominal delay is allowed for relay actuation to separate on-site buses from the grid if voltage does not recover to normal operating band. Loss of voltage will also result in an automatic start signal to the on-site standby power sources.
- A degraded voltage event that postulates sustained low voltage conditions for several seconds and subsequent recovery to normal operating band. If the off-site power system does not recover to nominal operating conditions, it is preferable to separate from the source.

The degraded voltage condition occurs in transmission systems that are overloaded due to generation deficiency caused by loss of a generating unit, unexpected system loads, loss of a transmission element or system faults. This protective scheme requires additional plant specific considerations. A general philosophy is outlined below:

- The voltage drop/load flow studies done for evaluating off-site power/on-site power system interface use minimum expected voltage at the plant/grid interface node, demonstrating adequate voltage for starting and running of plant components during normal, abnormal and accident conditions.
- The selection of voltage and time delay set points are determined from an analysis of the operating voltage requirements of the safety significant loads at all on-site system distribution levels.
- The time delay is selected based on the following conditions:
  - The allowable time delay, including margin that does not exceed the maximum time delay that is assumed in the accident analyses;
  - The time delay has to override the effect of expected short duration grid disturbances, preserving availability of the off-site power supplies; and

- The time duration of a degraded voltage condition at all distribution system levels that will not result in failure of safety systems or components.

II-15. A typical scheme for degraded voltage relay involves two separate time delay relays to deal with the following conditions:

- The duration of the first time delay is sufficient to establish the existence of a sustained degraded voltage condition (i.e., something longer than a motor starting transient). Following this delay, an alarm in the control room alerts the operator to the degraded condition. The subsequent occurrence of an accident signal immediately separates the safety distribution system from the off-site power system.
- The duration of the second time delay is selected to be less than the duration of a sustained degraded voltage that will damage permanently connected safety loads. Following this delay, if adequate voltages have not been restored, the safety distribution system is automatically or manually (by operator action) separated from the off-site power system.

## TRANSIENT STABILITY STUDIES

II-16. By nature, a power system is continually experiencing disturbances. These may include loss of production, short-circuits caused by lightning or other fault conditions, sudden large load changes, or a combination of such events. These disturbances may lead to a change in the configuration of the power system. Transient stability study of a power system is necessary to determine whether the system will remain stable or not after such major disturbances. The assumed critical fault clearing time (CFCT)<sup>1</sup> with a given off-site power system configuration will be different for various fault conditions. This CFCT might be specified and described in the Plant's Safety Analysis Report. The recovery of a power system subjected to a severe large disturbance is of importance to reliable and safe operation of a nuclear plant. Typically the system has to be designed and operated in such a way that a specified number of credible contingencies do not result in failure of quality and continuity of power supply to the loads. This requires accurate calculation of the system dynamic behaviour, which includes the electromechanical dynamic characteristics of the rotating machines, generator controls, reactive power compensators, loads, protective systems and other controls. The degree of the system stability is an important factor in establishing the operating characteristics of the grid system in the vicinity of the nuclear plant. Grid perturbations that lead to loss of synchronism of the power system require separation of the disturbance in a rapid manner to avoid equipment damage or loss of system stability.

II-17. Parameters that can affect transient stability include:

- Synchronous machine parameters,

---

<sup>1</sup> Critical fault clearing time is the maximum fault duration for which a system remains stable.

- Generator step-up transformer impedance,
- Inertia of turbogenerator,
- Transmission line parameters,
- Circuit breaker and relay characteristics,
- System layout,
- Excitation system, power system stabilizer and generator governor characteristics,
- System grounding, and
- System Controls such as auto reclosing of circuit breakers, single pole switching, load shedding and system inertia.

II-18. Typically, transient stability analysis involves:

- Modelling generators in accordance to their steady state, transient, and sub-transient parameters,
- Simulating transient behaviour for three phase or line to ground faults,
- Modelling motor and motor load torque, slip, current and acceleration curves,
- Simulating generator and motor startups,
- Modelling trip/close of circuit breakers, open/close of switches, and actions of relays based on the settings, and
- Plotting generator and motor speed, current, voltage, and power curves after postulated disturbances.

II-19. Breaker operating characteristics, synchronous machine behaviour and system interconnections can be optimized using computer based transient stability analysis.

## LIGHTNING PROTECTION AND SYSTEM GROUNDING STUDIES

II-20. A lightning protection system is a system designed to protect a structure from damage due to lightning strikes by intercepting such strikes and safely passing their extremely high voltage currents to ground. The voltage from a lightning strike rises very rapidly, typically to its peak in a few millionths of a second. This energy has to be returned to ground very quickly through a low impedance path to preclude equipment damage and injury of personnel.

II-21. Most external systems for lightning protection consist of an air terminal, down conductor and grounding terminal including a network of lightning rods, metal conductors, and ground electrodes connected to station ground mat to provide a low resistance path to ground for potential lightning strikes. The internal system for lightning protection will include lightning equipotential bonding, electrical insulation of the external system and a surge protective device.

II-22. In any generating station there are generally four conceptually identifiable, but not necessarily physically distinct, grounding systems: personnel safety, lightning, electrical system and I&C — including signal grounding. All grounding systems are finally tied to one grounding grid.

II-23. Typically, international standards recommend that the grounding electrode resistance of large electrical substations be 1 Ohm or less.

II-24. Factors that affect lightning protection schemes include:

- Plant ground mat design,
- Soil resistivity, and
- Lightning rod design (copper clad, coated, other noble materials, size and depth, etc.)

II-25. A well designed station grounding system is essential for protection of power plant equipment from ground faults and lightning strikes.

#### ELECTROMAGNETIC COMPATIBILITY STUDIES

II-26. International electromagnetic compatibility standards on industrial environments may serve as the basis for the requirements provided that they are supplemented, where necessary, to cover the electromagnetic compatibility environments of generating power plant components, which might be more demanding. Results of such a study would be the emission level envelope with frequency spectrum and the susceptibility level envelope with frequency spectrum.



DRAFT

## DEFINITIONS

*The following definitions apply for the purposes of this Safety Guide only, unless otherwise stated, and are not included in the IAEA Safety Glossary [22].*

**Alternate AC power source.** Dedicated power source that could be used as power supply to the plant during total loss of all non-battery power in the safety power systems (station blackout) and other design extension conditions.

**Controlled state.** Plant state, following an anticipated operational occurrence or accident conditions, in which the fundamental safety functions can be ensured and which can be maintained for a time sufficient to implement provisions to reach a safe state (from SSR 2/1).

**Preferred power supply.** The power supply from the transmission system up to the safety classified electrical power system. It is composed of transmission system, switchyard, main generator and distribution system up to safety classified electrical power system. Some portions of the preferred power supply are not part of the safety classification scheme.

**Safe state.** Plant state, following an anticipated operational occurrence or accident conditions, in which the reactor is subcritical and the fundamental safety functions can be ensured and stably maintained for long time (from SSR 2/1).

**Station blackout.** Plant condition with complete loss of all AC power from off-site sources, from the main generator and from standby AC power sources important to safety. DC power and uninterruptible AC power are available as long as batteries can supply the loads. Alternate AC power can be available.

DRAFT

## CONTRIBUTORS TO DRAFTING AND REVIEW

Auvinen, K.	Forsmark nuclear power plant, Sweden
Diaz, E.	Comisión Nacional de Energía Atómica, Argentina
Dubois, A.	Institut de Radioprotection et de Sûreté Nucléaire, France
Fredlund, L.	Ringhals AB, Sweden
Frey, W.	Gesellschaft für Anlagen- und Reaktorsicherheit, Germany
Giannelli, I.-A.	ENEL Engineering and Research Division — ATN, Italy
Givaudan, B.	EDF, France
Goodney, D.	Constellation Energy, United States of America
Johnson, G.	International Atomic Energy Agency
Jordan, R.	Westinghouse Electric Company, United States of America
Kiger, C.	Analysis and Measurement Services Corporation, United States of America
Kim, B.-Y.	Korea Institute of Nuclear Safety, Republic of Korea
Knutsson, M.	Ringhals AB, Sweden
Krastev, E.	Kozloduy nuclear power plant, Bulgaria
Lamell, P.	Forsmark nuclear power plant, Sweden
Lindner, L.	ISTec, Germany
Lochthofen, A.	Gesellschaft für Anlagen- und Reaktorsicherheit, Germany
Matharu, G.	United States Nuclear Regulatory Commission, United States of America
Mathew, R.	United States Nuclear Regulatory Commission, United States of America
Mauhin, B.	Tractebel Engineering GDF Suez, Belgium
Meiss, S.	Bundesamt für Strahlenschutz, Germany
Padin, C.	Comisión Nacional de Energía Atómica, Argentina
Rogers, A.	Private consultant, Canada
Sarwar, T.	Pakistan Atomic Energy Commission, Pakistan
Schnuerer, G.	ISTec, Germany
Sobott, O.	AREVA, Germany
Yonezawa, T.	Energis, Japan
Zhu, O.-P.	Korea Institute of Nuclear Safety, Republic of Korea