TITLE DPP DS-503

Protection against Internal and External Hazards in the Operation of Nuclear Power Plants

COMMENTS BY REVIEWER Reviewer: Civil & Site Studies Group, CNS Page.... of.... Country/Organization: Pakistan Date:				RESOLUTION			
Comment No.	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection
1.	7(2)/ Page 4	7(2) External hazards **Clogging of water intake and ultimate heat sink (UHS) due to sedimentation and debris.**	This external hazard associated with flooding event may also be added. The extreme flooding event may carry along with a lot of sedimentation & debris and that may cause clogging of water intake/ out fall and ultimate heat sink and resulting in serious challenges to heat removal capability.				