

TITLE : Japan Comments for DPP-DS 485 DPP in version 5

COMMENTS BY REVIEWER				RESOLUTION			
Reviewer: NRA		Page 1 of					
Country/Organization: Japan/NRA		Date: 10 Oct. 2014					
Comment No.	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection
1	General	<ul style="list-style-type: none"> ▪ Basically, the review for ‘ageing management’ and ‘LTO’ are different concept so it should be considered separately and carefully for drafting. ▪ ‘Ageing management’ is a management review for future aged plants including the plant maintenance program, and it should be also organized with PSR. ▪ On the other hands, ‘LTO’ is related to update for plant license and it includes update license from old technology, reflecting new technical standards etc. ▪ In Japan, from the aftermath of the Tepco Fukushima Dai-ichi NPPs accidents, we established the codes and standards as followings: <ul style="list-style-type: none"> – Operating period: max. 40 years. – Approve additional 20 years based upon the latest technical standards and specific inspections as LTO. – In parallel with the above, technical review for over 30 years plants are introduced separately. 					
2	TOC	2. BASIC CONCEPTS Ageing management Obsolescence management Programme for long term operation	Duplicated in sec. 3. “Long term operation”.				