## DS 541 – Assessment of Meteorological and Hydrological Hazards in Site Evaluation for Nuclear Installations Comments Resolution Table – NUSSC Step 7

COMMENTS BY REVIEWER					RESOLUTION			
Reviewer:	<b>ROELANDT</b> Caroline	& BERNIER						
Frédéric								
Page of								
Country/Or	ganization: Federal A	gency For Nuclear Control.						
Belgium		geney i of i defear control,						
Date: May 9	8 <sup>th</sup> 2025							
Comment	Para/Line No	Proposed new text	Reason	Accepted	Accepted but	Rejected	Reason for	
No	Tara/Line 100.	r toposed new text	Reason	Accepted	modified as follows	Rejected	modification/rejection	
1	1.10 two last lines	Add a sentence acknowledging that the guidance provided remains relevant for radioactive waste management facilities including disposals, especially during their operational phase, when they host radioactive material and are exposed to meteorological and hydrological hazards that may affect both operational safety and the long-term performance of the facility.	While the Safety Guide focuses on nuclear installations as defined in the IAEA Safety Glossary (2018 Edition), it may be helpful to acknowledge that the guidance provided could also support the evaluation of meteorological and hydrological hazards for <b>radioactive waste</b> <b>management facilities</b> <b>including disposals</b> , particularly during their <b>operational phase</b> . At this stage, the facility — remaining exposed to meteorological and hydrological hazards prior to closure — could face risks that impact both operational and long-term performance of the facility.				Added this consideration as a footnote to para 1.10-	
2	1.12	Refer to the IAEA's definition, as outlined in the Safety Glossary (2018 Edition) of "external event":	Add reference to IAEA glossary for clarity			1	Paragraph 1.9 states that the terminology used in this document refers to	

COMMENTS BY REVIEWER					RESOLUTION				
Reviewer: ROELANDT Caroline & BERNIER									
Frédéric									
Page of									
Country/Or	ganization: Federal Ag	gency For Nuclear Control,							
Belgium									
Date: May	8 <sup>th</sup> 2025								
Comment No.	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection		
		Events unconnected with the operation of a facility or the conduct of an activity that could have an effect on the safety of the facility or activity.					the IAEA Safety and Security Glossary.		
3	After 2.13 (new paragraph proposed)	Add "Combination of hazards 2.14 In addition to assessing individual hazards, combined events and cascading effects should be systematically identified. This can be achieved, for example, by developing a matrix that maps potential combinations between meteorological, hydrological, and other natural phenomena, along with their possible amplification effects. Particular attention should be given to realistic sequences in which an initial event may significantly worsen the consequences of secondary phenomena."	While the guide acknowledges that multiple phenomena may occur simultaneously or sequentially, no structured approach is currently proposed to identify their combinations and cascading impacts. Past events (e.g., Fukushima Daiichi accident) have demonstrated that the most critical risks often arise not from a single hazard, but from a sequence of coupled events leading to compounded failures. Introducing a systematic combination and cascading effect analysis would significantly enhance the comprehensiveness and robustness of hazard assessments.				Paragraph addressing combinations has been added.		

COMMENTS BY REVIEWER					RESOLUTION				
Reviewer: ROELANDT Caroline & BERNIER									
Frédéric									
Page of									
Country/Or	ganization: Federal Ag	gency For Nuclear Control,							
Belgium	6	, , , , , , , , , , , , , , , , , , ,							
Date: May	8 <sup>th</sup> 2025								
Comment	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but	Rejected	Reason for		
No.					modified as follows		modification/rejection		
		Reassess the numbering in this section to ensure coherence following the inclusion of an additional bullet point.							
4	2.13	Add "d) Extended licensing period compared to initial projections."	While the guide correctly states that foreseeable changes in hazards over the lifetime of the installation should be considered, it does not explicitly acknowledge the fundamental uncertainty surrounding the actual duration of operation. In practice, installations may be extended far beyond initial licensing periods.				The necessity of a Periodic Safety Review (PSR) is described in SSR-1, and references to PSR and license renewal are also included in SSG-48. The guidelines provided in SSG-18 cover hazard assessments that serve as inputs for PSR and license renewal. Therefore, the use of this guideline in the context of PSR and license renewal is clear from the requirements of SSR-1.		
5	2.13	c) geological or- geomorphological processes, which may also lead to changes in hazards over time (e.g. uplift or subsidence, sediment transport).	Consider clarifying that the evaluation of geological or geomorphological processes should be limited to those that can realistically affect the installation during its operational and post- operational phases, in line with the scope defined in 1.10 and 1.11. Very slow geological changes (e.g.,				"Changes in hazards over time" is understood to mean over the expected lifetime of the nuclear installation. Specific reference to tectonic uplift has been changed to "uplift".		

	COMM	ENTS BY REVIEWER			RESC	DLUTION	
Reviewer: ROELANDT Caroline & BERNIER							
Page of							
Country/Or	 ganization: Federal Ag	ency For Nuclear Control					
Belgium		cency i or inderear condor,					
Dergrunn Date: May 9	8 <sup>th</sup> 2025						
Comment	Para/Line No	Proposed new text	Peason	Accented	Accepted but	Pajacted	Reson for
No.	T ara/Line 100.	T toposed new text	Reason	Ассериси	modified as follows	Rejected	modification/rejection
			tectonic uplift over millennia) should not be considered.				
6	3.25 / lines 1 -3	"Observational, historical or paleo-climatic records might not fully capture future climate and extreme event conditions due to climate change. Therefore, these records should be supplemented or extended by using outputs from climate models "	Refined for improved clarity	J			Instead of "paleo- climatic records," the term "paleo information" is used, as it is used consistently throughout this document.
7	4.7/lines 2-5	Replace by "Extreme air temperatures and high atmospheric moisture content (resulting in increased enthalpy) could impair the performance of heating, ventilation, and air conditioning (HVAC) systems that maintain environmental conditions in rooms housing safety- important equipment (especially electronic devices), and could also affect the availability of the ultimate heat sink."	Reworded to enhance precision		✓ Extreme air temperatures and high atmospheric moisture content (resulting in increased enthalpy) could impair the performance of heating, ventilation, and air conditioning systems that maintain environmental conditions of rooms housing items important to safety (especially electronic devices) and could also affect the availability of the ultimate heat sink.		Abbreviation was removed, and the terminology was reviewed.

COMMENTS BY REVIEWER					RESOLUTION				
Reviewer: ROELANDT Caroline & BERNIER									
Frédéric									
Page of									
Country/Or	α anization: Federal Aα	ency For Nuclear Control							
Belgium		ency for rucical control,							
Doto: Mov 9	2th 2025								
Date. May a		Dream a ser di se ser starret	Desser	Assessed	A second at here	Daiaatad	Daaran fan		
No	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	modification/rejection		
8	49	Replace by "If a statistical	Adjusted for better readability	./			The revision was made		
0		approach is followed a	Adjusted for better readability	v			according to the		
		dataset of daily maximum					comments.		
		and minimum air							
		temperatures (representing							
		the extreme recorded							
		temperatures each day)							
		should be collected. This							
		dataset can be used to derive							
		either annual maximum and							
		minimum values (block							
		maxima method) or							
		temperature values							
		thresholds (peak over							
		threshold method) These							
		data provide the foundation							
		for the statistical analysis."							
9	5.3	Add "When evaluating	The current text does not		1		This has been reflected		
		storm surge hazards,	explicitly address the possible		When evaluating		in paragraph 5.4.		
		interactions with other	amplification of storm surge		storm surge hazard, a				
		concurrent phenomena —	hazards due to interactions		reference water level,				
		such as tidal cycles, heavy	with other concurrent		such as tidal cycle or				
		precipitation, river flooding,	phenomena, such as tidal		high lake level,				
		and wave set-up — should	effects, heavy precipitation,		should be assumed to				
		be carefully considered, as	river flooding, or wave set-up.		occur coincidently				
		these combinations may	These interactions can		with the storm surge.				
		significantly amplify the	significantly worsen the		In addition,				
		overall hazard at the site.	Hooding hazard. It is		interactions with				
		Appropriate models or	nerograph 5.2 by available		other concurrent				
		should be used to represent	requiring that potential		pnenomena such as				
		should be used to represent	concurrent effects be		river flooding and				
			concurrent cricets be		river mooning, and				

	COMM	ENTS BY REVIEWER			RESC	DLUTION	
Reviewer:	ROELANDT Caroline &	& BERNIER					
Fieueric Deserved							
Page of							
Country/Or	ganization: Federal Ag	gency For Nuclear Control,					
Belgium							
Date: May 8	8 <sup>th</sup> 2025						
Comment	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but	Rejected	Reason for
No.				_	modified as follows	-	modification/rejection
		such interactions where	considered in the evaluation		wave set-up should be		
		relevant."	and that appropriate models or		considered, as these		
			conservative assumptions be		combinations may		
			applied when such interactions		amplify the overall		
			are possible.		hazard at the site.		
10	5.87	Add "The evaluation should	While paragraphs 5.87–5.89	1			The revision was made
		consider both the direct	provide a general framework				according to the
		effects of local precipitation	for evaluating precipitation-				comments.
		on the site and indirect	induced flooding hazards,				
		effects from upstream	several critical factors are not				
		watershed runoff, while	explicitly addressed. These				
		taking into account the	include the effects of				
		potential for concurrent	antecedent soil saturation,				
		offacts (a.g., precipitation	events rain on snow events				
		coinciding with saturated	and the presence of flow				
		soil conditions or with high	obstructions (e.g. debris or ice				
		river stages) "	iams) Moreover, there is no				
		iiver suges).	mention of the quantification				
			of uncertainties associated				
			with hydrologic and hydraulic				
			modeling, particularly in the				
			context of future climatic				
			changes. Incorporating these				
			elements would significantly				
			strengthen the robustness of				
			the hazard evaluation, align				
			the methodology, and provide				
			clearer guidance to ensure				
			conservative and				
			comprehensive site				
			assessments. It is				
			recommended to enrich				

	COM	MENTS BY REVIEWER			RESC	DLUTION	
Reviewer:	<b>ROELANDT</b> Caroline	& BERNIER					
Frédéric							
Page of							
Country/Or	rganization: Federal A	Agency For Nuclear Control,					
Belgium	-						
Date: May	8 <sup>th</sup> 2025						
Comment	Para/Line No	Proposed new text	Reason	Accepted	Accepted but	Rejected	Reason for
No.		rioposed new text	Reuson	riccepted	modified as follows	Rejected	modification/rejection
1.01			paragraphs 5.87–5.89 accordingly.				
11	5.88	Replace by "An extreme precipitation event is characterized by heavy rainfall, snowfall, or other 	See paragraphs 5.87–5.89				All of these considerations are addressed, although not in a single paragraph.

COMMENTS BY REVIEWER					RESOLUTION				
Reviewer:	<b>ROELANDT</b> Caroline	e & BERNIER							
Frédéric									
Page of									
f age 01	 	A gap av Ean Nuclean Control							
Country/Of	gamzation. rederal	Agency For Nuclear Control,							
Belgium	oth a car								
Date: May	8 <sup>th</sup> 2025					1	1		
Comment No.	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection		
		events) should be assessed. Furthermore, the possibility of obstructions (e.g., debris jams, ice jams) influencing runoff and flood behavior should be considered."							
12	5.89	Replace by "Flooding conditions at the site should generally be characterized using two successive steps. The first step involves the simulation of hydrologic processes such as precipitation, snowmelt, evaporation, infiltration, and surface runoff, to determine river discharge and overland flow. The second step involves hydraulic modeling to determine the flooding conditions at the site (e.g., water elevation, water velocity, duration of inundation). Where sufficiently long and reliable records of river discharge exist, hydrologic simulation may be replaced or supplemented by analysis of observed data. The evaluation should explicitly quantify and document the uncertainties associated with	See paragraphs 5.87–5.89				Replaced last sentence of paragraph with "Where sufficiently long and reliable records of river discharge exist, hydrologic simulation may be replaced or supplemented by analysis of observed data." Uncertainties are addressed elsewhere in the text.		

	COMMI	ENTS BY REVIEWER			RESC	DLUTION	
Reviewer:	ROELANDT Caroline &	z BERNIER					
Frédéric							
Page of							
Country/Or		ency For Nuclear Control					
Belgium		ency for ruelear control,					
Doto: Mov S	eth 2025						
Date. May a		Draw and reserve to set	Danaar	Assessed	A second and here	Deiested	Deesen for
No	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but	Rejected	Reason for modification/rejection
110.		hydrologic and hydroulic			mounned as follows		mouncation/rejection
		modeling particularly when					
		projecting future scenarios					
		under changing climatic					
		conditions."					
13	5.119	Add at the end of the	Paragraph 5.119 does not	✓			Added the suggested
		paragraph "In either case,	explicitly refer to the impact of				sentence along with a
		future changes in climatic	climate change on future flood				pointer to Section 9
		conditions — including	scenarios. Given the well-				which specifically
		potential increases in the	documented influence of				addresses climate
		frequency and intensity of	climate change on extreme				change.
		extreme precipitation and	hydrological events, it is				
		flooding events — should be	recommended to include a				
		evaluation in line with	projected changes in climatic				
		current scientific	conditions are considered in				
		understanding and available	site-specific flood hazard				
		projections."	evaluations.				
14	Chapter 5 (general), or	It is recommended to add a	While climate change and		✓		Addressed in response
	specifically paras 5.119	general statement reminding	climatic variability are		-		to previous comment.
	and/or 5.122	that all flood hazard	addressed later in Chapter 9				1
		evaluations — including	and in Annex IV, Chapter 5				
		those based on hydraulic	lacks explicit reminders to				
		modelling at the site (paras	integrate future climate				
		5.107–5.121) and those	conditions into hydraulic and				
		related to sudden release of	flooding hazard evaluations.				
		5 122 5 130) should	for design basis flood				
		consider projected future	assessments and for cascading				
		changes in climatic	failure scenarios involving				
		conditions. These may	dams, ice jams, and glacial lake				
		include changes in the	outbursts — all of which may				
		frequency, intensity, and	become more frequent or				

	COMM	ENTS BY REVIEWER	RESOLUTION				
Reviewer:	ROELANDT Caroline	& BERNIER					
Frédéric							
Page of							
Country/Or	ganization: Federal Ag	gency For Nuclear Control,					
Belgium							
Date: May a	8 <sup>m</sup> 2025		Γ				
Comment No.	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection
		spatial distribution of extreme precipitation events, snowmelt patterns, and other hydrometeorological drivers, as informed by available climate projections.	intense under changing climate conditions. Including such a reference would reinforce consistency with climate- resilient safety planning and align Chapter 5 with the forward-looking scope of the rest of the Safety Guide.				
15	6.1 -6.6	Add in the paragraph an explicit reference to the role of climate change in increasing wildfire risk	This section on wildfires (paras 6.1–6.6) addresses the physical mechanisms and potential impacts in a comprehensive manner. However, it currently lacks an explicit reference to the role of climate change in increasing wildfire risk — an omission that may undermine the forward-looking nature of hazard assessment.		•		Sentence on considering climate and land use change added to para 6.2
16	6.2	Add at the end of the paragraph: "Particular attention should be paid to regions where climate change is expected to increase the frequency or intensity of wildfires, for example due to prolonged droughts or higher summer temperatures."	Short reminder in para. 6.2 regarding the expected influence of climate change on wildfire regimes.		✓		Sentence on considering climate and land use change added to para 6.2
17	6.4 line 3-4	Replace last sentence by "If this likelihood is considered sufficiently high — for example, based on historical	The vague criterion "sufficiently high likelihood" in para. 6.4 would benefit from clarification (e.g., using	<i>✓</i>			The revision was made according to the comments.

COMMENTS BY REVIEWER					RESOLUTION				
Reviewer:	ROELANDT Caroline &	& BERNIER							
Frédéric									
Page of									
Country/Or	 ganization: Federal Ag	gency For Nuclear Control							
Belgium		geney i or i delear control,							
Dete: May	8 <sup>th</sup> 2025								
Commont	Dara/Lina No	Proposed new text	Passon	Accopted	Accorted but	Paiactad	Passon for		
No.	I ala/Line No.	T toposed new text	Keason	Accepted	modified as follows	Rejected	modification/rejection		
		fire frequency, fire danger indices, proximity of vegetation, and prevailing wind patterns — the hazard to the nuclear installation should be evaluated."	historical data, vegetation proximity, fire danger indices).						
18	6.6	Add at the end of b):: "These secondary hydrological effects may be long-lasting and should be accounted for in multi-hazard scenarios affecting the site."	The paragraph highlights the fact that wildfires can increase flooding and erosion risks by altering vegetation cover and soil stability. However, the persistence of these secondary effects is not explicitly mentioned, nor is their relevance to multi-hazard risk scenarios. The proposed addition would strengthen the section by encouraging the analyst to consider the long- term and compounding nature of wildfire impacts, particularly in combination with intense rainfall or flood events.				The revision was made according to the comments.		
19	7.8 last line	Replace last sentence by "Annex I contains example sets of meteorological design basis parameters used for nuclear installations. In addition, the evaluation of meteorological hazards and their combinations should consider potential changes in	The paragraph does not mention that the frequency or intensity of such events may evolve over time due to climate change. Including a reference to this dynamic context would strengthen the guidance, especially considering the long lifetime of nuclear installations				Paragraph 7.9 has been revised in line with the comment. This seems to overlap with that revision.		

COMMENTS BY REVIEWER					RESOLUTION				
Reviewer: ROELANDT Caroline & BERNIER									
Fieueric									
Page of									
Country/Or	ganization: Federal	Agency For Nuclear Control,							
Belgium									
Date: May	8 <sup>th</sup> 2025								
Comment No.	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection		
		frequency and intensity due to climate change, especially over the expected lifetime of the installation."	and the growing scientific consensus on the changing nature of extreme weather patterns. This addition would also improve alignment with Section 9 and Annex IV.						
20	7.9 line 4-6	Replace the two last sentences by "Consideration should be given to the potential for variability of hazard parameters over long time periods, including changes induced by climate change (e.g. increased air temperature, altered wind and precipitation patterns, increased frequency of extreme events), based on the expected lifetime of the nuclear installation. This consideration should be informed by the recommendations provided in Section 9 and relevant climate projections."	This paragraph does not explicitly mention climate change as a key driver of such variability. Given that changes in temperature, precipitation, and wind patterns are increasingly documented in climate assessments, and that these changes can affect the severity and frequency of design basis meteorological events, it is recommended to explicitly refer to climate change. This would ensure consistency with Section 9 and reinforce the need to use up-to- date climate projections in the derivation of design parameters.				The revision was made according to the comments.		
21	7.9	Add at the end of the paragraph "As a reference, an annual exceedance frequency of $10^{-4}$ per year (i.e. a 10,000-year return period) is often used for external events in design basis hazard assessments, as	The paragraph does not provide a reference frequency to guide users in selecting a target exceedance probability. Several IAEA Safety Guides (e.g. SSG-68, SSG-18) refer to an annual exceedance frequency of 10 <sup>-4</sup> per year as a				Including specific numerical values in the main text is to be avoided.		

	COMM	IENTS BY REVIEWER			RESC	DLUTION	
Reviewer: ROELANDT Caroline & BERNIER							
Frédéric							
Page of							
Country/Or	ganization: Federal A	gency For Nuclear Control.					
Belgium	6	<u> </u>					
Date: May	8 <sup>th</sup> 2025						
Comment	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but	Rejected	Reason for
No.					modified as follows		modification/rejection
		reflected in SSG-68 and SSG-18. This target frequency should be confirmed or adapted based on national regulatory guidance."	conservative basis for external events such as flooding or extreme meteorological phenomena. Adding this information would provide clarity and promote consistency in the derivation of design parameters, especially where national standards are				
			not explicitly defined.				
22	8.1 line 1	Replace opening phrase to: "This section <b>provides</b> recommendations on measures for protecting a nuclear installation site"	Grammatical correctness				The revision was made according to the comments.
		Suggested rephrasing of the text in parentheses: "such as wildfires and flooding from nearby water bodies (i.e., situations where physical exclusion of the hazard from the site is feasible)."	The text within parentheses could be modified to improve clarity by explicitly stating the principle of physical exclusion, which is central to site protection logic.				Removed parenthetical.
23	8.3	Add a sentence at the end of 8.3 "Periodic safety reviews (PSRs), as required in SSR-1 [1], should be used to reassess site protection measures in light of evolving hazard information, new scientific knowledge (e.g.	Paragraphs 8.1–8.3 do not mention periodic safety reviews (PSRs), which are mandated in SSR-1 (Requirement 21). PSRs provide a systematic framework for verifying that protection measures remain appropriate over time and	<b>√</b>			The revision was made according to the comments.

	COM	MENTS BY REVIEWER	RESOLUTION				
Reviewer: ROELANDT Caroline & BERNIER							
Frédéric							
Page of							
Country/Or	ganization: Federal A	Agency For Nuclear Control,					
Belgium							
Date: May	8 <sup>th</sup> 2025						
Comment No.	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection
		climate change projections), and operational experience."	under changing external conditions. Referencing SSR-1 here would reinforce the link between site hazard protection and the regulatory requirement for long-term safety assurance through periodic reassessment. This is particularly relevant in the context of uncertainties in hazard evolution and the need for adaptive risk management.				
24	9.6 line 4-5	Replace second sentence by: "The planned operating lifetime of a nuclear power plant is assumed to be <b>approximately</b> 100 years. "	Tipping error (correction in bold)		<i>√</i>		The statement was revised and moved to a footnote.
25	Annex IV - 3	Add: "(c) Early detection of emerging climate trends that may diverge from initial projections, enabling proactive safety measures. (d) Enhanced robustness of hazard assessments through iterative data integration, helping reduce uncertainty margins. (e) Stronger alignment with safety review processes such as the Periodic Safety Review (PSR) by	It is recommended to expand the discussion on the benefits of periodically updated climate change information beyond the two advantages currently listed. In addition to improving the spatial and temporal identification of expected changes and refining order-of- magnitude estimates for extreme events, regularly updated datasets enable: (i) early detection of emerging trends that may deviate from initial projections; (ii)				The revision was made according to the comments.

	COMM	ENTS BY REVIEWER			RES	OLUTION	
Reviewer: ROELANDT Caroline & BERNIER							
Frédéric							
Page of							
Country/Or	 ganization: Eaderal A	ancy For Nuclear Control					
Dolaium	gamzation. Tederal Ag	gency for Nuclear Control,					
Belgium							
Date: May 8	3 <sup>cm</sup> 2025					T	
Comment	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but	Rejected	Reason for
No.					modified as follows		modification/rejection
		supporting reassessment of	term hazard assessments by				
		design margins based on the	reducing uncertainty margins;				
		most recent climate signals."	and (iii) stronger alignment				
			with regulatory instruments				
			such as Periodic Safety				
			Reviews (PSRs), where				
			updated climate signals can				
			help assess whether existing				
			protection measures remain				
			adequate.		1		
26	IV - 6	Replace by "The Coupled	The original description of				Resolution Pending.
		Model Intercomparison	RCPs and SSPs inaccurately				Will be addressed
		Project (CMIP) brings	suggests that RCPs are based				during Step 8.
		together contributions from	on socioeconomic assumptions				
		numerous climate modelling	and that SSPs represent an				
		centres around the world. As	"improvement" of RCPs. In				
		a result, the norizontal	lact, RCPs are concentration-				
		resolution of models varies,	based scenarios with				
		typically between 50 km and	predefined radiative forcing				
		CMD are widely used in	trajectories, independent of				
		confir ale widely used in	socio-economic context. SSFS,				
		major chinate assessments,	distinct				
		Intergovernmental Panel on	nathways and can be combined				
		Climate Change (IPCC)	with RCPs to form fully				
		reports to support global	integrated scenarios The				
		climate policy and decision-	revised version clarifies the				
		making	nature and relationship of these				
		Two key scenario	scenario frameworks in line				
		frameworks are used in	with the definitions used in the				
		CMIP:	IPCC Sixth Assessment				
		Representative	Report.				
		<b>Concentration Pathways</b>	<b>1</b> • · · ·				
		Climate Change (IPCC) reports, to support global climate policy and decision- making. Two key scenario frameworks are used in CMIP: <b>Representative</b> Concentration Pathways	with RCPs to form fully integrated scenarios. The revised version clarifies the nature and relationship of these scenario frameworks, in line with the definitions used in the IPCC Sixth Assessment Report.				

COMMENTS BY REVIEWER					RESOLUTION				
Reviewer: ROELANDT Caroline & BERNIER									
Frédéric									
Page of									
Country/Or	ganization: Federal Ag	gency For Nuclear Control.							
Belgium	B	,,,,,,							
Date: May 8	S <sup>th</sup> 2025								
Comment	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but	Rejected	Reason for		
No.		rioposed new text	i i cuson	riccopica	modified as follows	rejected	modification/rejection		
		(RCPs) are trajectories of							
		greenhouse gas							
		concentrations that							
		correspond to specific levels							
		of radiative forcing by the							
		year 2100 (e.g. 2.6, 4.5, 6.0,							
		$8.5 \text{ W/m}^2$ ). These pathways							
		are not based on specific							
		socio-economic							
		assumptions.							
		<b>Dathways</b> (SSPs) describe							
		alternative socio-economic							
		futures including narratives							
		and quantitative projections							
		for variables such as							
		population, economic							
		growth, and technological							
		development. SSPs can be							
		combined with RCPs to							
		generate integrated climate							
		scenarios (e.g. SSP2-4.5 or							
		SSP5-8.5), allowing for a							
		broader and more consistent							
		exploration of future climate							
		and societal conditions."							
27	IV – 11	Add at the end of the	Consider expanding the current				Resolution Pending		
21	1 7 - 11	naragraph " (e) Some	summary of IPCC AR6				Will be addressed		
		climate-related impacts.	conclusions to reflect				during Step 8.		
		such as sea level rise and	additional findings relevant to				stop of		
		icesheet melt, are now	nuclear site safety evaluations.						
		unavoidable and irreversible	This includes (1) the long-						

	COMMI	ENTS BY REVIEWER	RESOLUTION				
Reviewer:	ROELANDT Caroline &	z BERNIER					
Frédéric							
Page of							
Country/Org	ganization: Federal Ag	ency For Nuclear Control,					
Belgium							
Date: May 8	8 <sup>th</sup> 2025						
Comment	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but	Rejected	Reason for
No.					modified as follows		modification/rejection
		over centuries to millennia.	term irreversibility of certain				
		These long-term trends	climate impacts such as sea				
		lifetime assessments and	increase in compound and				
		infrastructure design	cascading extreme events.				
		margins.	and (3) the need to rely on				
		(f) Compound and cascading	ensembles of downscaled				
		events (e.g. concurrent	regional models to reduce				
		heatwaves and droughts, or	uncertainty in hazard				
		storms and coastal surges)	projections.				
		frequency and intensity					
		Such scenarios should be					
		integrated into hazard					
		combinations and stress					
		testing.					
		(g) Given the uncertainty in					
		regional climate projections,					
		using multiple models,					
		downscaled datasets, and					
		recommended to ensure					
		robust hazard evaluation and					
		conservative design					
		margins."					
28	FIG IV 1 Trands in alabal	Add references	Source references are missing				Resolution Pending
20	mean temperature anomalies	Add telefences	Source references are missing.				Will be addressed
	(relative to 1850-1900).						during Step 8.

	COMMENTS BY REVIEWER					DLUTION	
Reviewer:	ROELANDT Caroline &	E BERNIER					
Frédéric							
Page of							
Country/Org	ganization: Federal Ag	ency For Nuclear Control,					
Belgium		-					
Date: May 8	8 <sup>th</sup> 2025						
Comment	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but	Rejected	Reason for
No.					modified as follows		modification/rejection
29	FIG. IV-12 Observed Ocean	Correct the reference	The figure reference number is	1			The revision was made
	Heat Content from 1958 to	number	incorrect.				according to the
	2023 (upper 2000 m).						comments.
30	FIG. IV-2 <del>3</del> . Trend of global	Correct the reference	Source references are missing,				Resolution Pending.
	mean sea level between 1993-	number and add the source	and the figure reference				Will be addressed
	2023.		number is incorrect.				during Step 8.

		COMMENTS BY REVIEWER	RESOLUTION				
Reviewer: Page Country/C Date: 29 A	: Organization: April 2025	China					
Comment	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection
1	para 5.132	(d) Capacity (e.g. <del>reservoir volumestage- capacity curve</del> );	Editorial It is suggested to change "reservoir volume" to "stage- capacity curve". This term is more accurate and professional.		✓ The following sentence was added to paragraph 5.148. The stage–capacity curve, which defines the relationship between the water surface elevation (stage) and the stored volume in the reservoir, should be used to estimate the available water volume at the time of failure.		While the term "stage-capacity curve" is technically valid, "reservoir volume" is more appropriate in this context, as it refers to a basic parameter suitable for initial evaluations. Instead, recommendation for stage–capacity curve was added in the para. 5.148.
2	para 3.40	(c) Modification in water resource use(e.g. aquaculture);	Editorial It is suggested to add a paragraph. Because aquaculture will change the amount of aquatic organisms and debris in the water body.		✓ (b) Modifications in the watershed associated with structures such as dams and reservoirs, weirs and locks, levees and other flood protection structures along rivers, diversions into or out of the basin, flood ways, channel improvements and modifications (e.g. dredging), bridges and transport embankments, and water-related developments (e.g. aquaculture).		In SSR-1, the term "the present and future use of land and water" is used, and the suggested topic of aquaculture can be considered a part of water use. Therefore, instead of adding a new paragraph, a reference to aquaculture has been included in the explanation.
3	para 4.36 footnote	However, certain locations (e.g. locations atlow latitudes) may need a larger area of inspection	Editorial It is suggested to add a note. Considering that with the same are, the latitude and longitude scope in low-latitude regions is relatively smaller. Locations at low latitudes may need a larger area of inspection.			$\checkmark$	This footnote describes how the investigation area is defined based on factors such as the characteristics of tornadoes and the homogeneity around the site. It is not intended to explain any apparent increase or decrease in area based on

		COMMENTS BY REVIEWER		RESOLUTION				
Reviewer: Page Country/C Date: 29 A	: Organization: April 2025	China						
Comment No	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection	
							latitude and longitude coordinates.	
4	para 6.13	Expected potential impacts from these biological species on the nuclear installation(e.g. biological thermotaxis habit)	Editorial It is suggested to add "e.g. biological thermotaxis habit" to explain how organisms affect the water intake of nuclear facilities.	1			<ul> <li>"biological thermotaxis " was added in (b).</li> <li>(b) Potential initiators that can bring the debris to the site (e.g. marine currents, high river flow, winds, biological thermotaxis in organisms);</li> </ul>	
5	para 5.109	Add : Tropical cyclones can bring storm surge and rainfall at the same time, and coastal watershed flooding needs to be considered for both hazards.	Editorial Coastal watersheds are affected by both storm surge and rainfall and should to be considered in watershed flood analysis.		✓ 5.4 "When evaluating storm surge hazard, a reference water level, such as tidal cycle or high lake level, should be assumed to occur coincidently with the storm surge. In addition, interactions with other concurrent phenomena such as heavy precipitation, river flooding, and wave set-up should be considered, as these combinations may amplify the overall hazard at the site "		Combination of storm surge and precipitation was added in the Para. 5.4.	
6	1.4/Gener al	It is recommended that the special requirement for offshore location and transportation should be given clearly	the DS541 include new reactor site such as offshore location and transportation, as the site evaluation for offshore/ transportable reactor is different between stationary reactor			$\checkmark$	Regarding site evaluation and the consideration of external events for FNPP and TNPP, a revision of SSR-1 is planned to describe overall concept of site evaluation for those. Within the scope of SSG-18, hazards applicable to FNPP, such as tsunami, storm surge, wave action, and icebergs have	

		COMMENTS BY REVIEWER	RESOLUTION				
Reviewer:							
Page							
Country/C	organization:	China					
Comment	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection
							been considered, but detailed guidance is not provided since there is little practical experience with this type of facility. Likewise, detailed guidance is not provided TNPP, since there is little practical experience with this type of facility, although certain aspects may be equivalent to those for
7	2.4	It is recommend the relevant requirements about climate change in this guide should be consistent with DS535 (PSR)	In this guide, the affect of climate change should be considered during PSR		√		stationary NPPs. DS535 was reviewed and found to be consistent with this guide (DS535 discusses the need to consider climate, but the detailed methods are in this guide). The connection to PSR is already addressed in paragraph 2.4. In addition, specific information is provided in Annex IV (IV-3).
8	2.12/6.26	The necessity of Meteoroids and meteorites should be further considered	Meteoroids and meteorites are the very rare event for land-based nuclear facility, it is should not include in site evaluation			✓ 	Consideration of these aspects is necessary; however, in most cases, they are expected to be screened out probabilistically. If the deployment of offshore NPPs is considered, the potential for tsunami generation due to objects falling into the sea should also be taken into account.
9	11.13	It is recommended some relevant standards or guide should be cited ,or some example should be given, to introduce the specific approach	The requirement of "risk informed approach" is very simple now ,			√	As part of the graded approach applied to site evaluation, the availability of a risk-informed approach has been described. This indicates that, for nuclear

		COMMENTS BY REVIEWER		RESOLUTION				
Reviewer:								
Page								
Country/C	rganization:	China						
Date: 29 A	pril 2025							
Comment	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection	
No.								
							installations with lower risk,	
							the level of detail in the site	
							evaluation may be optimized	
							through the use of a risk-	
							informed approach. It is	
							considered that this level of	
							description is appropriate for a	
							Safety Guide.	

		COMMENTS BY REVIEWER	RESOLUTION				
Reviewer: ENISS	Reviewer: ENISS members						
Page 1 of 25							
Country/Organiza	ation: EN	VISS					
Date: 19 May 202	25						
Comment Para No. N	ra/Line No.	Proposed new text	Reason	Acc epte d	Accepted, but modified as follows	Rejected	Reason for modification/rejecti on
1By providing clear and well-defined methodology for meteorological, hydrological and other natural hazard evaluation, SSG-18 significantly enhances its value and usability for its users—a contribution we greatly appreciate. The establishment of clear definitions for the various methods to be employed in the evaluation of hazards will enhance the comprehension and usability of SSG-18 among its users. The detailed comments outlined below are intended to further refine its applicability and			√				
2 General comment	ıt	Guidance should be provided or specifically referenced on how to deal with uncertainties in paragraph 9.6					Sentence added on model ensembles and downscaling
3 General comment		<ul> <li>Paragraph 9.7 should mention that regional, site-specific climate predictions must be considered for a fixed time frame and re-assessed with a specific frequency. This approach will take advantage of improvements and new knowledge in predictions, minimizing uncertainties.</li> <li>An example would be that models should provide relevant parameters for the following 10 years but in 5 years, models must be re-evaluated.</li> <li>Ensure that periodic review of data and models data, should be made</li> </ul>					Sentence added to mention updating climate projections as new information becomes available.
Ensure that periodic review of data and models data There is a clear distinction in the report between watershed scale precipitation (pages 30-32) and flo precipitation events (pages 55-69). The section of precipitation seems to miss some aspects such as the data and other possible methodologies (explained			eport between floods caused by 30-32) and floods due to extreme The section on watershed scale ects such as the use of discharge es (explained on pages 55-69 for			$\checkmark$	Section 4 discusses methods for assessing precipitation, while section 5

		COMMENTS BY REVIEWER		RESOLUTION				
Reviewer: E	ENISS memb	ers		ENISS				
Page 1 of	25							
Country/Or	ganization: E	NISS						
Date: 19 Ma	ay 2025							
Comment	Para/Line	Proposed new text	Reason	Acc	Accepted, but	Rejected	Reason for	
No.	No.			epte	modified as follows		modification/rejecti	
				d			On	
		extreme precipitation events), which	would not be screened when the				discusses now to	
		It is advised to combine these two part	niation.				use the	
		that includes all relevant information	s into one comprehensive section				precipitation	
		floodings	and include the entire range of				develop flood	
		noodings.					hazard	
							estimates	
5		The inclusion of different methods	deterministic statistical and			./	See previous	
General cor	nment	probabilistic) for most hazards is			·	comment		
General con	milent	differences in the results from these	approaches are not always clear				comment.	
		as seen in the watershed example of						
		sections 5.93 and 5.95 provide clear e	xplanations of the results of these					
		methods.	representations of the results of these					
6		The document seems to focus prin	narily on approaches, methods,			$\checkmark$	Experts from	
General cor	nment	definitions, and data availability o	f the United States. Including				Europe and Asia	
		examples, definitions and methodolog	gies from other parts of the world				were included in	
		could strengthen the guideline.	I I I I I I I I I I I I I I I I I I I				the drafting of	
							the document.	
7		It is understood that no design frequ	ency is advised for the different			$\checkmark$	The SRS-series	
General con	nment	hazards although some are mentione	d in the examples in annex. We				publications are	
		would suggest to add a, item on the	challenges of estimating the low				a more	
		frequencies of exceedance as illustration	ted in figure 33 (on page 91-92)				appropriate	
of the IAEA SRS-120 publication "assessment of high wind an							venue for such	
external flooding (excluding tsunami) hazards in site evaluation for							detailed	
		nuclear installations"					discussions.	
8		Exploratory Data Analysis is an	important part of quantitative			$\checkmark$	Specific	
General con	nment	analyses, especially of the statistical	l kind. In our estimation, more				guidance on	
		guidance about this analysis step may	provide valuable input.				EDA is beyond	

	COMMENTS BY REVIEWER					RESOLUTION			
Reviewer: E	ENISS member	ers		ENISS					
Page 1 of	25								
Country/Or	ganization: E	NISS							
Date: 19 Ma	ay 2025								
Comment No.	Para/Line No.	Proposed new text	Reason	Acc epte d	Accepted, but modified as follows	Rejected	Reason for modification/rejecti on		
							the scope of this document.		
9 General con	nment	It seems that extreme water temperature hazards are missing in the guide. In SSG-68 this hazard can be found.				√	Water temperature is discussed in paras 2.1, 7.6, 7.8, 9.9, 9.10, and in ANNEX I (Table I-1)		
10 General comment		It is advised to reconsider the content the content of SSG-68 to avoid unn inconsistencies, and possibly readers	of Chapter 7 in conjunction with ecessary duplication and risk of misunderstanding.			√	The comment does not provide concrete examples of unnecessary duplication or inconsistencies and our review of this section did not reveal any such issues.		
11	1.12	"The concept of external events <sup>3</sup> is intended to include more than those occurring in the external zone <sup>4</sup> , since in addition to the area immediately surrounding the site area, the site area itself may contain features that pose a hazard to the installation, such as a water	<ul> <li>Add definition of 'External Event' as in the IAEA glossary as a footnote</li> <li>Clarification for such features located inside the installation.</li> </ul>			√ 	Para. 1.9 cites the IAEA Nuclear Safety and Security Glossary as the source for terms used in this guide. The		

COMMENTS BY REVIEWER					RESOLUTION				
Reviewer: E	Reviewer: ENISS members					ENISS			
Page 1 of	Page 1 of 25								
Country/Or	ganization: El	NISS							
Date: 19 Ma	ay 2025								
Comment	Para/Line	Proposed new text	Reason	Acc	Accepted, but	Rejected	Reason for		
No.	No.			epte	modified as follows		modification/rejecti		
		recorde features are		d			on ddad tawt		
		reservoir. If such features are					added lext		
		are considered as internal hazards					bazarda is not		
		are considered as internal hazards.					consistent with		
		<sup>3</sup> "Events unconnected with the operation					the IAFA		
		of a facility or the conduct of an activity that					alossary		
		could have an effect on the safety of the					g1035ary.		
		facility or activity."							
10							D 116		
12		The meteorological, hydrological,	SSG-18 is a guide on site			$\checkmark$	Para. $1.16$		
		and other natural hazards addressed	characterisation/evaluation. In				merely discusses		
		in this Safety Guide may need to be	case the no information on the				the scope of this		
		determined independently of the	nuclear installation is available,				document in		
		characteristics of the nuclear	ssg-os will not help to realise				relation to the		
		Ear avample some hozard	a decoupling between sling				scope of $SSG$ -		
		For example, some nazard	and design. SSG-08 provides a				08.		
		evaluations may be performed at the	graded approach, which is						
		she selection and/or site	radialagiaal approximation						
	1.16	prior to the availability of	which is based on a set of						
		information on the design of the	(detailed) characteristics of the						
		nuclear installation	(detailed) characteristics of the						
		Recommendations on the	instantion.						
		determination of the appropriate							
		basis for the design and evaluation							
		of a nuclear installation through the							
		use and application of							
		appropriate criteria are provided in							
		IAEA Safety Standards Series No.							

		COMMENTS BY REVIEWER		RESOLUTION			
Reviewer: E	ENISS memb	ers			]	ENISS	
Page 1 of	25						
Country/Or	ganization: E	NISS					
Date: 19 Ma	ay 2025						
Comment	Para/Line	Proposed new text	Reason	Acc	Accepted, but	Rejected	Reason for
No.	No.			epte	modified as follows		modification/rejecti
				d			on
		SSG-68, Design of Nuclear					
		Installations Against External					
10		Events Excluding Earthquakes [10].					
13		The hazards considered in this	The hazards will not only		$\checkmark$		Added proposed
		Safety Guide may simultaneously	simultaneously impact multiple				text "units,
		affect multiple units, modules or	SSC of a single unit, but the				modules"
		structures, systems and components	units & modules (for SMR) on				<b>G</b> <sup>1</sup>
		(SSCs) important to safety at a	the same site.				Since the
		nuclear installation site (e.g.					various IAEA
		electrical power supply systems,	Please indicate the references at				safety guides are
		decay heat removal systems, other	the para. level in SSG-67 and				updated
		vital systems), introducing the	556-08.				asynchronously,
		Defense in death (i.e. providing					providing
	2.2	Defence in depin (i.e. providing					paragraph-level
	2.2	adequate diversity as well as					referencing to
		is with in design against common					other guides is
		is vital in design against common					not advised.
		Recommendations on the design of					
		nuclear installations against external					
		avents including consideration of					
		common cause failures are					
		provided in IAEA Safety Standards					
		Series Nos SSG-67 Seismic Design					
		for Nuclear Installations (para X Y)					
		[11] and SSG-68 (para $X Y$ ) [10]					
14		High intensity winds	Are cyclones being considered		$\checkmark$		Added (iii)
	2.5	(i) Tornadoes;	as covering all 'straight' wind				Other extreme

	COMMENTS BY REVIEWER	< colored and set of the set of t	RESOLUTION			
Reviewer: ENISS mem	Ders		ENISS			
Page 1 of 25						
Country/Organization: I	ENISS					
Date: 19 May 2025						
Comment Para/Line No. No.	Proposed new text	Reason	Acc epte d	Accepted, but modified as follows	Rejected	Reason for modification/rejecti on
	<ul> <li>(ii) Cyclones (tropical cyclones, typhoons, and hurricanes).</li> <li>(iii) Other extreme wind events like downburst, derecho, katabatic winds</li> </ul>	events? E.g. downburst, derecho, katabatic winds				wind events such as downbursts, squall lines, katabatic winds, etc.
15 2.6	The hazard types listed id §.2.5 should be assessed individually or as combined hazards when appropriate. This consideration applies to both phenomena combination, and consequences initiated by a single hazard (for example a storm surge caused by a tropical cyclone may also cause flooding at the site, flooding then being a consequential hazard). On the other hand For example, high intensity winds may have a major bearing on the safety of a nuclear installation (direct effects) and may lead to initiating events that are to be included in the safety analysis for the installation (indirect effects). High intensity winds, particularly tropical cyclones and tornadoes may also generate flying debris and projectiles. This illustrates the case	This paragraph mixes the notion of phenomenological hazard (listed in §.2.5) combination and the study of several consequences caused by a single hazard. The proposed text describes both possibilities to identify potential relevant hazards combinations, if one wishes to keep both these possibilities. It might be clearer if the two notions were in two different paragraphs.				Para. Modified as: "The hazard types listed in para. 2.5 should be assessed individually or as combined hazards where appropriate. This consideration applies to both phenomena combination, and consequences initiated by a single hazard (i.e., direct and indirect effects). For example, high intensity

	COMMENTS BY REVIEWER					RESOLUTION			
Reviewer: H	ENISS memb	ers		ENISS					
Page 1 of	25								
Country/Or	ganization: E	NISS							
Date: 19 M	ay 2025								
Comment	Para/Line	Proposed new text	Reason	Acc	Accepted, but	Rejected	Reason for		
No.	No.			epte d	modified as follows		modification/rejecti on		
		of different consequences initiated					winds may have		
		by a single hazard, as does the					direct effects		
		example of extreme precipitation					(e.g., wind		
		that may lead to both large loads on					forces) and may		
		structures (e.g. roofs) as well as					lead to other		
		cause and flooding.					initiating events		
							that are to be		
							included in the		
							safety analysis		
							for the		
							installation		
							(indirect effects		
							such as flying		
							debris and		
							projectiles).		
							Storm surge		
							associated with		
							tropical		
							cyclones may		
							also cause		
							flooding_at the		
							site. Extreme		
							precipitation		
							may lead to large		
							loads on		
							structures (e.g.		
							roofs) as well as		
							cause flooding.		

	COMMENTS BY REVIEWER					RESOLUTION			
Reviewer: H	ENISS memb	ers			ENISS				
Page 1 of	25								
Country/Or	ganization: E	NISS							
Date: 19 Ma	ay 2025								
Comment No.	Para/Line No.	Proposed new text	Reason	Acc epte d	Accepted, but modified as follows	Rejected	Reason for modification/rejecti on		
16	2.13	<ul> <li>[]</li> <li>(b) Climatic variability and climate change, which may have effects on the occurrence and/or intensity of extreme meteorological and hydrological conditions.</li> <li>[]</li> </ul>	The paragraph is dedicated to foreseeable modification over the lifetime of the nuclear installation. The climatic variability, except for the part due to climate change, is not foreseeable. It is suggested to delete this part of the sentence.			$\checkmark$	Climate variability (e.g., ENSO, PDO, NAO) are important considerations in addition to climate change.		
17	2.19	[] (a) increasing the observation time frame using data provided by historical accounts or paleo- information, if they can be considered as representative enough of the current situation []	The environmental conditions as well as the anthropization may have changed, not to mention climate change.			$\checkmark$	Paleo-data and historical accounts may provide valuable insights even if circumstances have changed. For example, informing use of interval data.		
18	2.21	[] Threshold selection should be performed carefully to ensure the selection of an appropriate number of peaks and that the peaks are statistically independent and identically distributed. []	One requirement for Extreme Value Analysis is the identically distribution of the data/peaks. It could also be added that the threshold should be high enough to focus on extreme values but not so high that too few data points are left for analysis	✓			Proposed text added.		

	COMMENTS BY REVIEWER				RESOLUTION			
Reviewer: E	ENISS membe	ers		ENISS				
Page 1 of	25							
Country/Or	ganization: El	NISS						
Date: 19 Ma	ay 2025							
Comment	Para/Line	Proposed new text	Reason	Acc	Accepted, but	Rejected	Reason for	
No.	No.			epte	modified as follows		modification/rejecti	
				d			on	
19		Sensitivity analysis should be	The same precautions that are	$\checkmark$			Text modified	
		performed to ensure that small	listed for the threshold selection				as: Sensitivity	
		changes in the threshold or change	apply to block size selection				analysis should	
		in the block size does not lead to	especially when a block size				be performed to	
		large changes in analysis results	shorter than annual is selected				ensure that small	
	2 21		to compensate for a short				changes in the	
	2.21		obervation period availability.				threshold (or	
							perhaps change	
							in the block size)	
							does not lead to	
							large changes in	
							analysis results.	
20	2.21, lines	Recommendation could be made	The term "distribution		$\checkmark$		In practice,	
	6-8	clearer.	function" can also be used to				many	
		For both block maximum and peak-	refer to the <i>types</i> of probability				distributions	
		over-threshold approaches,	distributions (e.g., lognormal,				other than GEV	
		distribution parameters should be	beta) regardless of their				and GPD are	
		estimated from the data using	parameter values. The Block				used in	
		statistical methods. The resulting	Maxima (BM) and Peak-over-				meteorology and	
		estimated distribution functions	threshold (PoT) methods are				hydrology, so	
		should be checked to fit the extreme	based on only one type of				the	
		values under study.	distribution (so-called GEV-				recommendation	
			and GPD distributions,				needs to be	
			respectively). <i>"Different</i>				rather general.	
			probability distribution				Added goodness	
			functions should be tested"				of fit as a focus	
			might mislead to use				of testing	
			distribution types other than				different	
			GEV / GPD, which is invalid				distributions.	

Daviawan I	COMMENTS BY REVIEWER				RESOLUTION			
Page 1 of 25						EINI22		
Country/Or	ganization: E	NISS						
Date: 19 Ma	av 2025							
Comment	Para/Line	Proposed new text	Reason	Acc	Accepted, but	Rejected	Reason for	
110.	110.			d	mounied as follows		on	
			for BM and PoT, respectively. Values of GEV/GPD distribution parameters are estimated from the data with statistical methods (e.g., Maximum Likelihood). Regardless, goodness-of-fit					
			should be checked after parameter estimation. This is done with the data used for estimation; for BM/PoT, these are only the extreme datapoints (defined as block maxima and exceedances over a high					
			threshold, respectively).					
21	2.22	Extra explanation would be needed.	Some trends are clear and documented extensively, but other trends, such as cyclic trends, are less easy to identify. This difficulty can be due to the slow variation of the trend and the limitation of the available data. SSG-18 can give a suggestion on how to address this issue, especially with declining non-significant trends			$\checkmark$	More detailed discussion is beyond the scope of this type of document.	

	COMMENTS BY REVIEWER					RESOLUTION			
Reviewer: H	ENISS membe	ers		ENISS					
Page 1 of	25								
Country/Or	ganization: E	NISS							
Date: 19 Ma	ay 2025								
Comment No.	Para/Line No.	Proposed new text	Reason	Acc epte d	Accepted, but modified as follows	Rejected	Reason for modification/rejecti on		
22	2.23	From line: "Care should be taken in" should go in new para.	This comment is applicable to all statistical models, not only Bayesian methods.	√			New paragraph started here.		
23	2.24	Suggestion to add a para.: The probabilistic methods require a lot of model calculations. This issue can be addressed by using fast models or by using a more advanced sampling technique like Latin Hypercube sampling or stratified sampling instead of the basic Monte Carlo sampling.	Extra info on how to overcome the issues of the probabilistic method. 5.15 mentions these optimal sampling methods but they should be mentioned in the general definition.		✓		Added footnote to address strategies.		
24	2.28	The results of the hazard analysis should be compared with results of previous studies, observations, and historical or paleorecords and adapted if necessary <sup>1</sup> . <i>Footnote to be added</i> <sup>1</sup> Recognised industrial (non- nuclear) standards can also be relevant references.	WENRA guidance: If the site specific hazard assessment for a DBE with a frequency not higher than $10^{-4}$ per annum leads to loads that are lower than those required according to recognized standards (e.g. Eurocode 1 (EC1)), as a minimum design basis event for meteorological hazards the requirements according to the recognized standards (e.g. Eurocode 1 (EC 1)) should be applied. There are dedicated Eurocode standards for snow loads (EN 1991-1-3:2003 [4]),		~		Added proposed text, but not the proposed footnote. The footnote is not relevant to topic of this paragraph.		

COMMENTS BY REVIEWER					RESOLUTION			
Reviewer: H	Reviewer: ENISS members				ENISS			
Page 1 of 25								
Country/Or	ganization: El	NISS						
Date: 19 Ma	ay 2025							
Comment	Para/Line	Proposed new text	Reason	Acc	Accepted, but	Rejected	Reason for	
No.	No.			epte	modified as follows		modification/rejecti	
				d			on	
			wind loads (EN 1991-1-4:2005					
			[5]), and thermal loads (EN					
			1991-1-5:2003 [6]).					
25		In the statistical approach,	Para. 2.29,2.30 and 2.31 are	$\checkmark$			Proposed	
		uncertainty estimates (e.g.	related to uncertainty				deletion	
		confidence intervals) should be	evaluation. This sentence is				accepted	
		produced as part of the analysis.	relative to conservatism and is					
	2.30	Uncertainty can also be investigated	applied only for statistical					
		by fitting different distributions to	approach while conservatism					
		the data. Conservatism can be	could be discussed for each					
		applied by use higher percentile	method. Proposal to delete this					
		estimates instead of the mean.	sentence or to move it.					
26	2.30, lines	Recommendation could be made	For the first sentence about			$\checkmark$	No longer	
	2-4	clearer.	different distributions, see the				relevant because	
		Depending on the analysis,	top of comment No.1 about				conservatism	
		uncertainty can also be investigated	different distributions and				statement	
		by fitting different distributions to	BM/PoT. In other types of				deleted in	
		the data. In the Bayesian approach,	analyses, fitting different types				response to	
		conservatism can be applied by	of distributions is common,				previous	
		using high percentiles from the	however.				comment.	
		posterior distributions.						
			Non-Bayesian (frequentist)					
			methods consider only					
			confidence intervals, not					
			posterior probability					
			distributions; thus the concept					
			of using higher percentiles is					
			natural only in the Bayesian					

Reviewer: F	COMMENTS BY REVIEWER Reviewer: ENISS members				RESOLUTION ENISS			
Page 1 of	Page 1 of 25							
Country/Or	ganization: E	NISS						
Date: 19 Ma	ay 2025							
Comment No.	Para/Line No.	Proposed new text	Reason	Acc epte d	Accepted, but modified as follows	Rejected	Reason for modification/rejecti on	
			framework. Here, posterior distributions can be summarised by their mean, but also by the median, other percentiles, or the mode. Posterior distributions need not be symmetric, i.e. mean != median in general. Thus, the mean can be equal to a high percentile.					
27	3.3	Data collected by site monitoring systems that have been in operation since the preliminary phase of the site evaluation — although obtained over a short period of time — should be used to assess whether the data obtained from regional networks used to estimate the hazards at the site are representative of the specific characteristics in the vicinity of the site. The representativeness can be analysed through a correlation analysis resulting in a correlation coefficient for and a regression relation between on-site and off-site data. Collection of data and information should be continued throughout the lifetime of the	The representativeness can be expressed through a correlation analysis				Added the following sentence: "One method to assess representativene ss of regional data can be performing a correlation analysis between on-site and off-site data."	

		COMMENTS BY REVIEWER	2		RESOLUTION			
Reviewer: H	ENISS membe	ers		ENISS				
Page 1 of	25							
Country/Or	ganization: El	NISS						
Date: 19 Ma	ay 2025				Γ	I		
Comment No.	Para/Line No.	Proposed new text	Reason	Acc epte	Accepted, but modified as follows	Rejected	Reason for modification/rejecti	
		nuclear installation to support updates of the safety case (e.g. as determined by periodic safety reviews)		d			on	
28	3.4	To the extent possible, dData should include the location and date/time at which it was measured/acquired. []	A data without location and date/time at which it was measured/acquired seems to be useless for data analysis.	$\checkmark$			Deletion accepted	
29	3.7	Instrumental records, historical information and hazard analysis should be supplemented with paleoinformation, where available and compatible with the current situation (e.g. geologic or dendrochronological information). For example, tree ring data can be used to extend temperature and precipitation records, and geologic evidence can be used to extend the useful record for riverine and coastal flooding, but limitation in such records should be considered.	In some cases this additional information may be considered at the hazard analysis stage. For analyses of extreme values (Block Maxima / Peak-over- threshold), such data may only be used for rough plausibility checks of the results but not in the quantitative hazard evaluation itself (very imprecise and uncertain data). Because of climate change, these data may not be representative of the current and further evolving climate conditions, not to mention environmental and occupational changes.				Use of paleo- information is part of the hazard analysis. Response to Comment No. 17 provided rational for not including the "compatible with current situation" qualifier. The qualifier regarding "limitation" is too vague to be useful.	
COMMENTS BY REVIEWER					RESOLUTION			
----------------------	------------------	--	--	------------------	--------------------------------------	----------	---	--
Reviewer: E	ENISS membe	ers		ENISS				
Page 1 of	25							
Country/Or	ganization: El	NISS						
Date: 19 Ma	ay 2025							
Comment No.	Para/Line No.	Proposed new text	Reason	Acc epte d	Accepted, but modified as follows	Rejected	Reason for modification/rejecti on	
30	3.8	[] (ii) Extreme or threshold air temperature and humidity conditions (e.g. the number of hours certain wet bulb temperature <sup>11</sup> values are exceeded each year) to establish loads for the design of heat sink systems, systems for the removal of containment heat following an accident, and installation heating, ventilation and air conditioning systems. []	Use of threshold air temperature not understood. + a typo		✓		Thresholds exceedances are used in the design of certain equipment (e.g. HVAC). Added "nuclear" to clarify use of installation.	
31	3.9	[] In this regard, the specifications for measurements — including standards and best practices for instruments, instrument siting, observations, data management, the quality management system and homogenization — are available in publications of the World Meteorological Organization or Nuclear Safety Authorities.	There is also a set of nuclear standard for on-site program (e.g. RG 1.23). For on-site monitoring, it may not always be possible to have optimal conditions.		✓		Reference to national nuclear safety guides and standards.	
32	3.13	Extra explanation would be needed	An explanation for the reason of	√			Example added	
		to understand why this	unis recommendation might be				understanding	
		recommendation is introduced.	neipiul to understand its intent.				understanding.	

COMMENTS BY REVIEWER					RESOLUTION			
Page 1 of	25	ers				ENISS		
Country/Or	ganization: E	NISS						
Date: 19 M	ay 2025							
Comment No.	Para/Line No.	Proposed new text	Reason	Acc epte d	Accepted, but modified as follows	Rejected	Reason for modification/rejecti on	
33		Documentation of meteorological analyses should include a	Perhaps it would also be helpful to give an example or some conditions under which this paragraph is relevant (for example short observational records). For some analysis a full cycle is important so both the start as the end should be checked. Proposal to add this clarification to highlight that the		√		Paragraph revised to	
	3.15	description of each meteorological station and the monitoring programme, including types of instrument, calibration history, geographical location, instrument exposure and altitude, data record period(s), and data quality and quality of the meteorological station.	meteorological station should fulfil some WMO requirements concerning its quality (e.g. : the potential impact of specific condition like lake, high threes, concrete areas on the measure).				improve clarity.	
34	3.19	There may be indirect evidence that long term measurements made at nearby meteorological stations can be considered representative of the site. Nevertheless, on-site data obtained during the short period of record of the site evaluation should be the basis for assessing the	On site data collection may not be necessary or can be significantly limited if there are representative meteorological measurements or if the facility characteristics (like underground final disposal			$\checkmark$	The proposed text is too vague. Disposal facility example not relevant to scope of this guide.	

	COMMENTS BY REVIEWER					RESOLUTION			
Reviewer: E	ENISS membe	ers		ENISS					
Page 1 of	25								
Country/Or	ganization: El	NISS							
Date: 19 Ma	ay 2025								
Comment No.	Para/Line No.	Proposed new text	Reason	Acc epte d	Accepted, but modified as follows	Rejected	Reason for modification/rejecti on		
		repressiveness of nearby station data, since deviations from regional to local meteorological conditions may be caused by local topography, nearby bodies of water, or other unique site characteristics. Associated approach could be graded in terms of on-site data collection according to the actual representativeness of available measurements.	facilities) do not require that kind of measurements.						
35	3.25 (new para. suggestion )	3.25.a In using climate models, Impact of other, more local parameters can shall be considered. E.g. if at new sites, a forest is cut to prepare the construction of NPP, the disappearance of the trees, may impact the soils capacity to absorb water and increase direct exposure of the soil to sun. As a consequence there may be more drought, which can impact the temperature.	It is ok to use climate models, but other, more local parameters can also evolve. E.g. if at new sites, forest is cut to prepare the construction of NPP, the disappearance of the trees, may impact the soils capacity to absorb water and increase direct exposure of the soil to sun. As a consequence there may be more drought, which can impact the temperature.		√		Added text to reflect this comment.		
36	3.36	(d) Tsunami induced by iceberg collapse	As another phenomenon which could cause a tsunami		$\checkmark$		Added item to list for tsunami associated with		

COMMENTS BY REVIEWER					RESOLUTION			
Reviewer: ENISS members				ENISS				
Page 1 of	Page 1 of 25							
Country/Org	ganization: El	NISS						
Date: 19 Ma	ay 2025				1			
Comment No.	Para/Line No.	Proposed new text	Reason	Acc epte d	Accepted, but modified as follows	Rejected	Reason for modification/rejecti on	
							ice shelf, iceberg, or glacier calving.	
37	3.41	For relevant water control structures, the following information should be collected, when available or obtainable from the organisations operating them : []	Some sensitive information regarding water control structures will not be public and the operators will not always agree to share data.		$\checkmark$		Added a footnote discussing this point.	
38	4.1	Nuclear installations are expected to be designed to withstand hazards associated with extreme meteorological conditions and with rarely occurring hazardous meteorological phenomena. The design and continued operation of a nuclear installation should consider the inclusion of parameters for rare and extreme meteorological events, as described in SSR-1 [1]. Meteorological hazards that could affect the safety of nuclear installations are required to be considered throughout the lifetime of the facility (see Requirement 7 of SSR-1 [1]).	To avoid misunderstanding like continuous operation is an absolute requisite.	✓			Agree that "continued" is not needed.	

COMMENTS BY REVIEWER					RESOLUTION			
Reviewer: E	Reviewer: ENISS members				ENISS			
Page 1 of	Page 1 of 25							
Country/Or	ganization: El	NISS						
Date: 19 Ma	ay 2025							
Comment	Para/Line	Proposed new text	Reason	Acc	Accepted, but	Rejected	Reason for	
No.	No.			epte	modified as follows		modification/rejecti	
20			This sentence second and have done	d			On It?	
39		Additionally, historical data alone	This sentence seems redundant			$\checkmark$	It's appropriate	
		might not rully represent ruture	with 3.25				to make the link	
		chmate and extreme event					between	
		conditions due to climate change.					extrapolation of	
		For sites that have a limited					historical data	
	4.3	nistorical dataset, observational					and use of	
		records snould be supplemented or					climate	
		extended using climate model					projections nere.	
		outputs or reanalysis data.						
		Recommendations on the use of						
		climate projection data are provided						
10		In Section 9.			,		D	
40		Exploratory Data Analysis Data	Data processing usually refers		$\checkmark$		Partially agree	
		processing should be used to take	to preparing raw data for further				with comment.	
		into account the possible non-	analyses.				EDA should be	
		stationary behaviour of the	Properties of these data (such as				used to identify	
		stochastic process under	non-stationarities) are usually				nonstationarity	
		consideration, which may reflect	investigated as part of an				behaviour, but	
		climatic variability and climate	Exploratory Data Analysis.				EDA itself does	
		change, among other phenomena.	There are instances where data				not "account for	
	4.4	In data processing, attention should	processing affects the way non-				nonstationarity."	
		be paid in order to retain these non-	stationarities are reflected in the				Other methods	
		stationarities in the data.	data. Example: Modelling				do this.	
			seasonality of monthly					
			temperatures with a sine curve					
			when some months are (perhaps					
			irregularly) missing in the data,					
			affecting the phase of the curve.					
			Thus, data processing should be					

COMMENTS BY REVIEWER					RESOLUTION			
Reviewer: I	ENISS memb	ers		ENISS				
Page 1 of	25							
Country/Or	ganization: E	NISS						
Date: 19 M	ay 2025							
Comment	Para/Line	Proposed new text	Reason	Acc	Accepted, but	Rejected	Reason for	
No.	No.			epte	modified as follows		modification/rejecti	
			conducted with the later	u			OII	
			analyses in mind.					
41		Extend the list to other aggregation	Why limit to daily maximum		$\checkmark$		Added "Where	
		levels.	and minimum? If higher				available, sub-	
			resolution data (for example				daily air	
			hourly) is available statistical				temperature	
			analysis of different				should also be	
			aggregation levels (1h, 6h,				collected."	
	4.9		12h) can be performed to					
			estimate the return levels of the					
			peak values of these					
			aggregation levels.					
			IAEA_2011_SSG-18 from					
			2011 mentioned hourly data in					
			§4.8.					
42		[] in the data analysis. For wet	Wet bulb temperatures (WBT)			$\checkmark$	Covered in Para	
		bulb temperatures, the distinction	represent a combination of a dry				4.12.	
		can be made between extreme wet	bulb temperature (DBT) and a					
		bulb temperatures that can occur	certain degree of humidity					
		coincidentally with the extreme dry	(AH). During a heat wave,					
		bulb temperatures and extreme wet	extreme DBT are generally					
	4.10	bulb temperatures that occur	accompanied by low AH.					
		independent from extreme dry bulb	Outside heatwaves, relatively					
		temperatures.	moderate (but still high) DBT					
			can occur, but at high AH,					
			representative for WBT that					
			would exceed the ones during					
			the heatwave. For some systems					

	COMMENTS BY REVIEWER					RESOLUTION			
Reviewer: 1	ENISS memb	ers		ENISS					
Page 1 of	Page 1 of 25								
Country/Or	ganization: E	NISS							
Date: 19 M	ay 2025								
Comment	Para/Line	Proposed new text	Reason	Acc	Accepted, but	Rejected	Reason for		
No.	No.			epte	modified as follows		modification/rejecti		
				d			on		
			(like HVAC), combining						
			extreme DBT with the (non-						
			coincidental) WBT may be too						
			restrictive from a design						
42			perspective.		,		A 1 1 1 1		
43		[] should also be determined. The	High intensity winds can cause		$\checkmark$		Added proposed		
	4 17	characteristics from wind-borne	wind-borne missiles.				text, but changed		
	4.17	missiles shall be derived					"shall" to		
		consistently with the considered					"should"		
		wind speeds.			,				
44		The hazard evaluation for tropical	As in para. 4.39		$\checkmark$		Added "Cyclone		
		cyclones, hurricanes or typhoons					generated		
		should result in an extreme wind					projectiles		
		speed for a given averaging period					should be		
		and corresponding to an established					specified in		
		annual frequency of exceedance.					terms of their		
		Other features of interest for design,					dimension,		
	4.01	such as the vertical profile of the					mass, and		
	4.31	wind velocity, the duration of the					velocity."		
		wind intensity above specified							
		levels and wind-borne projectiles							
		should also be described. Cyclone							
		generated projectiles should be							
		specified in terms of their							
		dimension, mass, and velocity. This							
		can be a standard spectrum from							
		available regulatory documents or a							

	COMMENTS BY REVIEWER					RESOLUTION			
Reviewer: H	ENISS memb	ers		ENISS					
Page 1 of	25								
Country/Or	ganization: E	NISS							
Date: 19 Ma	ay 2025								
Comment No.	Para/Line No.	Proposed new text	Reason	Acc epte d	Accepted, but modified as follows	Rejected	Reason for modification/rejecti on		
		site-specific spectrum derived from a site-specific analysis.							
45	4.32	[] (d) The rainfall from tornadic storms may induce local floods and consequently may be the cause of additional indirect damage. Such rainfall is consistent with the guidance on local intense precipitation (items 4.44 – 4.47).	It is assumed that rainfall from tornadic storms is not different from other extreme rainfall.		$\checkmark$		Added reference to local intense precipitation.		
46	4.36.a	Proposed additional para.: In addition to the annual frequency of exceedance per tornado class, the damage footprint per tornado class is to be addressed. Inside the footprint, the tornado wind speeds can vary over the trajectory and lifespan of the tornado.	Generally, also the damage footprint is to be determined. Also, tornado wind speeds can vary over the lifespan of the tornado (Cfr WASH study)			√	Para 4.36 discusses AEF of tornado wind speeds. Tornado path segments and wind speed in segments are part of the wind speed AEF analysis.		
47	4.39	4.39. Tornado generated projectiles should be specified in terms of their dimension, mass, and velocity. This can be a standard spectrum from available regulatory documents or a site-specific spectrum derived from a site-specific analysis. To protect against []	Standard spectrum (as in US NRC R.G. 1.76) or site specific spectrum.				Added "This can be a standard spectrum from available regulatory guidance, or a site-specific spectrum		

		COMMENTS BY REVIEWER		RESOLUTION			
Reviewer: E	ENISS membe	ers		ENISS			
Page 1 of	25						
Country/Org	ganization: El	NISS					
Date: 19 Ma	ay 2025						
Comment	Para/Line	Proposed new text	Reason	Acc	Accepted, but	Rejected	Reason for
No.	No.			epte	modified as follows		modification/rejecti
				u			derived from a
							site-specific
							analysis"
48		Tornado missiles and the resulting	It is proposed to delete this part		1		Did not delete
10		impacts on SSCs should be	of the sentence as there are				reference to
		estimated using computational	other tools or means that can be				computational
		codes <sup>22</sup> designed to analyse these	used to evaluate those impacts				codes, but added
	4.40	specific phenomena.	(e.g. : structural/experimental				text to consider
	4.40		testing, engineering judgments				other methods
			or comparisons of load cases				
			used in other attacks (projectiles				
			generated by high winds,				
			etc.),).				
49		[] Data from stations equipped	If the rain gauges data is		$\checkmark$		Radar data can
		with a continuously recording rain	sufficient the radar data does				provide
		gauge suitable for resolving the	not have to be used. "where				information on
		temporal resolution of rainfall	appropriate" leave a lot to				spatial variation
		needed for the analysis (e.g. sub-	interpretation. Also, the results				not possible
		hourly rainfall data is typically	from long re-analysis model				from rain
	4 42	needed for site-scale local intense	simulations (e.g. ERA-5) can				gauges.
	4.45	where evolution should be used,	provide extra local info.				whore
		can be complemented by weather					appropriate"
		radar data in case of limited of					with "where
		sparse rain gauges <del>, where</del>					available". Use
		appropriate. Also, the results from					of reanalysis
		long re-analysis model simulations					mentioned as
		(e.g. ERA-5) can provide extra					additional

COMMENTS BY REVIEWER					RESOLUTION			
Reviewer: H	ENISS memb	ers		ENISS				
Page 1 of	Page 1 of 25							
Country/Or	ganization: E	NISS						
Date: 19 M	ay 2025							
Comment No.	Para/Line No.	Proposed new text	Reason	Acc epte d	Accepted, but modified as follows	Rejected	Reason for modification/rejecti on	
		local info. The complete set of precipitation data should be used to derive extreme values. []					complementary information.	
50	4.50	In some watersheds, snowmelt can be a significant contributor to flooding at a nuclear installation site. Data on extreme snowpack in the upstream basins and the pace at which the snow melt has occurred should be collected: this may be available from the national meteorological service or other entities. []	Besides the snowpack, the pace at which the snow melt occurs is important. However, this will be covered in the EVA of the river flow rate.			1	Melt sequences is mentioned in the following sentence.	
51	4.53/4.54	<ul> <li>4.53. For deterministic local intense precipitation flooding assessment, the precipitation input in the form of depth-area-duration or intensity-duration-frequency tables or curves []</li> <li>4.54. For statistical local intense precipitation flooding assessment, the precipitation flooding assessment, the precipitation input should be provided in the form of depth-duration-frequency or intensity-duration-frequency curves, from which the hydrologist should develop design rainfall events</li> </ul>	In Europe IDF (intensity – Duration Frequency) are used frequently for this analysis. It would be good to at least mention other available methodologies.	1			Added IDF in these two locations.	

	COMMENTS BY REVIEWER					RESOLUTION			
Reviewer: E	ENISS membe	ers		ENISS					
Page 1 of	25								
Country/Or	Country/Organization: ENISS								
Date: 19 Ma	ay 2025								
Comment	Para/Line	Proposed new text	Reason	Acc	Accepted, but	Rejected	Reason for		
No.	No.			epte	modified as follows		modification/rejecti		
		corresponding to the return		a			ОП		
		period(s) of interest [ ]							
52		[ ] Depending on the location of	The European building codes		1		Added "This		
52		the nuclear installation site, maps	and standards provide most		•		load case should		
		depicting the estimated snow load	likely values for limited return				be adapted to		
		may be available in building codes	periods (e.g. 50 yrs). In the				nuclear safety		
	4.65	and standards. This load case shall	Eurocode, there is a formula in				practice (e.g. in		
		be adapted to nuclear practice (e.g.	appendix to extrapolate the				terms of		
		in terms of appropriate return	value to higher return periods.				appropriate		
		period).	<b>C</b> 1				exceedance		
							frequency)."		
53		Positive lightning is more dangerous	To estimate the frequency of		$\checkmark$		Added "Positive		
		than negative lightning because it	exceedance of a certain				discharges are		
		originates from the tops of	lightning intensity, it is				typically less		
		thunderstorms and can strike up to	important to know that PLD				frequent than		
		40 km away, making it	(positive lightning discharges)				negative		
		unpredictable and potentially	are less frequent than NLD				discharges." To		
		deadly. It often hits areas far from	(negative lighting discharges).				the footnote		
	Footnote	the storm centre. Negative lightning,	IEC 62305-1 assumes a ratio of						
	24 (to	while still hazardous, comes from	10% PLD and 90% NLD.						
	4.70)	the lower levels of thunderstorms							
		and usually strikes directly beneath							
		the storm in the rain shaft. Its							
		shorter, more direct path makes it							
		more predictable compared to							
		positive lightning. Positive lightning							
		discharges are less frequent than							
		negative lighting discharges. IEC							

	COMMENTS BY REVIEWER					RESOLUTION				
Reviewer: H	ENISS memb	ers		ENISS						
Page 1 of	25									
Country/Or	ganization: E	NISS								
Date: 19 Ma	ay 2025									
Comment No.	Para/Line No.	Proposed new text	Reason	Acc epte d	Accepted, but modified as follows	Rejected	Reason for modification/rejecti on			
		62305-1 assumes a ratio of 10% positive lightning and 90% negative lightning.								
54	4.73	The lightning strike frequency should be determined, which is the product of the equivalent collection area of the structure or object <sup>25</sup> and the flash density per unit time in the area where the structure is located. Lightning data records (place, date and time, intensity) should be collected, when possible, taking into account the uncertainties from the estimation process.	The distribution curve of lightning shocks depends on the regions. These data may give access to flash density or estimated annual frequency of exceedance for lightning strike depending on the kind of method (deterministic or risk evaluation) that is used. The equivalent collection area of the structure is not sufficient to take into account para. 4.74			~	Proposed text provides less information than existing text.			
55	4.75	(d) Long	Looks like something is missing.		$\checkmark$		This is a typo; deleted.			
56	4.76	Suggestion to clarify in a footnote that impulse charge and specific energy are only provided for the first positive lightning strike.	Impulse charge and specific energy are only provided for the first positive lightning strike (Cf. IEC 62305).		1		Parenthetical regarding first positive strike added to items (d) and (e).			
57	5.4	When evaluating storm surge hazard, a reference water level, such as the high tide (spring tides) or high lake level, should be assumed to occur coincidently with the storm surge.	"high tides" seems too vague, better use spring tides (or 'king tides')		✓		Added "(e.g. spring tide or king tide)"			

		COMMENTS BY REVIEWER	< colored and set of the set of t	RESOLUTION				
Reviewer: H	ENISS memb	ers		ENISS				
Page 1 of	Page 1 of 25							
Country/Or	ganization: E	NISS						
Date: 19 Ma	ay 2025							
Comment	Para/Line	Proposed new text	Reason	Acc	Accepted, but	Rejected	Reason for	
No.	No.			epte	modified as follows		modification/rejecti	
50	57	[ ] The surge data should be	A small phase shift is often	d		1	0n The sited	
38	5.7	[] The surge data should be	A small phase shift is often			$\checkmark$	The clied	
		available as still water levels,	observed when comparing				net discuss show	
		fraguency weyes and estronomical	tide. This can result in large				not discuss skew	
		tides. This is normally the asso	ude. This can result in large				surge or	
		udes. This is normally the case	values. By using the show				combining it	
		when instrumental surge data for a	values. By using the skew				with storin	
		the surge is combined with high	surge (difference between the				surge.	
		the surge is combined with high	astronomical and the measured					
		tide for the hazard assessment the	nigh tide value) this can be					
		skew surge is advised.	avoided. The IAEA publication					
			SRS-120 "Assessment of high					
			wind and external flooding					
			(excluding tsunami) hazards in					
			site evaluation for nuclear					
			installations" does include this					
			explanation on page 93					
			(Fig.34)					
59		[] To compute the maximum	The credibility should be		$\checkmark$		Changed to	
		storm surge elevation using a	addressed to not being over				"credible	
		deterministic method, a set of	conservative. E.g. maximizing				maximized	
		maximized (but still credible)	each contributing parameter is				hypothetical	
	5.16	hypothetical storms should be	too restrictive.				storms"	
		constructed taking into account the	In this context, a sensitivity					
		information, knowledge and results	analysis on the contributing					
		from the evaluation of	parameters can be interesting.					
		meteorological hazards. []						

	COMMENTS BY REVIEWER					RESOLUTION				
Reviewer: H	ENISS membe	ers		ENISS						
Page 1 of	25									
Country/Or	ganization: El	NISS								
Date: 19 Ma	ay 2025									
Comment	Para/Line	Proposed new text	Reason	Acc	Accepted, but	Rejected	Reason f	for		
No.	No.			epte	modified as follows		modification	/rejecti		
<u></u>				d			on l			
60		Once the data set has been	Suggested additional	$\checkmark$			Proposed	text		
		developed, an annual frequency of	recommendation for complex				added.			
		exceedance for large floods (e.g. a	river systems							
		frequency of 10 <sup>-3</sup> per year or less)								
		should be computed through								
		extrapolation by using a								
		probabilistic model. To allow for								
		uncertainties in sampling, the								
		selected river discharge value is								
		usually a confidence level upper								
		limit, not the mean value, for the								
	5 105	chosen recurrence interval. In more								
	5.105	complex river systems with								
		multiple tributaries or tidal								
		downstream boundaries a								
		multivariate statistical model can be								
		applied to take the correlations into								
		account before sampling. A safety								
		factor should be added to take into								
		account uncertainties. This safety								
		factor should be added to the river								
		discharge rather than the still water								
		elevation								
61		A large flood event can generate	The parameters variation used	./			Proposed	text		
01		breaches of lavees along the river	in failure calculation can be	Ň			added	ил		
	5 1 1 4	that modify the water levels both in	described in a distribution and				auueu.			
	3.114	the river and in the fleedulein. The	thus included in the							
		hebryiour of the larges during the	mahahiliatia annalia a mith ant							
		benaviour of the levees during the	probabilistic sampling without							

	COMMENTS BY REVIEWER					RESOLUTION				
Reviewer: E	ENISS membe	ers		ENISS						
Page 1 of	25									
Country/Org	ganization: El	NISS								
Date: 19 Ma	ıy 2025									
Comment No.	Para/Line No.	Proposed new text	Reason	Acc epte d	Accepted, but modified as follows	Rejected	Reason for modification/rejecti on			
		flood event should be evaluated considering possible failure mechanisms (e.g. piping, overflow and overtopping, shearing of the backside slope). The behaviour assumed for these structures (breach or resist) could also be justified based on its unfavourable nature for the site flooding conditions or can, in case of a probabilistic approach, be included in the sampling.	having to assume the most unfavourable situation.							
62	5.116	In addition to inundation, floods could potentially affect the safety of the nuclear installation by undermining flood protection barriers, by causing direct hydrodynamic forces on any inundated buildings, by sedimentation and/or clogging of safety features on the site, or by eroding and destabilizing structures. Also the direct impact loads caused by any kind of debris (e.g. flotsam) should be considered.	It's not just hydrodynamic forces. Also the direct impact loads caused by all kind of debris should be considered.		✓		Added "Impact loads due to water-born debris should also be considered."			
63	5.121.	[]	Cf. comment #5.116.	$\checkmark$			Added "(f) Debris			

	COMMENTS BY REVIEWER					RESOLUTION				
Reviewer:	ENISS member	ers		ENISS						
Page 1 of	25									
Country/Or	rganization: E	NISS								
Date: 19 M	lay 2025									
Comment No.	Para/Line No.	Proposed new text	Reason	Acc epte d	Accepted, but modified as follows	Rejected	Reason for modification/rejecti on			
		(f) Debris transport (size, mass, velocity).					transport (e.g., size, mass, velocity)"			
64	5.123	[] (1) Wave induced erosion and breaching	Wave induced erosion and breaching could be mentioned	✓			Added "(k)(l) Wave induced erosion and subsequent breaching"			
65	6.13	[] (c) Expected potential impacts from these biological species on the nuclear installation (it could account for potential foreseeable climate change impact); []	IAEA analysis show a clear increase in IRS related to biological phenomena. Some of them are linked to climate change (e.g. excessive growth due to rising sea water temperature).			√	The impacts should be considered regardless of cause.			
66	6.15 - 6.24	Suggestion to move 6.15-6.24 to chapter 4.	It is not clear why ice (frazil ice and ice floes) and iceberg are not considered as meteorological phenomena?			√	Frazil ice and ice floes is not a purely meteorological phenomena.			
67	6.27.	The probability of estimated exposure to space weather hazards related consequences (GIC mainly) should be evaluated in the site characterization process. []	The site location has a limited impact on the original space weather hazard. It can however modify the consequences for sites according to their latitudes, their locations on the national grid, etc		$\checkmark$		Changed "probability of" to "estimated exposure to." Discussion of consequences gets into engineering			

	COMMENTS BY REVIEWER					RESOLUTION			
Reviewer: H	Reviewer: ENISS members					ENISS			
Page 1 of	25								
Country/Or	ganization: E	NISS							
Date: 19 M	ay 2025								
Comment No.	Para/Line No.	Proposed new text	Reason	Acc epte d	Accepted, but modified as follows	Rejected	Reason for modification/rejecti on		
							considerations, which beyond the hazard assessment.		
68	7.27	To be removed	It does not look correct to speak about cliff edge effect in a guide that is related to site evaluation, as a cliff edge introduces the plant response. Besides, if the cliff edge effect is maintained, it would be fair to add the External Event PSA as a complement to or alternative for the deterministic approach to identify cliff edge effects.			√	assessment.Thisparaexplainsthelinkagebetweenhazardevaluationevaluationandcliffedgeeffects.Also,thisdocumentmaybeusedinperiodreviews,whereinformationregardingcliffedgeeffectsmorereadilyavailablethanduringinitial sitecharacterization		
69	8.2	From our perspective, it seem better to remove section 8	Item 8.2 specifies that section 8 focuses on protection of the site, whereas SSG-68 provides specific recommendations on the design of the nuclear			$\checkmark$	Section 8.2 describes the relationship/inte rface between this guide and SSG-68. SSG-		

COMMENTS BY REVIEWER					RESOLUTION					
Reviewer:	Reviewer: ENISS members					ENISS				
Page 1 of	Page 1 of 25									
Country/Or	rganization: E	INISS								
Date: 19 M	lay 2025									
Comment No.	Para/Line No.	Proposed new text	Reason	Acc epte d	Accepted, but modified as follows	Rejected	Reason for modification/rejecti on			
			installation (i.e. specifically the SSCs of the installation). When comparing with SSG-68 this does not seem to be correct. E.g. SSG-68 also speaks about the dry site concept				68 refers back to SSG-18 on the "dry-site" concept.			
70	9.8	[] Results for the distant future are still affected by large uncertainties resulting from both greenhouse gas emission scenarios and climate models. Also, extreme weather events may behave differently than expected in a changed climate, e.g. it may become drier on average, but extreme precipitation may become more intense. Local observations	Climate is not the same as weather; hence also extremes weather events may behave different than the change in climate.			$\checkmark$	Although the proposed statement is correct, this level detail is not needed here.			
71	11.17	The extent to which a graded approach can be applied to hazard evaluation will depend on the nature of the specific event under consideration. Some hazards, due to the nature of the phenomena, cannot reasonably be evaluated using a graded approach (e.g. lightning). []	Why not? If a (maximised) lightning event will not result in major radiological consequences? Depending on the location, lower maximum lightning intensities can be witnessed.			√	Modified the sentence to increase clarity but kept the example of lightning.			
72	12.2	[] The management system for hazard evaluations should be integrated with and fulfil	Suggestion to include IAEA SSG-77 'Protection Against Internal and External Hazards			√	Site protection is not within the scope of this			

	COMMENTS BY REVIEWER					RESOLUTION			
Reviewer: E	Reviewer: ENISS members				ENISS				
Page 1 of	Page 1 of 25								
Country/Or	ganization: El	NISS							
Date: 19 Ma	ay 2025								
Comment	Para/Line	Proposed new text	Reason	Acc	Accepted, but	Rejected	Reason for		
No.	No.			epte	modified as follows		modification/rejecti		
				d			on		
		requirements of the overall safety	in the Operation of Nuclear				section. Section		
		management system for the nuclear	Power Plants'.				8 discusses site		
		installation project. IAEA Safety					protection. SSG-		
		Standards Series No. SSG-77					77 is cited there.		
		'Protection Against Internal and							
		External Hazards in the Operation of							
		Nuclear Power Plants' provides							
		specific recommendations on							
		protection against internal and							
		external hazards and combinations							
		of hazards in the operation of							
		nuclear power plants.							

COMMENTS BY REVIEWER					RESOLUTION				
Reviewer:									
Page of									
Country/Or	ganization:		FINLAND/STUK						
Date:	C								
Comment	Para/Line	Proposed new text	Reason	Accepted	Accepted, but	Rejected	Reason for		
No.	No.			_	modified as follows	-	modification/rejection		
1	2.1	The hazards considered in this Safety	Please see consistency	$\checkmark$			Proposed text was		
		hazards, hydrological hazards, and other	throughout the document				added.		
		natural hazards:							
2	2.6	High intensity wind combined with	Please consider to add a		$\checkmark$		Proposed text was		
		freezing precipitation or snow could block	separate table or matrix in				added, with		
		combustion and cooling air intake	appendix or annex on				modification.		
		structures and cause simultaneously	possible hazard				However, the		
		station black-out (loss-of grid).	should be considered in				toblo/motrix of		
			different regions				combinations for		
			different regions.				different regions is		
							beyond the scope of		
							this safety guide		
							This would be best		
							suited for a Tecdoc		
3	6.15	(c) pack ice which may lead to ice jams in	Please include pack ice		$\checkmark$		Pack ice added to		
		cooling water intake structures lead to	as a phenomena: Pack				list item (b).		
		damage to cooling water intake structures	ice, any area of sea ice						
			(ice formed by freezing of						
			seawater) that is not						
			landfast; it is mobile by						
			virtue of not being						
			attached to the shoreline						
			or something else.						
			Pack <u>ice</u> expands in the						
			winter and retreats in the						
			summer in both						
			hemispheres to cover						

		COMMENTS BY REVIEWER			RESC	DLUTION	
Reviewer: Page of Country/Or Date:	ganization:		FINLAND/STUK				
Comment No.	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection
			about 5 percent of the northern oceans and 8 percent of the southern oceans.[Source Britannica]. This phenomena was included in recent site characterization and evaluation in Finland.				

	COMMENTS BY REVIEWER					RESOLUTION				
Reviewer: <b>F</b>	ederal Minis	stry for the Environment, Nature Conse	ervation, Nuclear Safety							
and Consu	mer Protectio	on (BMUV) (with comments of GRS)	· ·							
Pages: 3										
Country/Org	ganization: G	ermanv								
Date: 19.05.	.2025									
Comment	Para/Line	Proposed new text	Reason	Accepted	Accepted, but	Rejected	Reason for			
No.	No.	· r			modified as follows		modification/rejection			
1.	1.1	Requirements for site evaluation for nuclear installations are established in IAEA Safety Standards Series No. SSR-1, Site Evaluation for Nuclear Installations [1]. This Safety Guide provides recommendations on meeting these requirements of SSR-1 [1] in relation to the evaluation of meteorological (Requirement 18), hydrological (Requirement 20), and selected other natural hazards (Requirement 21) (e.g. wildfire, drought, ice impacts, debris, biological phenomena) that potentially might affect nuclear installation sites	A specification of the exact requirements this Safety Guide is targeting would be helpful		✓		Text modified to identify the specific requirements in SSR- 1 for meteorological, hydrological, and other natural hazards.			
2.	1.2 New footnote	Meteorological hazards are associated with extreme meteorological conditions and with rarely occurring <sup>1</sup> hazardous meteorological events. Hydrological hazards are associated with external flooding events, as well as low water level conditions. Other natural hazards, selected for this Safety Guide are (e.g. wildfire, drought, ice impacts, debris, biological phenomena and debris <sup>2</sup> ) can also potentially affect nuclear installation sites. Footnote 2. For the purposes of this Safety Guide, debris represents any material, organic or non-organic, that is advected through the air and/or water. This does not	Clarification Additionally add the footnote (now Nr.47) to this para about debris, also emphasize that Requirement 21 of SSR-1 is referring to another type of debris.	√			Proposed text with slight edits and footnote added.			

		COMMENTS BY REVIEWER	RESOLUTION				
Reviewer: <b>F</b>	Federal Mini	stry for the Environment, Nature Conse	ervation, Nuclear Safetv				
and Consumer Protection (BMUV) (with comments of GRS)							
Pages: 3							
Country/Or	ganization: G	ermany					
Date: 19.05.2025							
Commont	.2025	Droposed new text	Passon	Accorted	Accord but	Dejected	Desson for
No	No	r toposed new text	Reason	Accepted	modified as follows	Rejected	modification/rejection
110.	110.	include debris avalanche, referred to in					moundation rejection
		SSR-1 [1].					
3.	1.5	Additionally, this Safety Guide clarifies	Clarification			$\checkmark$	Proposed text is not
		the distinction between the process for					needed.
		assessing site specific meteorological,					
		hydrological and other natural hazards –					
		<u>carried out during siting</u> and the process					
		for defining the relevant design basis and					
		beyond design basis parameters – <u>carried</u>					
		out during design of the for nuclear					
		installations . As a result, it fills in gaps and					
		avoids undue overlapping of the two					
		processes, which are performed to be					
		continued and revised at various stages					
		during the lifetime of nuclear installation.					
4.	1.11	This Safety Guide provides	Please make it clear that			$\checkmark$	The original text is
		recommendations on the evaluation of	such hazard evaluation is				clear.
		external hazards associated with	essential and fundamental				Decommissioning is
		meteorological, hydrological, and selected	for the site selection and				not within the scope
		other natural phenomena for nuclear	site evaluation.				of this safety guide.
		installation sites, carried out during site	Actualization is required.				
		selection and site evaluation. Additionally,	We guess not only for				
		<u>actualisation of</u> Eexternal hazard	operational period, but for				
		evaluations are needed required over the	decommissioning as well.				
		entire lifetime of the nuclear installation					
		project, from site survey, through the site					
		evaluation process (i.e. site selection and					
		site characterization stages from which the					
		design bases are derived, up until the end					
		of the operational period).					

		RESOLUTION					
Reviewer: <b>F</b>	Federal Minis	stry for the Environment, Nature Conse	ervation, Nuclear Safetv				
and Consu	mer Protecti						
Pages: 3		() (					
Country/Or	ganization G	ermany					
Date: 19.05	2025	cr many					
Comment	Dara/Line	Proposed new text	Resson	Accepted	Accented but	Pajacted	Reason for
No.	No.	r toposed new text	Reason	Accepted	modified as follows	Rejected	modification/rejection
5.	1.17	Section 10 is dealing with provides	Do we have Requirements		$\checkmark$		Removed
	Line 9	recommendations on meeting requirements	for warning? If yes – please				reference to "
		for monitoring and warnings for the	give a corresponding				requirements."
		protection of the nuclear installation site.	reference. Else – please				•
			change the wording. We				
			made a suggestion.				
6.	2.1	The hazards considered in this Safety	Clarification	$\checkmark$			Proposed
		Guide are grouped into meteorological					modification to text
		hazards, hydrological hazards, and other					adopted
		hazards: see Sections 4-6, respectively.					
		These hazards could affect the safety					
		functions of a nuclear installation in					
		multiple ways . For example, the ability of					
		the ultimate heat sink to perform its					
		function adequately could be affected by					
		hazards associated with water temperature					
		and water level conditions and drawdown					
		could all affect the ability of the ultimate					
		heat sink to perform its function					
		adequately. Inadequate cooling might be					
		caused by extreme water temperature					
		associated with heatwaves Limitation of					
		cooling water supply (e.g. low flow rate or					
		low water level) may be caused by severe					
		drought in the region, obstruction of					
		channels, loss of water source due to dam					
		failure, downstream failure of water					
		control structures, and anthropogenic					
		effects such as the pumping of					
		groundwater. In other cases, the ultimate					
		heat sink may be impacted by a drawdown					

COMMENTS BY REVIEWER Reviewer: Federal Ministry for the Environment, Nature Conservation, Nuclear Safety and Consumer Protection (BMUV) (with comments of GRS) Pages: 3 Country/Organization: Germany Date: 19.05.2025					RESC	DLUTION	
Comment No.	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection
		of the sea level resulting from a surge, seiche or tsunami.					
7.	2.4	Changes in hazards over time, including due to climate change, are important considerations for the further development of hazard parameters in the site <u>re-</u> evaluation process. Re-evaluation of hazards on regular basis should be considered, e.g. during the periodic safety review of a nuclear installation.	Clarification			$\checkmark$	Proposed text would change the intended meaning of the sentence.

		COMMENTS BY REVIEWER	RESOLUTION				
Reviewer:	Ahmad Kar	ramloo					
Country/Or	ganization: Ira	an/Iran Nuclear Regulatory Authority ()	INRA)				
Date: 13 Ma	ay 2025				Γ	1	
Comment No.	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection
1.	1.1	This updated Safety Guide supersedes SSG-18 (2011), providing comprehensive recommendations for assessing meteorological and hydrological hazards.	Emphasizes replacement of previous version and guide comprehensiveness			√	This statement is provided in para 1.6
2	1.3	The Guide aligns with the latest IAEA Safety Requirements SSR-1, SSR-2/1 (Rev.1), SSR-3, and SSR-4.	Ensures consistency with current safety standards			√	SSR-3 and SSR-4 refer back to SSR-1. SSR-2/1 focuses on design.
3	2.2	Meteorological and hydrological data should be collected from reliable global and regional sources with appropriate temporal and spatial coverage.	Highlight data reliability and coverage importance			$\checkmark$	Data collection is addressed in Section 3.

		COMMENTS BY REVIEWER		RESOLUTION			
Reviewer:	Ahmad Ka	ramloo					
Country/Or	ganization: Ira	an/Iran Nuclear Regulatory Authority ()	INRA)				
Date: 13 Ma	ay 2025						
4	3.1	Use of synthetic datasets and advanced modeling is recommended to supplement historical data gaps.	Update data analysis methodologies			$\checkmark$	These topics are mentioned elsewhere, including but not limited to paras 3.10, 3.25, and 3.26.
5	4.4	Combined hazard assessment methods (e.g., joint probability of hurricane and flooding) must be performed using advanced statistical techniques.	Addresses complexity of hazard combinations		✓		Comment accepted, but it would be better to discuss this in a previous section. So, added "Advanced statistical and probabilistic techniques may be needed to perform assessment of combined hazards (e.g. joint probability of hurricane and flooding)." to para 2.14

		COMMENTS BY REVIEWER	RESOLUTION				
Reviewer:	Ahmad Kar	ramloo					
Country/Org	ganization: Ira	an/Iran Nuclear Regulatory Authority (	INRA)				
Date: 13 Ma	ay 2025						
6	5.3	Flood assessments should consider	Ensures comprehensive			$\checkmark$	Dam breach is
		upstream dam breach effects and	hvdrological hazard				discussed elsewhere
		combined flow scenarios.					(para 5.152).
			coverage				
7	6.2	Design basis parameters must	Incorporates uncertainty			$\checkmark$	Already discussed
		account for uncertainties in modeling	considerations into design				in Section 7.
		and data.	C C				
8	7.1	Site protection measures should be	Ensures consistency and		$\checkmark$		Text on
		updated adaptively and aligned with	modern approaches				reassessment of
		SSG-68 and SSR-1.	11				protection added to
							para 8.5.

		COMMENTS BY REVIEWER	RESOLUTION				
Reviewer:	Ahmad Ka	ramloo					
Country/Or	ganization: Ira	an/Iran Nuclear Regulatory Authority (	INRA)				
Date: 13 Ma	ay 2025						
9	8.2	Climate change impacts must be	Addresses long-term			$\checkmark$	Already addressed
		considered as a key factor in periodic	environmental changes				in paras 9.2 and 9.3.
		hazard reviews.					
10	9.3	Warning systems should have	Guarantees reliability of		$\checkmark$		Proposed text added
		regular testing and validation to	warning systems				to para 10.5.
		ensure optimal performance					
11	10.1	A graded approach for hazard	Tailor assessment to			$\checkmark$	The discussion of
		assessment in non-power nuclear	installation types				the graded approach
		installations (e.g., SMRS, research					in Section 11 is
		reactors) should be described.					radiological hazard
							and is technology
							neutral. So, the
							recommendations
							are meant to apply
							to SMRs, research
							reactors, etc. SRS-
							94 specifically

		COMMENTS BY REVIEWER		RESC	LUTION	
Reviewer:	Ahmad Kar	ramloo an /Iran Nuclear Deculatory Authority (				
Date: 13 Ma	gamzation: In av 2025	an/Iran Nuclear Regulatory Authority (	IINKA)			
						addresses research reactors.
12	1.5	Technical terminology should be harmonized with the IAEA Safety Glossary (2018).	Standardizes technical vocabulary		√	IAEA Safety and Security Glossary cited in para 1.9. Other specific terms defined in footnotes.
13	2.4	General recommendations should include consideration of multi-event hazards and cascading effects.	Covers complex and cascading hazards	$\checkmark$		This comment has been addressed by edits made to para 2.6 made in response to ENISS comment no. 15

		COMMENTS BY REVIEWER		RESOLUTION			
Reviewer:	Ahmad Ka	ramloo					
Country/Or	ganization: Ir	an/Iran Nuclear Regulatory Authority (	INRA)				
Date: 13 Ma	ay 2025						
14	3.5	New meteorological data sources such as airport station data and tropical cyclone tracks should be incorporated.	Update data sources		√	Meteorological data sources is addressed in paras 3.8 – 3.23.	
15	4.7	Limitations of probable maximum parameter estimation methods in risk-based approaches should be clarified.	Clarifies technical limitations		$\checkmark$	The comment does not seem to apply to para 4.7. The limitations of probable maximum estimation (i.e. deterministic methods) are discussed in several sections of this guide (e.g. para 2.31).	
16	5.7	Tsunami modeling should employ state-of-the-art technology and up- to-date data.	Enhances modeling quality		$\checkmark$	The comment does not seem to apply to para 5.7, which addresses storm surge. The importance of selection of tsunami modeling is already described at para. 5.61. The	

		COMMENTS BY REVIEWER	RESOLUTION				
Reviewer:	Ahmad Ka	ramloo					
Country/Or	ganization: Ira	an/Iran Nuclear Regulatory Authority (	INRA)				
Date: 13 Ma	ay 2025						
							importance of the tsunami database is already described at para. 5.57.
17	6.4	Design basis parameter determination should consider effects on multiple units or adjacent sites.	Addresses multi-unit site complexities			$\checkmark$	The comment does not seem to apply to para 6.4, which addresses wildfire. This SSG supports site hazard characterization but does not differentiate between multi-unit or single-unit sites.
18	7.3	Hazard management must include continuous review and updating of protective measures documentation.	Ensures sustainability of protection		✓		The comment does not seem to apply to para 7.3, which addresses hazard evaluation. This comment is addressed by edits made to para 8.3 in response to Belgium comment No. 23.

		COMMENTS BY REVIEWER	RESOLUTION				
Reviewer:	Ahmad Kar	ramloo					
Country/Org	ganization: Ira	an/Iran Nuclear Regulatory Authority (I	INRA)				
Date: 13 Ma	ay 2025					1	
19	9.5	Monitoring systems should comply with NS-G-3.2 and SSR-1 standards.	Aligns with relevant standards			√	The comment seems to apply Section 10, not Section 9. Compliance with SSR-1 is addressed in paras 10.1 and 10.2. Compliance with NS-G-3.2 is cited elsewhere (paras 1.3, 1.13, 2.10, 3.18).
20	11.1	The hazard management system should be designed for rapid response to changing environmental conditions.	Increases management system flexibility		✓		This seems to apply to Section 12, not Section 11. Text added to para 12.2 to address this comment.
21	New Meteorolo gical hazards section (e.g., paragraph 2.1 or section 4)	It is recommended to include a dedicated section on dust hazards and their potential impacts on the safety of nuclear sites.	Dust is a significant meteorological hazard, especially in arid and semi-arid regions, affecting equipment, visibility, and personnel health, and should be			$\checkmark$	Paras 4.81 – 4.83 discuss characterization of dust storms and sandstorms.

		COMMENTS BY REVIEWER	RESOLUTION				
Reviewer:	Ahmad Ka	ramloo					
Country/Or	ganization: Ir	an/Iran Nuclear Regulatory Authority (	INRA)				
Date: 13 M	ay 2025	Ι					
			considered in a				
			comprehensive hazard				
			assessment.				
22	Nour	It is maximum dad to address frost	These phonomono cor			/	Hail is discussed in
22	new	fog and hail as important	These phenomena can			$\checkmark$	paras 4 86 to 4 88
	Meteorolo	meteorological hazards in the hazard	affect equipment				Freezing
	gical	assessment.	performance and site				precipitation and
	hazards		safety but are less				frost related
	section		amphasized in the current				phenomena are
	section 2 or		emphasized in the current				4.90 to 4.94.
	4)		document.				
							Fog is not a direct
							hazard to safety
							related SSCs but may modify
							assessments of
							human-induced
							external hazards
							(e.g. transportation
							near the site).
							external hazards are
							addressed in SSG-
							79.

		COMMENTS BY REVIEWER		RESOLUTION			
Reviewer:	Ahmad Kai	ramloo					
Country/Or	ganization: Ira	an/Iran Nuclear Regulatory Authority (I	INRA)				
Date: 13 Ma	ay 2025						
23	New Hydrologic al hazards section	It is recommended to include hazards related to sudden groundwater level changes and small-scale surface runoff in the hazard assessment.	These hazards may be significant in some sites and including them enhances the comprehensiveness of the assessment.		√	Small scale runoff already addressed in para 5.88-5.121 (local intense precipitation) High groundwater levels is addressed in paras 5.177- 5.181.	
24	New Related biological hazards section	It is recommended to dedicate a separate section to biological hazards related to meteorological and hydrological hazards.	These hazards can affect safety and personnel health and require specialized assessment.		$\checkmark$	Biological hazards are addressed in Section 6 (para 6.9- 6.14).	
25	New Hydrologic al and geological hazards section (e.g., section 5 or related)	It is recommended to include land subsidence as an important hydrogeological hazard in the site hazard assessment and to describe its monitoring and management methods.	Land subsidence caused by groundwater depletion and geological factors can have significant structural and safety impacts on facilities and should be included in a			Subsidence is already addressed in the Section 9 (paras 9.13, 9.20).	

		COMMENTS BY REVIEWER	RESOLUTION				
Reviewer:	Ahmad Ka	ramloo					
Country/Or	ganization: Ira	an/Iran Nuclear Regulatory Authority (	INRA)				
Date: 13 Ma	ay 2025				1		
			comprehensive hazard assessment.				
26	New Meteorolo gical hazards section (e.g., section 2 or 4)	It is recommended to include regional monsoon winds such as the 120-day Sistan wind and assess their potential impacts on nuclear site safety.	Regional monsoon winds can cause dust storms, reduce air quality, damage equipment, and pose health risks, making them important for local hazard assessment.	✓			Added regional monsoon winds to para 4.13
27	New Hydrologic al hazards section (e.g., section 5 or related)	It is recommended to include seiche as an important hydrological hazard in coastal areas in the site hazard assessment.	Seiche can cause water level oscillations and structural impacts in coastal regions and should be included in a comprehensive hydrological hazard assessment.			✓	Seiche is already discussed in Section 5 (paras 5.24, and paras 5.80-5.86).
		COMMENTS BY REVIEWER		RESC	DLUTION		
-------------	-------------------------	---	---	--------------	--------------	--------------------------------------	
Reviewer:	Ahmad Kai	ramloo					
Country/Org	ganization: Ira	an/Iran Nuclear Regulatory Authority (	INRA)				
Date: 13 Ma	ay 2025						
28	New	It is recommended to include a section addressing hazards caused by	This phenomenon can cause power outages	$\checkmark$		Text and footnote added to para 4.82	
	Section	high humidity and clay dust that can	eause power outuges,			to address this	
	related to	lead to short circuits in electrical and	malfunction of control			scenario.	
	electrical and	electronic circuits, impairing alarm and I&C system functions.	systems, and emergency				
	electronic		conditions, which are				
	hazard		critical for nuclear facility				
	assessment		entited for nuclear facility				
	(e.g., I&C		safety.				
	related						
• •	sections)					<u></u>	
29	New	It is recommended to include surface	These pollutions can		$\checkmark$	Oil spills are	
	Environme	significant environmental hazards in	severely impact water			and SSG-79 under	
	ntal and	comprehensive site hazard	quality and aquatic			Human Induced	
	water quality	assessments.	ecosystems and should be			External Events.	
	hazards		considered in				
	section (if applicable)		comprehensive				
	· · /		environmental hazard				
			management.				

	COMMENTS BY REVIEWER								
Revi Cour Mav	ewer: Jap htry/Orga . 2025	oan NUSSC member nization: Japan / NRA	Page of Date:16,		RESOL	UTION			
No.	Para/Li ne No.	Proposed new text	Reason	Accep ted	Accepted, but modified as follows	Reject ed	Reason for modification/rej ection		
1.	2.1.	The hazards considered in this Safety Guide are grouped into meteorological hazards, hydrological hazards, and other <u>natural</u> hazards: see Sections 4–6, respectively	In this draft, 'other hazards' is often used, as in para 2.1. This should be changed to 'other natural hazards' consistent with the document title. This should be reviewed throughout the document.	<i>√</i>			All "other hazards" s and "other phenomena" s were changed to "other natural hazards" s and "other natural phenomena" s.		
2.	2.2.	The hazards considered in this Safety Guide may simultaneously affect multiple structures, systems and components (SSCs) important to safety at a nuclear installation site (e.g. electrical power supply systems, decay heat removal systems, other vital systems), introducing the potential for common cause failure. Defence in depthMulti protection (i.e. providing adequate diversity as well as redundancy and physical separation) is vital in design against common cause failure.	Wording.			1	"Defense in depth" is a high- level IAEA safety requirement.		
3.	2.24.	Probabilistic hazard assessment aims to combine the strengths of deterministic and statistical approaches. The probabilistic approach generally uses the same mechanistic models used in deterministic approaches but treats model structure and model parameters as epistemic uncertainties <sup>7</sup> represented by probability distributions <u>or quantified by logic trees</u> . <u>Sampling from each of these distributions provides</u> <u>realizations of the physical system.</u> Aleatory uncertainties <sup>8</sup> are also represented by probability distributions. Propagation of these uncertainties to quantify their contribution to the final results (e.g. hazard parameters) should be addressed. This is generally accomplished via a <u>logic tree approach or</u> two- staged nested Monte Carlo simulation approach. <u>The logic</u> <u>tree approach represents the epistemic uncertainties using a</u> <u>set of branches for alternative models and parameter values</u> , and the mean or percentile hazard curves (i.e., magnitude-	Besides the two-staged nested Monte Carlo simulation approach, another common approach, i.e., the logic tree approach, should be mentioned in this para. As mentioned in 5.71 and Annex II, the logic tree approach has been adopted for probabilistic tsunami hazard assessment in some member states. The logic tree approach has been widely applied for probabilistic seismic hazard analysis by member states and mentioned in SSG-9 (Rev. 1).				The document has been revised in accordance with the comments.		

		COMMENTS BY REVIEWER					
Revi	ewer: Jap	ban NUSSC member	Page of		RESOL	UTION	
Cour	ntry/Orga	nization: Japan / NRA	Date:16,				
May	, 2025					•	
No.	Para/Li ne No.	Proposed new text	Reason	Accep ted	Accepted, but modified as follows	Reject ed	Reason for modification/rej ection
		frequency curves) can be calculated from a suite of hazard curves generated for the individual logic tree branches. In the Monte Carlo simulation approach, where the epistemic parameters are sampled in the outer loop					
4.	3.4.	To the extent possible, dData should include the location and date/time at which it was measured/acquired. Data should be presented clearly, using maps of an appropriate scale, graphs and tables. In general,	It seems mandatory to include this information from the viewpoint of data quality.	<i>,</i>			The document has been revised in accordance with the comments.
5.	3.7.	Instrumental records and historical information should be supplemented with paleo-information, where available (e.g. geologic or dendrochronological information). For example, tree ring data can be used to extend temperature and precipitation records, and geologic evidence can be used to extend the useful record for riverine and coastal flooding. It should be noted that the absence of geological evidence for floods does not prove that there were no floods in the past.	Clarification.				The document has been revised in accordance with the comments.
6.	3.29.	The tidal water level range should be determined for sites located in coastal areas affected by tides. The tidal range can vary greatly from place to place, and astronomical tides fluctuate on a time scale of hours to years. Tide predictions, as well as tide data obtained at coastal gauge stations in the site region should, where possible, be obtained from the national authorities. Data should cover a period that includes all the cyclical phenomena producing the tide (i.e. <u>approximately 19 years</u> ).	Is it the common to consider the 19-year tidal cycle in hazard assessment for site evaluation? The basis for using the 19-year cycle as a criterion for hazard assessment should be presented. If any member states use the 19-year cycle as a criterion, it would be better to state this in a footnote as an example of some member states, along with the basis.				The ~19-year tidal cycle is a function of the earth-moon-sun system that governs astronomical tides. This is not a reference to any particular member state regulation/criter ia

		COMMENTS BY REVIEWER					
Revi	ewer: Jap	ban NUSSC member	Page of		RESOL	UTION	
Cour	ntry/Orga	nization: Japan / NRA	Date: 16,				
May	, 2025		· · · · · · · · · · · · · · · · · · ·		A ( 1.1. (		D C
No.	Para/L1 ne No.	Proposed new text	Reason	Accep ted	Accepted, but modified as follows	Reject ed	Reason for modification/rej ection
7.	3.34.	Two different sets of geophysical and geological data should be considered with regards to tsunami, as follows: (a) specific site geology; and (b) sources of the tsunami phenomena, if appropriate to the site. The specific geological data in the vicinity of the site that should be collected include the following: (a) Specific site geology. The specific geological data in the vicinity of the site that should be collected include the following: (a)(i) Stability and erodibility of streambanks and shorelines; (b)(ii) Sediment characteristics that influence sediment transport, such as grain size distribution, density, and chemical composition, especially near the water intake structures of a nuclear installation; (c)(iii) Hydrogeological characteristics such as permeability and porosity; (d)(iv) The potential for landslides. (b) Sources of the tsunami phenomena, if appropriate to the site. Tsunamigenic sources include seismogenic structures, submarine and subaerial landslides and volcanic activity.	It is unclear what 'geophysical and geological data' refers to. This subsection (paras. 3.34- 3.36) seems to be recommendations for collecting data on tsunami. Therefore, it should be made clear that these data are related to tsunami. Additionally, we suggest adjusting the bullet system to more clearly express the contents of these datasets.				This section refers to geophysical and geological data that is used in all flood hazard assessments, not just tsunami.
8.	4.27.	Despite the availability of aircraft reconnaissance data accumulated over recent decades, certain pertinent tropical cyclones parameters might not be fully measured in each storm. Substantial changes in the inner core region in some mature cyclones have been noted to occur rapidly, and these changes should be considered.	The meaning of 'substantial changes' should be stated. In order to clarify the intent of this recommendation, it should be clearly indicated what changes have occurred and what should be taken into consideration.		✓		This text was from the 2011 version and was referring mainly to rapid intensification. The text has been modified to reference uncertainty in TC parameters, not specifically rapid intensification.

		COMMENTS BY REVIEWER					
Revi Cour May	ewer: Jap htry/Orga , 2025	oan NUSSC member inization: Japan / NRA	Page of Date:16,		RESOL	LUTION	
No.	Para/Li ne No.	Proposed new text	Reason	Accep ted	Accepted, but modified as follows	Reject ed	Reason for modification/rej ection
9.	4.36.	4.36. The annual frequency of exceedance at which a particular nuclear installation site will experience tornado wind speeds in excess of a specified value should be derived from a study of the tornado inventory. However, if there are not enough confirmed tornadoes to calculate the annual frequency of wind speeds exceeding the threshold, the maximum wind speed of the largest tornado in the vicinity of the site should be considered. A homogeneous region centred at the site should be considered for developing the tornado inventory. In addition, when determining the scope of a "homogeneous area", it is important to give due consideration to areas with meteorological conditions similar to those in which tornadoes occur in the vicinity of the site.	The largest tornado in the site's history should be considered if the annual exceedance frequency of tornado wind speeds cannot be calculated. When determining the scope of a "homogeneous area," it is important to give due consideration to areas with meteorological conditions similar to those in which tornadoes occur in the vicinity of the site.				Clarification added with respect to homogeneous region. The text recommending use of the largest tornado in the site vicinity is not appropriate. The wider region needs to be considered to develop the tornado inventory since tornados at any site are rare events (see footnote).
10.	4.37.	The results of a hazard evaluation for tornadoes should be the annual frequency of exceedance at which a particular site will experience tornado wind speeds in excess of a specified value. In addition, consideration should be given to the most severe tornadoes that have occurred within a smaller area surrounding the site (e.g. within a 50 km radius). <u>However,</u> the area to be investigated for tornado occurrence should be based on the meteorological conditions of the location, without being limited to its shape and size.	Added a note that the study area for tornado occurrence need not be limited to shape and size.				Revised the existing text for clarity but did not add proposed text.
11.	4.65.	If significant snowfall occurs in the region, an assessment should be made of the snowfall distribution. Remote sensing data taken after snowstorms at the site may be helpful in this task in	Clarification.			✓ ✓	Existing text is clear.

Revi	ewer: Jap	an NUSSC member	Page of		RESOL	LUTION	
Cou	ntry/Orga	nization: Japan / NRA	Date:16,				
Nay No.	, 2025 Para/Li ne No.	Proposed new text	Reason	Accep ted	Accepted, but modified as follows	Reject ed	Reason for modification/rej ection
		evaluating the accumulation of snow due to snowstorms. The variables that should be considered include precipitation rate and snow depth, packing density, and snow cover. Depending on the location of the nuclear installation site, maps depicting the estimated snow load may be available in building codes and standards.	The reason why remote sensing data are obtained after snowstorms seems unclear.				
12.	5.46.	(e) Several large waves could be observed; the first one might not be the largest. A recession of the sea could be observed in general before the first wave and between each consecutive flooding. A tsunami could cause inland inundation because its wavelength is so long that a huge mass of water follows behind the wave front. Propagation along the rivers towards inland is also common.	Could not be said to be in general.				The term "in general" was changed to "in many cases".
13.	5.48.	Earthquakes are the most frequent source of tsunamis. An earthquake induced tsunami is generated by a seafloor deformation associated with submarine and near-coast earthquakes with shallow depth (e.g. $< 50$ km), large magnitude (e.g. $M > 6.5$ ) and dip–slip mechanism.	Clarify the values as examples. The values are not internationally defined values but are considered to be examples of criteria.	1			Proposed text added.
14.	5.53.	As an initial assessment, a simplified screening criterion should be applied (see Fig. 1). Using publicly available information (see para. 3.35), evidence of past occurrences of tsunamis should be reviewed for the site region. The evidence should be collected as far back in time as possible. For this purpose, the information collected should be organized and a list of tsunamis relevant to the nuclear installation site should	Clarify the values as examples. The values are not internationally defined values but				The criteria of distance was changed to 20 km. Furthermore, the "or condition" between the

		COMMENTS BY REVIEWER					
Revi	ewer: Jap	an NUSSC member	Page of		RESOL	UTION	
Cou	ntry/Orga	nization: Japan / NRA	Date:16,				
May	, 2025						
No.	Para/Li ne No.	Proposed new text	Reason	Accep ted	Accepted, but modified as follows	Reject ed	Reason for modification/rej ection
		<ul> <li>be prepared. No further investigations and studies need to be performed to analyse the tsunami hazard for the site provided that:</li> <li>(a)</li> <li>(b) The site is located more than e.g. 10 km from the sea or ocean shoreline, or more than e.g. 1 km from a lake or fjord shoreline, as appropriate; or</li> <li>(c) The site is at more than e.g. 50 m elevation from the mean water level.</li> </ul>	are considered to be examples of criteria.				distance and height was changed to "and condition". According to this modification, FIG.1 was also revised.
15.	5.66.	The collection of site specific long term data tends to reduce uncertainties. However, s <u>S</u> ome of the data that are used indirectly in the evaluation of tsunami hazards might not be site specific; for example, the seismogenic data used to characterize the generation mechanism of distant sources. There may therefore be a part of the uncertainty that is irreducible with respect to site specific investigations.	It is difficult to say that observational data can reduce uncertainties. The interval between major tsunami is much longer than between small ones.				Proposed deletion accepted.
16.	5.67. (b) (ii)	<ul> <li>(b)</li> <li>(ii)Determine applicable seismic tsunami scenarios in accordance with the seismogenic sources identified in (<u>i</u>a);</li> </ul>	Editorial.	1			Accepted
17.	5.69.	Note that for megathrust earthquakes of Mw 98-class or greater, the tsunami should be numerically simulated using a non-uniform slip model.	We also consider that Mw8-class earthquake tsunami should be simulated using a non-uniform slip fault model.	1			Proposed text added
18.	5.76.	Owing to the small size of a source in comparison with that for an earthquake induced tsunami, the impacts of a landslide induced tsunami are <u>generally</u> limited around the source and <u>, but sometimes they</u> are <u>generally not</u> observed at more than several tens of kilometres from the source. The impact of a landslide tsunami around the source will depend <u>mainly</u> on the slope gradient map of the bathymetric data near the coast and bathymetric data <u>e.g.</u> up to the continental shelf is	This could lead to an underestimation of far fields tsunamis(e.g. massive landslides: 5.52). 5.74 states that "e.g. slope gradient map of bathymetric data, material	1			Proposed edits adopted.

		COMMENTS BY REVIEWER					
Revi	ewer: Jap	ban NUSSC member	Page of		RESOL	UTION	
Cour	ntry/Orga 2025	inization: Japan / NRA	Date: 16,				
No.	Para/Li ne No.	Proposed new text	Reason	Accep ted	Accepted, but modified as follows	Reject ed	Reason for modification/rej ection
		necessary to take into account the landslide sources. If the landslide source is near the coast, then the tsunami effect is more prominent; if the source is in the ocean and far from the coast then its height at the coast may be negligible. Therefore, the landslide source size and location should be taken into account.	characteristics and other available data". In some cases, the continental shelf is not well developed.				
19.	5.91.	If active drainage systems are necessary to provide adequate flood protection, <u>defence in depthMulti</u> <u>protection</u> should be ensured through the implementation of appropriate preventive and mitigating measures to be incorporated into the design and operation of the drainage system.	Wording.				"Defense in depth" is a high- level IAEA safety requirement.
20.	6.4.	The likelihood of fire ignition and propagation to the site should be assessed. Factors such as weather conditions, forested areas close to the site (i.e. within typically 10–30 km), historical fire patterns and the most probable wind direction should be considered.	Clarify the values as examples. The values are considered to be comprehensive examples of criteria in Member States.		1		Added "typically" and deleted "i.e."
21.	6.28 6.31.	<ul> <li>6.30. To-If it is necessary to evaluate the hazard to a nuclear installation from a meteorite impact, a spectrum of meteoroids at the top of the atmosphere — ranging at least from several centimetres in diameter to several tens of metres —with a range of impact velocities and impact angles at the top of the atmosphere should be considered.</li> <li>6.31. For meteorites hitting the earth's surface with most of their initial velocity, several other impacts on the nuclear installation site (i.e. in addition to a direct hit on SSCs) are possible and should be</li> </ul>	Meteoroids and meteorites are very low frequency events. In some member states, there are no regulatory requirements for hazard evaluation of these events. Should all of the recommendations in this subsection be carried out in site evaluation? At least paras 6.30 and 6.31 seem to be				Added "In some member states, there are no regulatory requirements for hazard evaluation of these events." To the footnote in para 6.28. Added proposed edits to para 6.30 and 6.31.

		COMMENTS BY REVIEWER					
Revi	ewer: Jap	ban NUSSC member	Page of		RESOL	<b>JUTION</b>	
Cour	ntry/Orga	inization: Japan / NRA	Date:16,				
No.	Para/Li ne No.	Proposed new text	Reason	Accep ted	Accepted, but modified as follows	Reject ed	Reason for modification/rej ection
		evaluated, if necessary. Meteorites with most of their initial velocity create craters with depths and diameters commensurate with the impact energy on the earth's surface. These impacts produce ejecta, pressure waves, heat blasts, vibratory ground motions and — if they impact on large water bodies — tsunami-like phenomena all of which may hit a nuclear installation even if the impact point is far away from the nuclear installation site. The potential impacts should be considered in the hazard evaluation.	recommendations to be carried out if the hazard level exceeds a certain threshold.				
22.	8.5.	In some cases, protection can be achieved by a combination of the two approaches outlined in para. 8.4. For both approaches, <del>a defence in depth-<u>multi</u> protection</del> strategy should be adopted.	Wording.			1	"Defense in depth" is a high- level IAEA safety requirement.
23.	8.9.	Nuclear installation sites should implement various practical safety measures to protect from wildfire. Common precautions include: (a) Vegetation should be maintained <u>to be and</u> cleared for an appropriate distance surrounding the installation to reduce the potential impact of wildfires spreading to the facility. This can be achieved through vegetation management practices.	The relationship between "maintained" and "cleared" seems unclear.		<ul> <li>Image: A start of the start of</li></ul>		Changed "maintained" to "managed"
24.	11.6.	In the radiological hazard categorization approach a graded approach is typically applied on the basis of the consequences of an uncontrolled, unmitigated radioactive release from the nuclear installation	It seems better to use the same wording as Table 1.	<b>√</b>			Proposed edit adopted.

		COMMENTS BY REVIEWER					
Revi	ewer: Jap	pan NUSSC member	Page of		RESOL	UTION	
Cour	ntry/Orga	nization: Japan / NRA	Date: 16,				
May	, 2025		1				D C
NO.	Para/Li ne No.	Proposed new text	Reason	Accep ted	Accepted, but modified as follows	Reject ed	Reason for modification/rej ection
		(some applications of the approach may consider mitigation; see para 11.11). Four radiological hazard categories, based on the consequences of unmitigated releases, are defined in Table 1. Categories range, from 'high', which corresponds to large nuclear power plants, to 'conventional', which corresponds to industrial facilities that have <u>no or</u> <u>negligible radiological consequences</u> <u>negligible or no</u> <u>radiological hazard</u> .					
25.	ANN EX I JAPA N I-5.	Table I–4 provides examples of criteria used in Japan for defining the design basis parameters for a given meteorological variable for existing nuclear power plants in Japan. These meteorological design basis parameters correspond to single load cases that are associated in design codes with different load combinations and different load factors for designing SSCs. Reference [I–5] defines criteria for Tornadoes design basis parameters. TABLE I-4. EXAMPLES OF <u>THE DESIGN BASIS</u> <u>PARAMETERSJAPANESE CRITERIA</u> FOR CHARACTERIZING METEOROLOGICAL AND HYDROLOGICAL VARIABLES <u>AS TAKEN</u> <u>FROM THE PRACTICE IN JAPAN</u>	Table I-4 is not criteria. It should be changed to the appropriate title <del>.</del>				Proposed edits adopted
26.	ANN EX II–6	Based on the seismological, geological, and geophysical background and field survey data for past tsunamis (paleo and historical tsunamis), the	Editorial.	1			Proposed edits adopted.

		COMMENTS BY REVIEWER						
Revi	ewer: Jar	oan NUSSC member	Pa	ige of		RESOL	UTION	
Cour	ntry/Orga	nization: Japan / NRA	D	Date: 16,				
May	, 2025							
No.	Para/Li ne No.	Proposed new text	Reason	1	Accep ted	Accepted, but modified as follows	Reject ed	Reason for modification/rej ection
		following events and their combinations need to be considered as tsunami sources:						
		(a)Inter-plate earthquakes;					l	
		<ul> <li>(b)Intra-plate earthquakes <u>in oceanic(subducting)</u> <u>plate;</u></li> <li>(c)Offshore active faults <u>crustal earthquakes;</u></li> <li>(d)Submarine and subaerial landslides;</li> <li>(e)Volcanic phenomena (e.g. eruptions, mountain collapses, caldera collapse)</li> </ul>						
27.	ANN EX II–11	The first step in the second part of the process is to select the potential zones in which earthquake, submarine and subaerial landslides, and volcanic phenomena induced tsunamis can occur. Generally, the effects of near field tsunamis are greater than those of far field tsunamis. The latter cannot be neglected, however, because the effects depend on geographical conditions and directional relations to the tsunami source. In Japan, major source areas are at tectonic plate boundaries (the Kurile trench, the Japan trench and the Nankai trough), the eastern margin of the Sea of Japan (East Sea)67 and <u>Offshore</u> active submarine faults around the Japanese archipelago for near field tsunamis, and off the west coast of South America for far field tsunamis.	Editorial.					Proposed edits adopted.

		COMMENTS BY REVIEWER						
Revi	ewer: Jap	ban NUSSC member		Page of	RESOLUTION			
Country/Organization: Japan / NRA				Date:16,				
May	, 2025		-					•
No.	Para/Li ne No.	Proposed new text	Reaso	n	Accep ted	Accepted, but modified as follows	Reject ed	Reason for modification/rej ection
28.	ANN EX II–16	For verification of the design basis tsunami, the two conditions of para. II– $\frac{2218}{18}$ -need to be confirmed. The concept of verification is shown in the lower part of Fig. II–2.	Editorial.		✓ 			Proposed edit adopted.

COMMENTS BY REVIEWER				RESOLUTION			
Reviewer: Poke Mashita							
Page 1 of 1							
Country/Organization: National Nuclear Regulator, South Africa							
Date: 19.05.2025							
Comment	Para/Line	Proposed new text	Reason	Accepted	Accepted, but	Rejected	Reason for
No.	No.				modified as follows		modification/rejection
1.		No comment	Draft is consistent with	$\checkmark$			Thank you!
			the DPP. Objectives and				
			scope are addressed				
			properly, etc.				

COMMENTS BY REVIEWER					RESOL	LUTION	
Reviewer: USNRC							
Country/Organization: USNRC Date: May 18, 2025			-				
Comment No.	Para/ Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection
1	Page 6 Hydrologic al Hazards 2.7	Include "Combined events"	There is mention of combined events flooding on page 81. However, it is important to state in the list the potential combined events flooding effect from two different floods causing mechanisms. NRC NUREG/CR-7046 provides additional information. Combined events could include coastal and non-coastal flooding, or dam breach and flooding in streams and rivers, etc.				Added (h) Credible combined events.
2	Page 6 Hydrologic al Hazards 2.7 (g)	Backwater effects due to impoundments	It's unclear how backwater effects are being considered as a phenomenon beyond what would normally be included in riverine flooding analysis. Recommend deletion or further clarity.		✓		Section on impounding (paras 5.165-5.168) discusses scenarios other than the usual backwater effects in the riverine flooding analysis. Modified (g) to read "(g) Backwater effects due to downstream blockages or impoundments"

COMMENTS BY REVIEWER					RESOL	LUTION	
Reviewer: USNRC							
Country/Organization: USNRC Date: May 18, 2025							
Comment No.	Para/ Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection
3	Page 6	There is no mention of surface water – groundwater interaction. This is important because the hydrologic process is comprised of the interaction between surface water and groundwater. The analysis of accidental or operational release of radioactive liquid effluents is governed by transport mechanisms that span across surface water and groundwater depending on where the source term is located.	Include a discussion on the interaction between surface water and groundwater with a focus on the accidental and operational release of radioactive liquid effluents.			✓ 	This comment seems to refer to the impact of the installation on the surrounding environment. This topic is address in NS-G-3.2 "Dispersion of Radioactive Material in Air and Water and Consideration of Population Distribution in Site Evaluation for Nuclear Power Plants"
4	Page 49	Tsunami analysis flowchart (Figure 1)	The distance of >10 km might need to be revisited because mega- tsunamis could potentially travel 20 km or more. Some language that either use "and" instead of "or" with some descriptive language to tsunamigenic sources might be worth considering.	√			These criteria depend on regions, as commented by the reviewer. And, it is inappropriate to apply the criteria alone, because damage was occurred up to 12 km from the shoreline when the 2011 Tohoku earthquake.

COMMENTS BY REVIEWER					RESOL	UTION	
Reviewer: USNRC							
Country/Organization: USNRC Date: May 1			Date: May 18, 2025				
Comment No.	Para/ Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection So, 10 km from the shoreline was changed to 20 km from the shoreline. Furthremore, "or condition" was applied to between the conditions on the distance from the sea or lake and those on the height were connected by but it was changed to "and condition".
5	Page 56	Local intense precipitation flooding. Consider storm maximization recommendations to address temporal and spatial variations.	One example would be consideration of different precipitation loading scenarios (such as front, middle, and back) during the development of flood simulation model.	√			Added "Different precipitation temporal distributions (such as front-loaded, middle- loaded, and back- loaded) should be considered." To para 5.90.
6	Page 96	The graded approach recommended will be based on radiological hazard categorization or risk-informed approach. Is there a dose based quantitative measure that will be used to enhance the qualitative description provided in Table 1?	Consider including a dose based and proximity-based criteria to enhance the discussion			$\checkmark$	Individual Member State regulations provide dose-based quantitative criteria. These are beyond the scope of this guide.

COMMENTS BY REVIEWER					RESOL	UTION	
Reviewer: USNRC							
Country/Organization: USNRC			Date: May 18, 2025				
Comment No.	Para/ Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection
		Also, is there consideration for multi-unit sites or sites that are in very close proximity to an existing nuclear facility?					Everything in this section applies to both single-unit and multi-unit sites.

## DS 541 – Assessment of Meteorological and Hydrological Hazards in Site Evaluation for Nuclear Installations Comments Resolution Table – WASSC

Step 7

COMMENTS BY REVIEWER					RESOLUTION			
Reviewer: WASSC Member								
Page 1 of 1								
Country/Or	ganization: Re							
Date: May	16, 2025							
Comment	Para/Line	Proposed new text	Reason	Accepted	Accepted, but	Rejected	Reason for	
No.	No.				modified as follows		modification/rejection	
1	Page 82/	The following is suggested.	o In my opinion, the term	✓			The revision was made	
	Para 7.4		of site emergencies could				according to the	
	Line 6	(before) ~~~ off-site resources used	be ambiguous. So, it				comments.	
		in the response to site emergencies.	should be replaced with it					
		(after) ~~~ off-site resources used in	based on the IAEA					
		the emergency preparedness and	glossary.					
		response.						