		COMME	NTS BY REVIEWER	RESOLUTION					
		ian Nuclear Safety Commissi							
Count		tion: CANADA	Date: 2013/05/31		1				
Com ment No.	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/ rejection		
	General	Possibly at clause 1.9 (wording is suggested onlyplease edit as required to meet IAEA writing style) "The guidance provided in this document may also be applied to the design of instrumentation and control systems for SMRs in a manner that is commensurate with the risks presented by the facility"	 This document is very well written, comprehensive and the requirements (shalls) and guidance (shoulds) are written in a technology neutral fashion. The scope of this document, however, requires a clarification to be added to confirm whether the document is applicable to nearterm deployable SMRs. This is particularly true for integrated light water reactor (ILWR) designs that are at a reasonably advanced state of design such as, but not limited to the: Korean SMART Generation mPower NuScale With that said, the document was reviewed from the point of view of how it might be applied to a very small SMR (e.g. 10 MWe). The conclusion is that the contents of DS431 are actually written at a level where the requirements and guidance can be applied asis to SMR I&C design as long as consideration is given to risks presented by the facility. (i.e. recognize that the requirements and guidance can be met by alternative means) CNSC is aware that the IAEA is at the initial DPP development stages for a possible document to cover "Instrumentation and Control for Advanced Small Modular Reactors". Based on the CNSC's review of DS431, CNSC suggests that this new DPP be developed to <u>supplement</u> DS431 rather than lead to the new proposed document should seek to identify address those SMR issues that differ significantly from what is found in DS431 such as shared I&C architectures between multiple units, increased use of automation and remote monitoring and control 						

Canada Comments on DS431: Design of Instrumentation and Control Systems for Nuclear Power Plants (Draft K)

	and unique environmental conditions that require novel I&C		
	solutions.		

DS431 Design of Instrumentation and Control Systems for Nuclear Power Plants, draft K 25th April 2013

		COMMENTS BY REVIEWER					
Reviewer:		M-L Järvinen/Heimo T takala	Page1 of 2				
Country/Or	ganization:	Finland	Date: 31.5.2013				
Comment	Para/Line	Proposed new text	Reason	Accept	Accepted, but modified as	Reje	Reason for
No.	No.			ed	follows	cted	modification/rejection
	General	The proposed new draft version K of DS431 incorporates a large number of changes based on comments made on the previous version of the draft guide. Finland supports the new version of the draft and proposes the following technical comments to be	Finland thanks the IAEA Technical Officers and the expert team responsible this draft and appreciate the quality of the draft and how the many improvements are carried out.				
	0 1	considered by the Agency for the preparation of the next version of the document.					
	General	The draft guide should be reviewed against the IAEA safety classification document DS367 rev. 8 April 2013 and revised where necessary	The new IAEA safety classification draft safety guide DS367 rev. 8 is accepted by CSS for submission to Publication Committee and is not expected to change. The new guide will propose somewhat different safety classification and categorization as the old IAEA safety classification guide.				
			This new safety grading is more appropriate for nuclear I&C and the I&C document draft DS431 should support it.				

Configura tion managem ent: 2.38 – 2.55		the configuration items are inevitable in plannig of the configuration		
Para 6.72, spurious action/op eration	At the end of para: ", cause spurious action by error in (SW) design or parametrization."	-		

May 2013 Comments on IAEA Draft Safety Guide "Design of Instrumentation and Control Systems for Nuclear Power Plants" (DS431)

		COMMENTS BY REVIEW	WER					
Reviewer:				RESOLUTION				
Country/Org	anization: US	S Nuclear Regulatory Commi	ssion Date: 6/05/2013					
Comment No. / Reviewer	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/ rejection	
1	2.18	Human Factors Engineering and establishment of computer security are examples of such activities.	"Computer Security" is not an activity. Instead, it is an established characteristic of a system. The activity is efforts to establish this characteristic.					
2	2.19	Replace "computer security" with "Cyber Security.", or change Figure 1 term to "Computer Security."	Terminology is not consistent with the terms used in Figure 1. Figure 1 uses "cyber security."					
3	2.25	Add Bullets for : • System Training, and • System Operation	Plans should also be developed for providing system training to operators and maintenance personnel. Planning should include operations plan.					
4	2.25	Consider adding a new bullet for "Cyber Security Plan.	Later in clauses 2.34, 2.35, and 2.36 the guide refers to a computer or cyber security plan but it is not included in 2.25 as an I&C planning topic.					
5	2.61	Add the following clause to the end of the sentence:	The guide should include the objective of addressing the potential for introducing new hazards into the system during					

Page 2 of 9	Page	2	of	9	
-------------	------	---	----	---	--

							Fage 2 01 9
Reviewer:		COMMENTS BY REVIEW	VER		RES	OLUTION	
Country/Orga	anization: US	S Nuclear Regulatory Commi	ssion Date: 6/05/2013				
Comment No. / Reviewer	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/ rejection
		" to ensure that hazards introduced to the system during the development process are adequately addressed."	development.				
6	2.85	Change last sentence to: "Claims for better reliabilities than this are not precluded, however, special justification should be provided, taking into account all of the factors mentioned."	Except for the last sentence, the clause can be viewed as informative guidance. Inclusion of the last sentence (as written) makes this a mandatory clause				
7	2.125a	Rewrite to say: "Challenge all integration interfaces, including hardware to software, software module to module, and overall I&C system with plant systems;	The current integration aspects omit the concept of integrating the I&C system into the plant systems.				
8	2.130	Replace the first sentence with: "For the purpose of this guide, the majority of system validation is	The second sentence contradicts the previous sentence.				

Page	3	of	9
I ugu	, 0	U.	J

COMMENTS BY REVIEWER RESOLUTION Reviewer: Country/Organization: US Nuclear Regulatory Commission Date: 6/05/2013 Accepted, Reason for Comment Para/Line No. / Proposed new text Accepted but modified Rejected modification/ Reason No. as follows Reviewer rejection complete when the system has been installed into the plant." Limitations of equipment The equipment preventing safety functions to protective provisions 3.14.d be performed are a realistic that could prevent the 9 (Design constraint. "Limitations on safety systems from Basis) materials to be used" is accomplishing their identified, 3.15.d.5, but this safety functions should not be the same. Additional clauses have been added since this reference was created. Change last phrase to: 4.22 I believe the reference is 10 "... of paragraphs 6.26 to intended to be to the whole 6.58" independence section which is 6.26 through 6.58. The final clause could be read as Probabilistic studies "internal events given in this should not treat I&C items document," implying a list of important to safety as fully events that is not found in the independent unless they document. Relocating the are diverse, and meet the 11 4.40 clause makes it clear that the guidance for functional guidance is "given in this independence given in this document." document, including electrical isolation,

	Pag	e 4	of	9
--	-----	-----	----	---

							Page 4 01 9
Reviewer:		COMMENTS BY REVIE	WER		RES	OLUTION	
Country/Orga	anization: US	S Nuclear Regulatory Commi	ssion Date: 6/05/2013				
Comment No. / Reviewer	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/ rejection
		communications independence, environmental qualification, seismic qualification, electromagnetic qualification, physical separation, and protection against internal events given in this document.					
12	4.41	Delete the word "simply" from the last sentence. Also reword as follows: "In probabilistic studies, failure probabilities for systems that are fully independent are calculated by taking the product of their individual failure probabilities." Sentence could also be deleted to resolve this	The last sentence in this clause incorrectly implies that simply taking the product of individual failure probabilities is a sufficient means of establishing independence.				
13	5.10	item. Delete the term "safety related." Replace with	Clause 5.12 states that this guide will avoid using the term				

	Page	5	of	9	
--	------	---	----	---	--

							1 age 5 61 5	
Reviewer:		COMMENTS BY REVIE	VER	RESOLUTION				
Country/Ora	Country/Organization: US Nuclear Regulatory Commission Date: 6/05/2013							
Comment No. / Reviewer	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/ rejection	
		"Items important to safety but not safety systems."	"safety related."				•	
14	5.12	Re-title the left most list of systems in Figure 3 as "Not Part of Safety System" in order to avoid use of the term "safety- related."	This clause claims that this guide avoids the use of the term "safety related," however; the term is defined within this same clause and is used in Figure 3.					
15	6.5	Delete one of the Clause 6.5's.	Clause 6.5 on page 47 is duplicated.					
16	6.16 through 6.19 / 1 (Single Failure Criterion)	Delete these steps.	There should be no justification within the design for non-compliance with the single failure criterion. The remote likelihood for postulated failures being discounted is an argument the NRC has steadfastly denied. As an example, the CCF in the safety system will require a DAS (regardless of the likelihood of a CCF). Another example is whether LBLOCA should be distinct from SBLOCAs. In this case, ITS systems are less qualified and less developed, making failures more likely than in a safety system. Requirements					

							1 age 0 01 9
Reviewer:		COMMENTS BY REVIE	RESOLUTION				
Country/Org	anization: U	S Nuclear Regulatory Commi	ission Date: 6/05/2013				
Comment No. / Reviewer	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/ rejection
			and guidance basis: 10 CFR 50 Appendix A Criterion 21 and IEEE Std 379 do not exclude SFC based on likelihood of failure.				
17	6.17	Delete first two bullets.	Allowing SFC exception due to rarity of PIE or when consequences are improbable opens the door to using PRA analysis as a tool for skirting the SFC criteria. SFC criteria should be applied to all safety systems and functions regardless of the likelihood of needing that safety function.				
18	6.49	Add statement: "Member countries may have additional requirements and restrictions on connections of non-safety maintenance systems to safety systems."	Different member countries have different requirements on connection of lower safety class maintenance systems to safety equipment. This should be pointed out in this guide. For example, the US only allows temporary connections of non- safety maintenance systems to safety systems that is enforced through physical disconnects.				
40	0.405	Change to:	This clause conflicts with clause				

6.167 in that Clause 6.165 does

not include provision for systems

19

6.165

"When possible, system

Page 7	of	9
--------	----	---

							Fage / U
Reviewer:		COMMENTS BY REVIE	WER		RES	OLUTION	
teviewei.							
Country/Orga	anization: US	S Nuclear Regulatory Commi	ssion Date: 6/05/2013				
Comment No. / Reviewer	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/ rejection
		designs should include provisions for testing and calibration of safety system equipment in all modes of normal operations, including power operation, while retaining the capability of the safety systems to accomplish their safety functions.	or components that cannot be feasibly tested during power operation as is accounted for in Clause 6.167.				
20	6.167.b	Delete the word "untested" from this clause.	There can be no interval between tests when the components are "untested."				
21	6.209, 2 nd bullet	Revise as follows: "Analytical limit (of setpoint) – The margin between the analytical limit and the safety limit takes into account: the response time of the instrument channel, analytical inaccuracies , modeling inaccuracies , plant dynamic response , and the range of transients due to the accident	Analytical Limit definition should include analytical and modeling inaccuracies.				

Page	8	of	9
------	---	----	---

COMMENTS BY REVIEWER RESOLUTION Reviewer: Country/Organization: US Nuclear Regulatory Commission Date: 6/05/2013 Accepted, Reason for Comment Para/Line No. / Proposed new text Accepted but modified Rejected modification/ Reason No. as follows Reviewer rejection considered. Revise as follows: Uncertainties should include those uncertainties that are "Limiting settings for associated with random and bias safety systems should be terms. calculated using a documented methodology that provides sufficient allowance between the trip setpoint and the 22 6.213 analytical limit to account for measurement and channel biases, uncertainties, including those associated with random and bias terms, and any changes to these values which occur over time." "should satisfy all No justification to limit or identify reliability, redundancy, just these few requirements; all and independence safety safety requirements should be 23 7.52 requirements in the maintained by the safety system in the presence of any nonpresence of a failure of any component ..." safety system failure. Replace "... the Transfers of power supply do not associated interruption in always have an associated 24 7.62 supply" with "... any interruption in supply.

Page 9) of 9	
--------	--------	--

	COMMENTS BY REVIEW	VER					
		RESOLUTION					
Country/Organization: US Nuclear Regulatory Commission Date: 6/05/2013							
Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/ rejection	
	associated interruption in supply".						
7.81	Replace the word "recommendations" with "guidance." Guidance was the term used in 7.101.	Reference to Independence section is inconsistent with the reference provided in 7.101.					
7.122	Recommend deleting clause 7.122.	Since operators could in fact pose an insider threat, I do not understand why the criteria of 7.119 through 7.121 should not also apply to their activities. I see no down side to monitoring and logging control room operator activities.					
8.23	Change reference to " 8.22 items a, b, c, and e should be classified as safety"	In the reference to 8.22, letter e should also be classified as safety because the protection / safety function depends on it.					
	Para/Line No. 7.81 7.122	anization:US Nuclear Regulatory CommiPara/Line No.Proposed new textassociated interruption in supply".7.81Replace the word "recommendations" with "guidance." Guidance was the term used in 7.101.7.122Recommend deleting clause 7.122.8.23Change reference to " 8.22 items a, b, c, and e should be classified as	Para/Line No. Proposed new text Reason associated interruption in supply". associated interruption in supply". Reference to Independence section is inconsistent with the "guidance." Guidance was the term used in 7.101. Reference to Independence section is inconsistent with the reference provided in 7.101. 7.122 Recommend deleting clause 7.122. Since operators could in fact pose an insider threat, I do not understand why the criteria of 7.119 through 7.121 should not also apply to their activities. I see no down side to monitoring and logging control room operator activities. 8.23 " 8.22 items a, b, c, and e should be classified as In the reference to 8.22, letter e should also be classified as	anization: US Nuclear Regulatory Commission Date: 6/05/2013 Para/Line No. Proposed new text Reason Accepted associated interruption in supply". Replace the word "recommendations" with "guidance." Guidance was the term used in 7.101. Reference to Independence section is inconsistent with the reference provided in 7.101. 7.122 Recommend deleting clause 7.122. Since operators could in fact pose an insider threat, I do not understand why the criteria of 7.119 through 7.121 should not also apply to their activities. I see no down side to monitoring and logging control room operator activities. 8.23 Change reference to " 8.22 items a, b, c, and e should be classified as In the reference to 8.22, letter e should also be classified as	RESI anization: US Nuclear Regulatory Commission Date: 6/05/2013 Para/Line No. Proposed new text Reason Accepted but modified as follows associated interruption in supply". associated interruption in supply". Reference to Independence Replace the word "recommendations" with "guidance." Guidance was the term used in 7.101. Reference to Independence section is inconsistent with the reference provided in 7.101. 7.122 Recommend deleting clause 7.122. Since operators could in fact pose an insider threat, I do not understand why the criteria of 7.119 through 7.121 should not also apply to their activities. I see no down side to monitoring and logging control room operator activities. 8.23 " 8.22 items a, b, c, and e should also be classified as safety because the protection / safety function depends on it.	RESOLUTION anization: US Nuclear Regulatory Commission Date: 6/05/2013 Para/Line No. Proposed new text Reason Accepted but modified as follows Rejected as follows Para/Line No. Proposed new text Reason Accepted Accepted but modified as follows Rejected Replace the word "recommendations" with "guidance: "Guidance was the term used in 7.101. Reference to Independence section is inconsistent with the reference provided in 7.101. Since operators could in fact pose an insider threat, 1 do not understand why the criteria of 7.119 through 7.121 should not also apply to their activities. I see no down side to monitoring and logging control room operator activities. Image: Change reference to should also be classified as safety because the protection / safety function depends on it. Image: Change reference to should be classified as In the reference to 8.22, letter e should also be classified as Image: Change reference to should also be classified as	

Design of instrumentation and control systems for NPP, DS431 draft K

		COMMEN	NTS BY REVIEWER		RESC	LUTION	
Review	wer:		Page.1. ofx				
Count	ry/Organiza	ation: FRANCE/IRSN	Date: 2013/05/09				
Com ment No.	Para/Line No.	Proposed new text	Reason	Accept ed	Accepted, but modified as follows	Rejecte d	Reason for modification/rej ection
FR 1	General	See other comments	France thanks the project leader for the many improvements made to solve the open items and the "some member states" issues. In particular the treatment of these issues in a unique place (annex 3) clarifies the whole document. In its current writing the annex III could sometimes lack some clarification about what is consensual and what is not. -some practices are presented as applied by "some MS"; this is correct; -but some practices, also only applied by these Member States, are presented in general statements, which by contrast with the first case could give the wrong impression that such practices are accepted by all MS. Thus some modifications (see comments about annex 3) are needed to distinguish what is consensual from what is recognized by some Member States.				
FR2	General	See other comments	We have limited the corresponding comments to the minimum in number and scope, in order to ease and accelerate the resolution process. The two comments about annex 3 (FR12 and FR13) are considered to be important.				
			The other comments are suggestions to further increase the technical quality of the guide.				
FR 3	2.138	Replace with: "The functional tests should be designed to cover all behaviours allowed by the functional requirements and their structural coverage, resulting from this	A system has several functional behaviours; each of them may correspond to many internal execution cases. The test campaign must provide assurance that : A1) all required behaviours are (correctly) implemented A2) no other behaviour is present A3) all execution cases corresponding to a given behaviour				

		l		[]	- I
		functional design, should be justified."	involve the same structural part of the software (thus testing this behaviour gives information for all corresponding execution cases).		
			Whatever the number of tests performed in practice, this number will always be infinitely small compared to the number of possible execution cases. Thus, if the tests are not correctly designed they can miss some behaviour: their number does not guarantee their adequacy. As a result, the only way to fulfil A1, A2 and A3 is a sound analysis, not the brute-force; so the testing strategy promoted in domains concerned by safety (nuclear, avionics, etc.) is:		
			-design the tests to cover all behaviours allowed by the functional requirements. This must be done by an independent team, who makes its own analysis of the functional requirements (i.e. independent from the analysis of the requirements made by the development team).		
			-only after the tests have been formalized, analyse how they cover the internal structure of the software. If the coverage is not correct, this may indicate that the software has behaviours not required (infringes A2) or implemented with extraneous complexity (infringes A3).		
			-perform the tests and check whether the system responds as specified by the test scenario (guarantees A1)		
FR4	7.70 1rst sentence	Full verification and validation of such complex components could be very difficult or even practically impossible, <u>if they</u> were not correctly designed.	This general statement is a conditional: "could". Given its importance for safety it is mandatory to mention the corresponding condition. If not limited in scope, the statement would also be inconsistent with clauses 2.67 and 2.69 which require full verification and validation.		
			In fact, the design requirements for safety systems (see e.g. IEC 60880) are elaborated primarily to allow full V&V. The safety guide must reflect this to be up to date.		
FR5	7.70 2 nd sentence	Unidentified errors are likely to might exist and they might exist in all redundant components	"are likely to exist" is too strong for safety systems properly developed. This is confirmed by more than 30 years of positive experience feedback. Otherwise, the guide should definitely ban digital safety systems to fulfil the overall safety objectives (see e.g. 1.7).		

	7.71 2 nd	Add to both sentences: "if they	All safety systems must be designed to avoid the mentioned	
aı	and 3^{rd}	were not correctly designed"	adverse effects. This is explicitly required by the safety standards;	
S€	sentences		see e.g. IEC 60880 or IEC 62340.	
			The safety guide must reflect this to be up to date.	
FR7 7.	7.76	Response time and accuracy of	The sampling rate and the processing cycle time (not to be	
		digital systems are heavily	confused with "processor" cycle time) are part of the functional	
		influenced by functionally	requirements.	
		depend on the sample rate and	The safety systems must be designed so that these parameters do	
		on the processing processor	not depend on variations of the intrinsic processor speed.	
		cycle time. In systems not	Otherwise the clause 7.74 of the guide (deterministic behaviour)	
		correctly designed, these	could not be fulfilled, especially with "modern" processors (i.e.	
		parameters could depend on	posterior to 1995) of which the intrinsic speed is essentially	
		the and processor speed.	unpredictable, including for successive iterations of the same	
			loop.	
			This design property is explicitly required by the safety standards;	
			see e.g. IEC 60880 or IEC 62340.	
			The safety guide must reflect this to be up to date.	
FR8 (7	7.145	Provide the definition of "HPD"	The term "HPD" is correctly used in the guide, but not defined.	
a	and	in the relevant location of the		
7.	7.147)	guide:		
		HDL-Programmed Device:		
		integrated circuit configured		
		(for NPP I&C systems), with		
		Hardware Description		
		Languages and related software		
		tools.		
		(IEC 62566)		
FR9 7.	7.145.a	Replace "HDL Programmed	For editorial consistency.	
aı	and f;	Device" with "HPD"		
7.	7.148			
FR10 7.	7.148.a	Confirm that no hidden circuits	The wording "hidden circuits exist" is ambiguous in this context.	
		unspecified function exist has	It could be interpreted as referring to the basic micro-electronic	
		been programmed	circuits embedded in the silicon itself: the verification process	
			cannot address this. It only addresses what is programmed in	
			HDL.	
			Probably the intent is to match the software verification process	
			(which verifies the code, not the low-level circuits of the	
			microprocessor).	
FR11 8.	8.60.e	(should) be the simplest design consistent with	A "should" requirement for the "simplest design" implies that the designer has to provide a justification based on a measure of	

		function	simplicity, but no such metrics is widely recognized.		
FR12	Annex III-2, 2 nd sentence	Thus to estimate digital system reliability it is necessary to estimate the probability of system failure due to both hardware failure and, for some Member States, software error. For other Member States design errors (including software errors) and their consequences are not adequately treated by probabilities but only by qualitative analyses of the	Needed to:		
FR13	Annex III-4	architecture and of the design. Add at the beginning: "For the Member States who apply numerical reliability to software,"	Needed to clarify what is consensual and what is not.		

		COMMENTS BY REVIEWERS		RESOLUTION				
	IEC/SC45A Secretar		Page.1. of7					
Country/Organiz Comment No.	ation: IEC/SC45A Para/Line No.	Date:2013/05/ Proposed new text	Reason	Accepted	Accepted, but modified	Rejected	Reason for	
Comment No.	F al a/Line No.	r toposed new text	Keason	Accepted	as follows	Rejected	modification/rejection	
1	General	IEC/SC45A supports draft K dated 25 th of April 2013 submitted for comments for the 35th NUSSC meeting and proposes the following technical comments prepared by IEC/SC45A experts to be considered by the Agency for the preparation of the next version of the document.	IEC/SC45AexpertsacknowledgedtheworkdonebythetheIAEATechnicalOfficersandtheexpertteamwhichproducedthisdraftandrecognizedthehighqualityofthisdocumentandthehighlevelofofconsensusit reached.IEC/SC45AnotedthenumerousformulatedontakenconsensuallyintoaccordingtakenconsensuallyintoaccordingtakenonesformulatedduringtakeninparticularthenumerousinparticulartheonesformulatedduringtheNUSSCmembersrecommendationsinparticulartheonesformulatedduringthestaftJAEA SafetyGuideas a basic documenttodevelopIEC/SC45A		as follows		modification/rejection	

Design of instrumentation and control systems for NPP (DS431)

			standards, as soon as it will			
			be published.	ļ		
2	1.15 pages 9-10	Reword the last sentence:	Effluent monitoring			
		"Examples of I&C systems to which this	systems and I&C for fuel			
		guide may apply include:"	handling are important to			
			safety in some member			
			states and not important to safety in some others			
			member states.			
3	Fig 1	In Fig. 1, Add a bracket "cybersecurity	Cybersecurity related parts			
5	Fig. 1 (mentioned in	•	(right side) of Fig. 1 are			
	2.19 & 2.29)	cycle level".	misleading:			
	2.17×2.27		- They give the false			
		Change CDA in "graded approach to	impression that there is no			
		security" or "security level/degree	cybersecurity activity at the			
		assignment"	individual system life-cycle			
			level, which is wrong;			
			- Overall terminology and			
			concepts are inconsistent			
			with IAEA NSS17. In			
			particular, the identification			
			of Critical Digital Asset is a			
			US (NRC RG5.71) concept.			
			IAEA NSS17 concepts			
			should be privileged.			
4	2.82	Security testing usually involves	The terms "know			
		vulnerability assessment and respect of	vulnerabilities/unknown			
		security good practice.	vulnerabilities" are not			
			clear. Moreover,			
			penetration testing is useful			
			only when the system is in			
			place in the target			
			architecture.			
5	2.85	when all of the potential sources of				
		failures" (excluding cybersecurity related	to quantify attack			
		ones)	probability on I&C systems:			
			we suggest adding a			
			parenthesis to exclude this			
			aspect.	ļ		
6	6.5 page 47	Recommendation 6.5 is written twice.	Туро			

	< F0			[[
7	6.50 page 52	Add the following sentence:	As per clause 6.168. I&C		
		"Monitoring systems of lower safety	systems should have self-		
		classification may be connected to safety	supervision or monitoring		
		systems provided that it is demonstrated	features that allow regular		
		that they cannot disturb them."	confirmation of their		
			continued correct operation.		
			~		
			Considering the		
			functionality to be		
			implemented in the		
			monitoring systems, it is		
			common that the terminal		
			which displays the detailed		
			state of the safety systems		
			to the maintenance		
			operators cannot be safety		
			systems. A demonstration		
			that such monitoring		
			systems of lower safety		
			classification cannot disturb		
			the safety systems to which		
			they are connected has to be		
			provided in this situation.		
8	6.72 page 55	The failures that might result from software	The identification of all		
		errors are difficult to predict. Nevertheless,	possible failure modes for a		
		it is not necessary to know how the	PLC based systems, which		
		software fails to determine the possible	includes thousands of		
		failure states as seen at device terminal. The	variables, several internal		
		most likely possible failure modes could be	states, and multiple		
		identified and classified into a manageable	interfaces and outputs,		
		set of possibilities, e.g. wrong output,	cannot be done. This is in		
		delayed output, frozen output.	line with the first sentence		
			of recommendation 6.72.		
			However, expectable failure		
			modes can be identified and		
			addressed.		
9	7.126	Remove "such as scanning for security	It is proposed to group		
		vulnerabilities"	specific considerations on		
			security scanning in 7.129,		
			as right now, it is split		
			between 7.126 and 7.129.		

10	7.129	Remove "for safety systems"	Scanning should be made
-			on off-line system for all
			I&C systems, not only
			safety ones.
11	7.99 page 82	Delete	IEC/SC45A experts do not
	1 - 1 - 1		understand why the clause
			removed in revision J has
			been reintroduced.
			IEC/SC45A experts noted
			that communication
			between safety divisions
			concern essentially the
			votes.
			Each division typically
			sends its partial trip to the
			others and receive partial
			trip from the others to do
			the votes.
			In such a case, it is unclear
			how one-directional
			communication is possible
			between safety divisions.
12	7.140 page 86	Delete	IEC/SC45A experts noted
			that there is no definition of
			what is "IP cores" and in
			this context this
			recommendation would be
			extremely difficult to apply.
			In the frame of the
			elaboration of the IEC
			62566 standard,
			IEC/SC45A experts have
			concluded that it was not
			possible to provide a viable definition for IP core
			because the terminology
			widely differs between
			vendors.
			IEC/SC45A experts noted
			also that from a formal
			perspective it is difficult to
	1		poispective it is unificant to

	1				1	
			have a recommendation to			
			avoid IP cores that is			
			directly followed by a			
			clause that contradicts this			
			recommendation. Simply			
			deleting clause 7.140			
			resolves the contradiction.			
13	9.41+	(additional section, set at the end of the	IEC/SC45A experts noted			
		design section, or close to 9.35)	that there can only be one			
		The software design should take into	software design process:			
		account the best practices in terms of	this guide must refer to			
		information security, in order to avoid the	software secure			
		creation of vulnerabilities by design, that	development			
		are easy to exploit by malware or hackers,	methodologies, that may be			
		and difficult to fix.	further developed in another			
			document (dedicated to			
			cybersecurity). A large			
			number of vulnerabilities			
			for I&C systems was made			
			public during the years			
			2011 to 2013. Many of			
			those are caused by design,			
			that addressed well safety &			
			reliability, but ignored			
			security. We now have			
			many unfixable devices in			
			the field, with "exploits"			
			easy to use and publicly			
			available.			
			The requirement could be			
			"shall" for safety systems			
			actually (and "should" for			
14	0.50 mar 100	Mana the sectores (These sec	non safety)		<u> </u>	
14	9.59 page 106	Move the sentence "There are many	IEC/SC45A experts noted			
		different sources of potential coincident	that this sentence is			
		software failures and statistical	applicable only for some			
		independence cannot always be assumed;	member states that use			
		this would need to be accounted for in any	numerical reliability target			
		claim for the reliability achieved. » in	for software.			
		appendix III	Consequently, it is			
			suggested to move this			

			sentence in appendix III.		
15	9.60+	(additional section, set at the end of the implementation section, or close to 9.53) Implementation teams should be trained on secure development techniques. Development methodologies and tools should include the best practices in terms of secure development.	IEC/SC45A experts noted that as for comment #1, the same rational applies to software development. Although in theory software security vulnerabilities that are caused during the development are easier to fix (patches), in reality, patching (especially of I&C) is difficult to perform.		
16	9.90+	(two additional sections, set at the end of the verification section, or close to 9.78 for code review, and 9.89 for pen tests) The code should be reviewed to check for software security vulnerabilities, using automated tools and complemented by manual review of the critical sections of the code (I/O handling, exception handling) For safety systems, the resulting application should be submitted to security-specific testing (such as pen testing), to make sure that common security vulnerabilities are not easy to detect, and to allow for continuous improvement of the software design and implementation.	(same rational as #2 and #3)		
17	III – 6 page 125	Add the following sentence: Some member states use a qualitative approach for determining SW reliability. Such qualitative approach is typically based on strong requirements on the deterministic behaviour of the software to allow a full verification and validation. Such combination of strong design requirements that allow full V&V gives a high confidence in the reliability of the software.	A description of the qualitative approaches used in some other member states is proposed by IEC/SC45A experts for consideration.		
18	III – 7 page 125	Paragraph 4.32 recommends that an analysis should be done of the consequences of each PIE in combination with CCF that will prevent the I&C safety	IEC/SC45A experts noted that this sentence was modified to match recommendation 4.32		

systems a protection system from	which it refers to.		
performing the needed safety functions.			

Design of instrumentation and control systems for NPP (DS431)

COMMENTS BY REVIEWER				RESOLUTION			
Reviewer: Country/Organization: Switzerland/ENSI			Page.1 of 1 Date:2013/05/29				
Comment No.	Para/Line No.	Proposed new text	Reason	Accepted	Accepted, but modified as follows	Rejected	Reason for modification/rejection
1	2.79 / 1	(Add Reference for GS-R-4)	Reference is missing				
2	3.6/3	The objective of these functions, corresponding to the concept of defence in depth, are to					
3	6.72 / 5	, spurious output actions.	spurious output actions are not mentioned				